

FIRE ALARM RISER DIAGRAM

NOT TO SCALE

- SHEET NOTES**
1. DISCONNECT AND REMOVE EXISTING FACP. REPLACE WITH NEW FACP SPECIFIED. PROVIDE (2) #12 CONDUCTORS AND RECONNECT ALL FIRE ALARM CIRCUITS, POWER CONDUCTORS, AND TELEPHONE LINES.
 2. LOCATED NEAR THE FACP.

Ownership of Documents
 This document, the ideas and designs incorporated herein, as an instrument of Professional Service is the property of Integrated Designs by SOMAM, Inc. and is not to be used, in whole or in part for any other project without written authorization.
 © COPYRIGHT 2009

integrated designs by SOMAM, Inc.
 ARCHITECTURE • ENGINEERING • INTERIOR DESIGN • CONSTRUCTION MANAGEMENT
 8011 N. Fresno, Suite 130 - Fresno, California 93710
 Phone (559) 436-0887 Fax (559) 436-0887 E-Mail: design@somam.com
 www.integrateddesigns.com

Rev. No.	Date	Revision Description


FIRE ALARM RISER DIAGRAMS

**FREMONT MAGNET ELEM. SCHOOL
 14 CLASSROOM BLDG.**
 BAKERSFIELD CITY SCHOOL DISTRICT
 607 TEXAS ST. BAKERSFIELD, CA 93307

Issue Date: _____
 Date: _____
 Designer: _____
 DFR: _____
 PC: _____

DSA Identification Stamp:

FILE # : _____
 IDENTIFICATION STAMP
 DIV. OF THE STATE ARCHITECT
 OFFICE OF REGULATION SERVICES
 03-112891
 AC: [Signature] FLS: [Signature] SS: [Signature]
 DATE: 2-19-09
 TRACKING # : _____



Job No.: **3829.1**

BORRELLI AND ASSOCIATES, INC.
 CONSULTING ELECTRICAL ENGINEERS
 180 N. FRENCO AVENUE
 FRESNO, CALIFORNIA 93704
 PH: 559-233-4248 FAX: 559-254-4254
 848# 99134
 HTTP://WWW.BORRELLIENGINEERING.COM
 E-MAIL: ADMIN@BORRELLIENGINEERING.COM

Sheet No.: **E3.2**

Release: _____