

TITLE 24 MECHANICAL & PLUMBING REQUIREMENTS (CODE REFERENCES ARE TO 2019 BUILDING ENERGY EFFICIENCY STANDARDS):

- All air cooled HVAC units shall have minimum efficiencies per Table 110.2-A.
- All furnaces shall have minimum efficiencies per Table 110.2-1.
- All furnaces shall have stand-by loss controls per section 110.2 (d).
- All thermostats shall comply with 110 (b) or (c), as applicable.
- All HVAC systems shall have outside (ventilation) air per 120.1 (b) 2. Also see mechanical plans for minimum outside air settings. Refer to table on plan.
- When CO2 ventilation demand controls are specified, provide in accordance with 120.1 C. 4.
- Minimum ventilation rates shall be initiated one hour prior to scheduled occupancy per 120.1 (c) 2.
- Each HVAC system shall have shut-off and reset controls complying with 120.2 (e).
- All outside and exhaust dampers shall automatically close per 120.2 (f).
- All systems greater than a nominal 54 MBH cooling capacity shall have economizers equipped with fault detection and diagnostics per 120.2 (i).
- All ductwork insulation shall comply with 120.4.
- Set up all thermostats with a dead band of no less than three degrees to prevent cycling between heating and cooling.
- Acceptance tests required prior to granting occupancy. NA refers to Non Residential appendices:
 - Outdoor air ventilation systems per NA 7.5.1.
 - Constant volume single zone system controls per NA 7.5.2.
 - Air economizers per NA 7.5.4.
 - Demand control (CO2) controls, when required, per NA 7.5.5.
 - Fault Detection & Diagnostics (FDD) per NA 7.5.11.

Equipment Anchorage Notes:

All Mechanical, Plumbing, and Electrical components shall be anchored and installed per the details on the DSA approved construction documents. The following components shall be anchored or braced to meet the force and displacement requirements prescribed in the 2019 CBC, Sections 1617A.1.18 through 1617A.1.26 and ASCE 7-16 Chapters 13, 26 and 30.

- All permanent equipment and components.
- Temporary, movable or mobile equipment that is permanently attached (E.G. hard wired) to the building utility services such as electricity, gas or water. "Permanently attached" shall include all electrical connections except plugs for 110/220 volt receptacles having a flexible cable.
- Temporary, movable or mobile equipment which is heavier than 400 pounds or has a center mass located 4 feet or more above the adjacent floor or roof level that directly support the component are required to be restrained in a manner approved by DSA.

The following Mechanical and Electrical components shall be positively attached to the structure, but need not demonstrate design compliance with the references noted above. These components shall have flexible connections provided between the component and associated ductwork, piping and conduit. Flexible connections must allow movement in both transverse and longitudinal directions:

- Components weighing less than 400 pounds and have a center of mass located 4 feet or less above the adjacent floor or roof level that directly support the component.
- Components weighing less than 20 pounds, or in the case of distributed systems, less than 5 pounds per foot, which are suspended from a roof or floor or hung from a wall.

The anchorage of all Mechanical, Electrical and Plumbing components shall be subject to the approval of the design professional in general responsible charge or structural engineer delegated responsibility and acceptance by DSA. The project inspector will verify that all components and equipment have been anchored in accordance with above requirements.

Piping, Ductwork, and Electrical Distribution System Bracing Note:

Piping, ductwork, and Electrical distribution systems shall be braced to comply with the forces and displacements prescribed in ASCE 7-16 Section 13.3 as defined in ASCE 7-16 Section 13.6.5, 13.6.6, 13.6.7, 13.6.8, and 2019 CBC, Sections 1617A.1.24, 1617A.1.25 and 1617A.1.26.

The method of showing bracing and attachments to the structure for the identified distribution system are as noted below. When bracing and attachments are based on a pre-approved installation guide (e.g., OSHPD OPM for 2013 CBC or later), copies of the bracing system installation guide or manual shall be available on the jobsite prior to the start of and during the hanging and bracing of the distribution systems. The Structural Engineer of Record shall verify the adequacy of the structure to support the hanger and brace loads.

Mechanical Piping (MP), Mechanical Ducts (MD), Plumbing Piping (PP), Electrical Distribution Systems (ES):

Option 1: Detailed on the approved drawings with project specific notes and details

Option 2: Shall comply with the applicable OSHPD Pre-Approval (OPM#) # OPM 0052-13 B-LINE/TOLCO SYSTEM

Air Conditioning Legend

SYMBOL	ABBV	ITEM	SYMBOL	ABBV	ITEM
	A.C.	Air Conditioning		H.W.R.	Heating Water Return
	A.A.D.	Access Door		H.W.S.	Heating Water Supply
	A.A.F.	Above Finished Floor		INT.	Intermittent
	A.H.	Air Handler		LOC.	Location
	B.A.S.	Building Automation System		M.O.	Motor Operator
	B.V.	Butterfly Valve		N.	New
	C.D.	Condensate Drain		N.C.	Normally Closed
	C.E.R.	Ceiling Exhaust Register		N.I.C.	Not in Contact
	C.W.R.	Condenser Water Return		N.O.	Normally Open
	C.W.R.	Chilled Water Return		O.S.A.	Outside Air
	C.W.S.	Chilled Water Supply		O.B.D.	Opposed Blade Damper
	C.	Connection		P.O.C.	Point of Connection
	C.	Control		P.R.V.	Pressure Reducing Valve
	C.R.R.	Ceiling Return Register		R.	Register
	C.S.R.	Ceiling Supply Register		S.F.D.	Smoke / Fire Damper w/ alarm panel
	C.V.	Check Valve		S.M.	Sheet Metal
	D.C.W.	Domestic Cold Water		S.O.V.	Shut Off Valve
	D.	Damper		S.P.S.T.	Single Pole Single Throw
	D.L.	Door Latch		F.S.	Fire/Smoke or Room Sensor
	D.P.D.T.	Double Pole Double Throw		TYP.	Typical
	D.T.R.	Duct Thru Roof		U.	Underground
	E.	Existing		U.N.O.	Unknown Noted Otherwise
	E.F.	Exhaust Fan		V.D.	Volume Damper
	E.M.S.	Energy Management System		V.V.	VAV Damper w/ Remote Operator
	F.A.C.P.	Fire Alarm Control Panel		W.R.	Wall Return Register
	F.C.	Flexible Connection		W.S.	Wall Supply Register
	F.T.R.	Fluor Thru Roof		Z.	Zone w/ Anularis Lining
	F.	Furnace		T.V.	Tuning Vanes
	G.	Gauge		E.	Extractor
	G.	Gasket			
	G.	Gasketed			
	G.P.M.	Gaskets per Minute			
	G.V.	Globe Valve			
				U.	Upset
				R.I.	Reducer or Inletor

EQUIPMENT SCHEDULE

HP-1
Carrier 50CCQM06 Rooftop Heat Pump, 1,800 CFM @ 0.60 E.S.P., 0.66 BHP direct drive supply fan drive vane-axial fan with electrically commutated motor, 1,200 CFM low speed (staged air volume), 61,300 BTUH total / 46,320 sensible gross cooling / 54,860 heating capacity / 16.2 SEER / 11.7 EER / 8.3 HSPF at ARI conditions. Two stage cooling, 5 year compressor warranty, high and low pressure switches, adjustable defrost timer, and anti-short cycle timer. (4) 16" x 16" x 2" MERV 8 return air filters, 10.6 kW electric strip heater factory mounted and wired, single point power connection for heat pump and strip heater. Integrated modulating economizer with dry bulb control, fault diagnostics and detection per T24 regulations, power exhaust fan module, demand control ventilation package with wall mounted CO2 sensor set to 1000 ppm. Adjust outside airflow to modulate between hi-low settings per O.A. schedule on plans. Include information on both settings in air balance report. Provide separate power feed and disconnect for economizer power exhaust fan. Sloped roof curb with seismic hold down clips, internal high and low compressor protection.
Electrical: 34 MCA / 40 MOCP @ 460v-3ph. (HP Unit) Operating Weight: 816 Lbs.
1.9 MCA / 3.4 MOCP @ 460v-3ph. (Power Exhaust) Curb: 107 Lbs.

HP-2
Carrier 50VT-C24 Rooftop Heat Pump, 700 CFM @ 0.40 E.S.P., 0.38 BHP direct drive supply fan motor, 22,620 BTUH total / 16,730 sensible net cooling / 22,380 heating capacity / 14.5 SEER / 8.2 HSPF at ARI conditions. Single stage cooling, 5 year compressor warranty, high and low pressure switches, adjustable defrost timer, and anti-short cycle timer. 2" Deep MERV 13 return air filters in factory filter rack, 5.4 kW electric strip heater, factory mounted and wired, single point power connection for heat pump and strip heater. Motorized two-position outside air damper. Sloped roof curb with seismic hold down clips internal high and low compressor protection.
Electrical: 53.7 MCA / 60 MOCP @ 208v-1ph. (HP Unit) Operating Weight: Unit 326 Lbs. Curb 65 Lbs.

HP-3
Carrier 50FCQM07 Rooftop Heat Pump, 2,100 CFM @ 0.60 E.S.P., 0.83 direct drive supply fan drive vane-axial fan with electrically commutated motor, 1,400 CFM low speed (staged air volume), 73,450 BTUH total / 55,300 sensible gross cooling / 63,550 heating capacity / 11.2 EER / 15.0 IEER / 3.6 COP at ARI conditions. Two stage cooling, 5 year compressor warranty, high and low pressure switches, adjustable defrost timer, and anti-short cycle timer. (4) 16" x 16" x 2" MERV 8 return air filters, 10.6 kW electric strip heater factory mounted and wired, single point power connection for heat pump and strip heater. Integrated modulating economizer with dry bulb control, fault diagnostics and detection per T24 regulations, power exhaust fan module, demand control ventilation package with wall mounted CO2 sensor set to 1000 ppm. Adjust outside airflow to modulate between hi-low settings per O.A. schedule on plans. Include information on both settings in air balance report. Provide separate power feed and disconnect for economizer power exhaust fan. Sloped roof curb with seismic hold down clips, internal high and low compressor protection.
Electrical: 31 MCA / 35 MOCP @ 460v-3ph. (HP Unit) Operating Weight: 809 Lbs.
3.5 MCA / 6.3 MOCP @ 460v-3ph. (Power Exhaust) Curb: 107 Lbs.

EF-1
Greenheck SPA-50-90-VG Ceiling Mounted Exhaust Fan, 90 CFM @ 0.20" E.S.P., 887 RPM, 6 watts ECM motor, 0.7 zones. Provide with backdraft damper, full size discharge to roof cap, and NEMA-1 toggle switch. Interlock fan operation with light circuit. Dial on fan speed control with time delay set to fifteen minutes.
Electrical: 6 Watts @ 115v-1ph. Operating Weight: 12 Lbs.

Codes:

- California Code of Regulations (C.C.R.)
 - Part 1 - 2022 California Standards Administrative Code, Title 24, C.C.R.
 - Part 2 - 2019 California Building Code (C.B.C.), Title 24, C.C.R. Volumes 1-3.
 - Part 3 - 2019 California Electrical Code, Title 24, C.C.R.
 - Part 4 - 2019 California Mechanical Code (C.M.C.), Title 24, C.C.R.
 - Part 5 - 2019 California Plumbing Code (C.P.C.), Title 24, C.C.R.
 - Part 6 - 2019 California Energy Code, Title 24, C.C.R.
 - Part 9 - 2019 California Fire Code, Title 24, C.C.R.
 - Part 11 - 2019 California Green Code, Title 24, C.C.R.

Standards and Guides:

- ADAAG - American with Disabilities Act, Accessibility Guidelines.
- Fixtures - Plumbing fixtures to comply with table 5.303.6 of the California Green Building Standards - 2019 Edition.

General Project Note:

- Coordination of work: Layout of materials, equipment and systems is generally diagrammatic unless specifically dimensioned. Some work may be shown offset for clarity. The actual location of all materials, piping, ductwork, fixtures, equipment, supports, etc. shall be carefully planned, prior to installation of any work to avoid all interferences with each other, or with structural, electrical, architectural or other elements. Verify the proper voltage and phase of all equipment with the electrical plans. All conflicts shall be called to the attention of the architect and the engineer prior to the installation of any work or the ordering of any equipment.
- Cutting, boring, saw cutting or drilling through the new or existing structural elements to be done only when so detailed in the drawings or accepted by the Architect and Structural engineer with the approval of DSA representative.

GRILLE SCHEDULE

- CD-1**
Titus Model TDC Louvered Face Diffuser with T-Bar mount frame and O.B.D. See diffuser sizing chart for neck sizes.
- CD-2**
Titus Model TDC Louvered Face Diffuser with flat surface mount frame and O.B.D. See diffuser sizing chart for neck size.
- CR-1**
Titus Model 50F eggcrate T-Bar mount return grille.
Note: Paint all visible surfaces behind diffusers and grilles flat black.

DIFFUSER SIZING CHART

CFM	TITUS MCD, SQUARE NECK	CFM	TITUS TDC, SQUARE NECK
0 - 200	6" x 6"	0 - 150	6" x 6"
201 - 325	8" x 8"	151 - 215	9" x 9"
326 - 450	10" x 10"	216 - 415	12" x 12"
451 - 600	12" x 12"	416 - 700	15" x 15"
601 - 700	14" x 14"	701 - 950	18" x 18"
701 - 850	16" x 16"	951 - 1250	21" x 21"
851 - 950	18" x 18"	1251 - 1700	24" x 24"
951 - 1150	20" x 20"	1701 - 2500	30" x 30"

The California Energy Code Section 10-103 requires Acceptance Testing on all newly installed lighting controls, mechanical systems, envelopes, and process equipment after installation and before project completion. An Acceptance Test is a functional performance test to help ensure that newly installed equipment is operating and in compliance with the Energy Code.


Lighting controls acceptance tests must be performed by a certified lighting controls Acceptance Test Technician (ATT). Mechanical system acceptance tests must be performed by a certified mechanical ATT for projects submitted on or after October 1, 2021.

Envelope and process equipment acceptance tests shall be performed by the installing contractor, engineer/architect of record or the owner's agent.

A listing of certified ATT can be found at: <https://www.energy.ca.gov/programs-and-topics/programs/acceptance-test-technician-certification-provider-program/acceptance>.

The Acceptance Testing procedures must be repeated, and deficiencies must be corrected by the builder or installing contractor until the construction/installation of the specified systems conform and pass the required acceptance criteria.

Project inspectors will collect the forms to confirm that the required Acceptance Tests have been completed.



Central Plant Demo Keynotes:

- Remove existing chiller, all chilled water piping, hangers, supports, etc.
- Cap mechanical piping at 6" above grade. Abandon existing below grade chilled / hot water loop piping.
- Remove all existing pumps, expansion tanks, pot feeder, supports, controls, accessories, etc.
- Demo back domestic CW pipe back to entry into chiller yard and cap.
- Remove existing EMG and / or analog control panel, all related conduits, wiring, controls, etc.
- Remove existing boiler, all hot water piping, supports, etc.
- Remove existing flue thru roof, roof jack, etc.
- Cap and patch / weatherproof openings in boiler building walls and roof to match existing.
- Remove existing control air compressor all piping, controls, etc.
- Demo gas pipe back to 6" inside Boiler Room and cap.
- Note: Entire central plant chiller yard and boiler room shall be made free of all mechanical, plumbing, electrical, and control items related to items being removed. Confirm exact details based on field conditions.

CHILLER YARD AND BOILER ROOM DEMO PLAN
SCALE: 1/8"=1'-0"

IDENTIFICATION STAMP
DIV. OF THE STATE ARCHITECT
APP: 03-122920 INC.
REVIEWED FOR:
SS FLS ACS
DATE: 07/05/2023

PTN: 63321- FILE: 15-6

ROOSEVELT ELEMENTARY SCHOOL
MODERNIZATION
2324 VERDE STREET
FOR
BAKERSFIELD CITY SCHOOL DISTRICT
BAKERSFIELD, KERN COUNTY, CALIFORNIA



1601 NEW STINE ROAD, SUITE 280
BAKERSFIELD, CA 93309
PH: (661) 397-4377
FAX: (661) 397-4378
WWW.SCARCHITECT.COM

STEPHEN J. CARROLL, ALLIED - AP
CHECK AND VERIFY ALL DIMENSIONS BEFORE PROCEEDING WITH THE WORK. REPORT DISCREPANCIES TO THE ARCHITECT. ALL CONSTRUCTION SHALL CONFORM TO THE C.B.C.

MECHANICAL SITE PLAN

MARK	DATE	REVISIONS
△		
△		
△		

JOB NO. 1317
DRAWN: B.S.
CHECKED: M.B.
DATE: 8/5/21


M
1.0

MECHANICAL SITE PLAN
SCALE: 1"=30'-0"


bme BASKIN MECHANICAL ENGINEERS

175 Fulton Street
Fresno, CA 93721
Tel: (559) 237-0376
Job: 21146
Pit: 12-13-22







DUCT HANGER UPPER ATTACHMENT
 SCALE: N.T.S. **G**




THERMOSTAT MOUNTING LOCATION
 SCALE: N.T.S. **D**




CEILING DIFFUSER/REGISTER CONNECTION
 SCALE: N.T.S. **A**




HP UNIT INTERLOCKS WITH FIRE ALARM PANEL
 SCALE: N.T.S. **H**




LAN ARCHITECTURE
 SCALE: N.T.S. **E**



SUPPLY AIR PLENUM & BRANCH TAKE-OFFS
 SCALE: N.T.S. **B**



EX. FAN CONTROL DETAIL
 SCALE: N.T.S. **F**




NINETY DEGREE ELBOW
 SCALE: N.T.S. **C**

ROOSEVELT ELEMENTARY SCHOOL
 MODERNIZATION
 2324 VERDE STREET
 FOR
 BAKERSFIELD CITY SCHOOL DISTRICT
 BAKERSFIELD, KERN COUNTY, CALIFORNIA



1601 NEW STINE ROAD, SUITE 280
 BAKERSFIELD, CA 93309
 PH: (661) 397-4377
 FAX: (661) 397-4378
 WWW.SCARCHITECT.COM



CHECK AND VERIFY ALL DIMENSIONS BEFORE PROCEEDING WITH THE WORK. REPORT DISCREPANCIES TO THE ARCHITECT. ALL CONSTRUCTION SHALL CONFORM TO THE C.B.C.

MECHANICAL DETAILS

MARK	DATE	REVISIONS
△		
△		
△		

JOB NO.	1317
DRAWN:	B.S.
CHECKED:	M.B.
DATE:	8/5/21




ROOSEVELT ELEMENTARY SCHOOL
 MODERNIZATION
 2324 VERDE STREET
 FOR
 BAKERSFIELD CITY SCHOOL DISTRICT
 BAKERSFIELD, KERN COUNTY, CALIFORNIA



1601 NEW STINE ROAD, SUITE 280
 BAKERSFIELD, CA 93309
 PH: (661) 397-4377
 FAX: (661) 397-4378
 WWW.SCARCHITECT.COM


STEPHEN CARROLL, ARCHITECT
 LICENSED ARCHITECT
 No. 1788
 JAN 11 2024
 STATE OF CALIFORNIA
 CHECK AND VERIFY ALL DIMENSIONS BEFORE PROCEEDING WITH THE WORK. REPORT DISCREPANCIES TO THE ARCHITECT. ALL CONSTRUCTION SHALL CONFORM TO THE C.B.C.




MECHANICAL
 DETAILS

MARK	DATE	REVISIONS
△		
△		
△		

JOB NO.
 1317
 DRAWN:
 B.S.
 CHECKED:
 M.B.
 DATE:
 8/5/21




(HP-1,HP-3) UNIT CURB 816 lb. MAX UNIT WT.




(HP-2) UNIT CURB 326 lb. MAX UNIT WT.

UNIT ANCHORAGE
 SCALE: N.T.S.




A







TRANSVERSE RIGID BRACING FOR TRAPEZE SUPPORTED RECTANGULAR DUCT
 SCALE: N.T.S. **A**




LONGITUDINAL RIGID BRACING FOR TRAPEZE SUPPORTED RECTANGULAR DUCT
 SCALE: N.T.S. **B**




TRANSVERSE & LONGITUDINAL COMBINATION RIGID BRACING FOR TRAPEZE SUPPORTED RECTANGULAR DUCT
 SCALE: N.T.S. **C**



TRANSVERSE RIGID BRACING FOR STRAP SUPPORTED ROUND DUCT
 SCALE: N.T.S. **D**



LONGITUDINAL RIGID BRACING FOR STRAP SUPPORTED ROUND DUCT
 SCALE: N.T.S. **E**



TRANSVERSE & LONGITUDINAL COMBINATION RIGID BRACING FOR STRAP SUPPORTED ROUND DUCT
 SCALE: N.T.S. **F**

PTN: 63321- FILE: 15-6

ROOSEVELT ELEMENTARY SCHOOL
 MODERNIZATION
 2324 VERDE STREET
 FOR
 BAKERSFIELD CITY SCHOOL DISTRICT
 BAKERSFIELD, KERN COUNTY, CALIFORNIA




1601 NEW STINE ROAD, SUITE 280
 BAKERSFIELD, CA 93309
 PH: (661) 397-4377
 FAX: (661) 397-4378
 WWW.SCARCHITECT.COM

STEPHEN J. CARROLL, ALLIANCE - AP
 CHECK AND VERIFY ALL DIMENSIONS BEFORE PROCEEDING WITH THE WORK. REPORT DISCREPANCIES TO THE ARCHITECT. ALL CONSTRUCTION SHALL CONFORM TO THE C.B.C.

MECHANICAL DETAILS


MARK	DATE	REVISIONS
△		
△		
△		

JOB NO. 1317
 DRAWN: B.S.
 CHECKED: M.B.
 DATE: 8/5/21




175 Fulton Street
 Fresno, CA 93721
 Tel: (559) 237-0376
 Job: 21146
 Pit: 12-13-22






BRACE ATTACHMENT TO STUD WALL
 SCALE: N.T.S. **A**



THRU-BOLT STRUCTURAL ATTACHMENTS PERPENDICULAR TO WOOD BEAM
 SCALE: N.T.S. **B**




THRU-BOLT STRUCTURAL ATTACHMENTS PARALLEL TO WOOD BEAM
 SCALE: N.T.S. **C**

ROOSEVELT ELEMENTARY SCHOOL
 MODERNIZATION
 2324 VERDE STREET
 FOR
 BAKERSFIELD CITY SCHOOL DISTRICT
 BAKERSFIELD, KERN COUNTY, CALIFORNIA



1601 NEW STINE ROAD, SUITE 280
 BAKERSFIELD, CA 93309
 PH: (661) 397-4377
 FAX: (661) 397-4378
 WWW.SCARCHITECT.COM

STEPHEN CARROLL, AIA, LEED®-AP
 ARCHITECT
 CHECK AND VERIFY ALL DIMENSIONS BEFORE PROCEEDING WITH THE WORK. REPORT DISCREPANCIES TO THE ARCHITECT. ALL CONSTRUCTION SHALL CONFORM TO THE C.B.C.



MECHANICAL DETAILS

MARK	DATE	REVISIONS
△		
△		
△		

JOB NO.
1317
 DRAWN:
 B.S.
 CHECKED:
 M.B.
 DATE:
 8/5/21



1.4



bme BASKIN MECHANICAL ENGINEERS
 175 Fulton Street
 Fresno, CA 93721
 Tel: (559) 237-0376
 Job: 21146
 Pjt: 12-13-22

ROOSEVELT ELEMENTARY SCHOOL
 MODERNIZATION
 2324 VERDE STREET
 FOR
 BAKERSFIELD CITY SCHOOL DISTRICT
 BAKERSFIELD, KERN COUNTY, CALIFORNIA



1601 NEW STINE ROAD, SUITE 280
 BAKERSFIELD, CA 93309
 PH: (661) 397-4377
 FAX: (661) 397-4378
 WWW.SCARCHITECT.COM

Stephen C. Carr
 STEPHEN C. CARR, ALLIED®-AP
 CHECK AND VERIFY ALL DIMENSIONS BEFORE PROCEEDING WITH THE WORK. REPORT DISCREPANCIES TO THE ARCHITECT. ALL CONSTRUCTION SHALL CONFORM TO THE C.B.C.







MECHANICAL PLAN BUILDING 'A'

MARK	DATE	REVISIONS
△		
△		
△		

JOB NO.
1317
 DRAWN:
 B.S.
 CHECKED:
 M.B.
 DATE:
 8/5/21

M
2.0




MECHANICAL FLOOR PLAN KEY NOTES.
 1. DEMO EXISTING CEILING EXHAUST FAN AND EXHAUST DUCT. RETAIN ROOF CAP FOR RE-USE.
 2. INSTALL NEW EXHAUST FAN AND DISCHARGE DUCT. EXTEND TO CONNECTION AT EXISTING ROOF CAP.


MECHANICAL PLAN BUILDING 'A'
 SCALE: 1/8"=1'-0"

bne BASKIN MECHANICAL ENGINEERS
 175 Fulton Street
 Fresno, CA 93721
 Tel: (559) 237-0376
 Job: 21146
 Plt: 12-13-22






MECHANICAL PLAN BUILDING 'B'
 SCALE: 1/8"=1'-0"



MECHANICAL PLAN BUILDING 'C'
 SCALE: 1/8"=1'-0"

- MECHANICAL FLOOR PLAN KEY NOTES**
1. REMOVE EXISTING FLOOR MOUNTED UNIT VENTILATOR, ALL RELATED MECHANICAL PIPING, CONDENSATE PIPING, CONTROLS, SUPPORTS, ANCHORAGE, ETC. PATCH EXISTING SURFACES TO MATCH EXISTING.
 2. REMOVE EXISTING OUTSIDE AIR LOUVERS. INFILL / PATCH WALL TO MATCH EXISTING.
 3. REMOVE EXISTING HYDRONIC AND CONDENSATE PIPING AND EXTERIOR CHASE. REMOVE PIPING TO 12" BELOW GRADE. CAP PIPING AND ABANDON IN PLACE.
 4. REMOVE EXISTING GRAVITY RELIEF VENT, DUCTWORK, RELIEF GRILLE, ETC. INFILL TO MATCH SURROUNDING CONSTRUCTION.
 5. EXISTING WASTE VENT, TYPICAL. CONFIRM EXACT LOCATION IN FIELD.
 6. ABANDON IN PLACE BELOW GRADE SITE HYDRONIC PIPING.
 7. ROOF MOUNTED HEAT PUMP UNIT. SEE MECHANICAL ROOF PLAN.
 8. 12" X 18" SUPPLY AIR DROP WITH 1" LINER, 14" X 20" NET. PROVIDE MITERED ELBOW AT BOTTOM OF RISER. SEE DETAIL C/M1.1.
 9. 26" X 11" RETURN AIR RISEK WITH 1" LINER, 28" X 13" NET. PROVIDE MITERED ELBOW AT BOTTOM OF RISER. SEE DETAIL C/M1.1.
 10. CD-1 TYPICAL. SEE DETAIL A/M1.1.
 11. CR-1 TYPICAL.
 12. T-STAT LOCATION TYPICAL. CLASSROOMS USE PELICAN TS250 WITH CO2 SENSOR AND DEMAND CONTROL VENTILATION.
 13. 12" X 12" SUPPLY AND RETURN AIR DROPS WITH 1" LINER, 14" X 14" NET. PROVIDE MITERED ELBOW AT BOTTOM OF RISER. SEE DETAIL C/M1.1.
 14. THIS THERMOSTAT TO BE A PELICAN TS200.
 15. NO MECHANICAL WORK IN THIS ROOM.
 16. SEE TYP. BRANCH DUCT DETAIL B/M1.1.
 17. PELICAN WIRELESS GATEWAY w/ 115V PLUG CONNECTED TO WALL OUTLET AND CONNECTION TO LOCAL ROUTER. PROVIDE WALL MTD. BRACKET FOR MOUNTING. SEE DETAILS E&F/M1.1.

ROOSEVELT ELEMENTARY SCHOOL
 MODERNIZATION
 2324 VERDE STREET
 FOR
 BAKERSFIELD CITY SCHOOL DISTRICT
 BAKERSFIELD, KERN COUNTY, CALIFORNIA



1601 NEW STINE ROAD, SUITE 280
 BAKERSFIELD, CA 93309
 PH: (661) 397-4377
 FAX: (661) 397-4378
 WWW.SCARCHITECT.COM



CHECK AND VERIFY ALL DIMENSIONS BEFORE PROCEEDING WITH THE WORK. REPORT DISCREPANCIES TO THE ARCHITECT. ALL CONSTRUCTION SHALL CONFORM TO THE C.B.C.



MECHANICAL PLAN BUILDING 'B' AND BUILDING 'C'


MARK	DATE	REVISIONS
△		
△		
△		

JOB NO. 1317	M 2.1
DRAWN: B.S.	
CHECKED: M.B.	
DATE: 8/5/21	


bme BASKIN MECHANICAL ENGINEERS



175 Fulton Street
 Fresno, CA 93721
 Tel: (559) 237-0376
 Job: 21146
 Plt: 12-13-22



MECHANICAL PLAN BUILDING 'D'
 SCALE: 1/8"=1'-0"



MECHANICAL PLAN BUILDING 'E'
 SCALE: 1/4"=1'-0"

- MECHANICAL FLOOR PLAN KEY NOTES.**
1. REMOVE EXISTING FLOOR MOUNTED UNIT VENTILATOR, ALL RELATED MECHANICAL PIPING, CONDENSATE PIPING, CONTROLS, SUPPORTS, ANCHORAGE, ETC. PATCH EXISTING SURFACES TO MATCH EXISTING.
 2. REMOVE EXISTING OUTSIDE AIR LOUVERS. INFILL / PATCH WALL TO MATCH EXISTING.
 3. REMOVE EXISTING HYDRONIC AND CONDENSATE PIPING AND EXTERIOR CHASE. REMOVE PIPING TO 12" BELOW GRADE. CAP PIPING AND ABANDON IN PLACE.
 4. REMOVE EXISTING GRAVITY RELIEF VENT, DUCTWORK, RELIEF GRILLE, ETC. INFILL TO MATCH SURROUNDING CONSTRUCTION.
 5. EXISTING WASTE VENT, TYPICAL. CONFIRM EXACT LOCATION IN FIELD.
 6. ABANDON IN PLACE BELOW GRADE SITE HYDRONIC PIPING.
 7. ROOF MOUNTED HEAT PUMP UNIT. SEE MECHANICAL ROOF PLAN.
 8. 12" X 18" SUPPLY AIR DROP WITH 1" LINER, 14" X 20" NET. PROVIDE MITERED ELBOW AT BOTTOM OF RISER. SEE DETAIL CM.1.
 9. 26" X 11" RETURN AIR RISER WITH 1" LINER, 28" X 13" NET. PROVIDE MITERED ELBOW AT BOTTOM OF RISER. SEE DETAIL CM.1.
 10. CD-1 TYPICAL. SEE DETAIL A/M.1.
 11. CR-1 TYPICAL.
 12. T-STAT LOCATION TYPICAL. CLASSROOMS USE PELICAN T5250 WITH CO2 SENSOR AND DEMAND CONTROL VENTILATION. SEE TYP. DETAIL D/M.1.
 13. EXISTING MAKE-UP-AIR UNIT SERVING TOILET ROOMS TO REMAIN. NO WORK.
 14. DEMO EXISTING EXHAUST FAN AND INSTALL NEW EXHAUST FAN AND DISCHARGE DUCT. EXTEND TO CONNECTION AT EXISTING ROOF CAP.
 15. THIS HP UNIT TO HAVE INTERLOCK WITH FIRE ALARM PANEL FOR AUTOMATIC SHUT-DOWN. SEE DETAIL H/M.1.
 16. NO MECHANICAL WORK IN THIS ROOM.

ROOSEVELT ELEMENTARY SCHOOL
 MODERNIZATION
 2324 VERDE STREET
 FOR
 BAKERSFIELD CITY SCHOOL DISTRICT
 BAKERSFIELD, KERN COUNTY, CALIFORNIA



1601 NEW STINE ROAD, SUITE 280
 BAKERSFIELD, CA 93309
 PH: (661) 397-4377
 FAX: (661) 397-4378
 WWW.SCARCHITECT.COM

REGISTERED ARCHITECT
 STATE OF CALIFORNIA
 No. 11788
 JAN 11 2023
 STEPHEN CARROLL, ALLIED - AP

CHECK AND VERIFY ALL DIMENSIONS BEFORE PROCEEDING WITH THE WORK. REPORT DISCREPANCIES TO THE ARCHITECT. ALL CONSTRUCTION SHALL CONFORM TO THE C.B.C.



MECHANICAL PLAN BUILDING 'D' AND BUILDING 'E'

MARK	DATE	REVISIONS
△		
△		
△		

JOB NO.
1317
 DRAWN:
 B.S.
 CHECKED:
 M.B.
 DATE:
 8/5/21

M
2.2

bme BASKIN MECHANICAL ENGINEERS
 175 Fulton Street
 Fresno, CA 93721
 Tel: (559) 237-0376
 Job: 21146
 Plt: 12-13-22



IDENTIFICATION STAMP
 DIV. OF THE STATE ARCHITECT
 APP: 03-122920 INC.
 REVIEWED FOR
 SS FLS ACS
 DATE: 07/05/2023

PTN: 63321- FILE: 15-6

ROOSEVELT ELEMENTARY SCHOOL
 MODERNIZATION
 2324 VERDE STREET
 FOR
 BAKERSFIELD CITY SCHOOL DISTRICT
 BAKERSFIELD, KERN COUNTY, CALIFORNIA



1601 NEW STINE ROAD, SUITE 280
 BAKERSFIELD, CA 93309
 PH: (661) 397-4377
 FAX: (661) 397-4378
 WWW.SCARCHITECT.COM

[Signature]
 STEPHEN COOK, ARCH. ALL NEED®-AP

CHECK AND VERIFY ALL DIMENSIONS BEFORE PROCEEDING WITH THE WORK. REPORT DISCREPANCIES TO THE ARCHITECT. ALL CONSTRUCTION SHALL CONFORM TO THE C.B.C.


**MECHANICAL
 PARTIAL ROOF
 BUILDING 'E'**

MARK	DATE	REVISIONS
△		
△		
△		

JOB NO.
1317
 DRAWN:
 B.S.
 CHECKED:
 M.B.
 DATE:
 8/5/21



6.2



MECHANICAL PARTIAL ROOF BUILDING 'E'
 SCALE: 1/8"=1'-0"

- MECHANICAL ROOF PLAN KEY NOTES:**
1. NEW HP UNIT ON SLOPED ROOF CURB. SEE DETAIL A/M12, TYPICAL.
 2. 14" X 18" SUPPLY DUCT DROP THRU ROOF WITH 1" LINER, 16" X 20" NET, TYPICAL.
 3. 26" X 11" RETURN DUCT RISER THRU ROOF WITH 1" LINER, 28" X 15" NET, TYPICAL.
 4. ECONOMIZER WITH POWER EXHAUST MODULE. SET MINIMUM OUTSIDE EQUAL TO 200 CFM WITH DEMAND CONTROL VENTILATION OVERRIDE TO 500 CFM. TYPICAL.

bme BASKIN
 MECHANICAL
 ENGINEERS
 175 Fulton Street
 Fresno, CA 93721
 Tel: (559) 237-0376
 Job: 21146
 Plt: 12-13-22



A. GENERAL INFORMATION

01 Project Location (City)	Bakersfield	04 Total Conditioned Floor Area	4800
02 Climate Zone	13	05 Total Unconditioned Floor Area	0
03 Occupancy Types Within Project:		06 # of Stories (Habitable Above Grade)	1
<input type="checkbox"/> Office (B)	<input type="checkbox"/> Retail (M)	<input type="checkbox"/> Non-refrigerated Warehouse (S)	
<input type="checkbox"/> Hotel/ Motel Guest Rooms (R-1)	<input type="checkbox"/> School (E)	<input type="checkbox"/> Healthcare Facility (H)	
<input type="checkbox"/> High-Rise Residential (R-2/R-3)	<input type="checkbox"/> Recreational Class Bldg (E)	<input checked="" type="checkbox"/> Other (write in)	See Table J

B. PROJECT SCOPE

This table includes mechanical systems or components that are within the scope of the permit application and are demonstrating compliance using the prescriptive path outlined in §140.6 or §141.0(b)2 for alterations.

01	02	03
Air Systems	Wet System Components	Dry System Components
<input checked="" type="checkbox"/> Heating Air System	<input type="checkbox"/> Water Economizer	<input checked="" type="checkbox"/> Air Economizer
<input checked="" type="checkbox"/> Cooling Air System	<input type="checkbox"/> Pumps	<input type="checkbox"/> Electric Resistance Heat
<input checked="" type="checkbox"/> Mechanical Controls (existing to remain, altered or new)	<input type="checkbox"/> System Piping	<input checked="" type="checkbox"/> Fan Systems
<input type="checkbox"/> Chillers	<input type="checkbox"/> Cooling Towers	<input checked="" type="checkbox"/> Ductwork (existing to remain, altered or new)
<input type="checkbox"/> Boilers	<input type="checkbox"/> Ventilation	<input type="checkbox"/> Zonal Systems/ Terminal Boxes

F. HVAC SYSTEM SUMMARY (DRY & WET SYSTEMS)

Dry System Equipment Efficiency (Other than Package Terminal Air Conditioners (PTAC) and Package Terminal Heat Pumps (PTHP))

01	02	03	04	05	06	07	08	09
Name or Item Tag	Size Category (Btu/h)	Rating Condition (°F)	Efficiency Unit	Minimum Efficiency Required per Tables 110.2 / Title 20	Design Efficiency	Efficiency Unit	Minimum Efficiency Required per Tables 110.2 / Title 20	Design Efficiency
HP-1 / B-1	<65,000	HSPF	7.7	8.3	SEER	13.0	16.2	16.2
HP-1 / B-2	<65,000	HSPF	7.7	8.3	SEER	13.0	16.2	16.2
HP-1 / B-3	<65,000	AFUE	0.80	0.81	SEER	13.0	16.1	16.1
HP-1 / B-4	<65,000	AFUE	0.80	0.81	SEER	13.0	16.1	16.1
HP-1 / B-5	<65,000	AFUE	0.80	0.81	SEER	13.0	16.1	16.1

G. PUMPS
This section does not apply to this project.

H. FAN SYSTEMS & AIR ECONOMIZERS

This table is used to demonstrate compliance with prescriptive requirements found in §140.4(c), §140.4(d), and §140.4(m) for fan systems. Fan systems serving only process loads are exempt from these requirements and do not need to be included in Table H.

System Name	HP-1 / B-1	Economizer ¹	Fixed Temperature	Economizer Controls	Designed per §140.4(e) and (m)	System Fan Type	Variable Air Volume
01	02	03	04	05	06	07	08
Fan Name or Item Tag	Fan Function	Qty	Maximum Design Supply Airflow (CFM)	HP Unit ²	Design HP	Fan Power Pressure Drop Adjustment - Table 140.4-B	Design Airflow through Device (CFM)
SF	Supply	1	1800	BHP	0.66	Maximum System Fan Power (BHP)	
Total System Design Supply Airflow (CFM):			1800	Total System Design (BHP):		0.66	Maximum System Fan Power (BHP):

I. SYSTEM CONTROLS

*Notes: Controls with a * require a note in the space below explaining how compliance is achieved. EX: system 1: SA Temp Reset: Exempt because zones compliant with §140.4(d); EXCEPTION 1 to §140.4(f)

J. VENTILATION AND INDOOR AIR QUALITY

This table is used to demonstrate compliance with mandatory ventilation requirements in §120.1 and §120.2(c)(3) for all nonresidential, high-rise residential and hotel/motel occupancies. For alterations, only ventilation systems being altered within the scope of the permit application need to be documented in this table. In lieu of this table, the required outdoor ventilation rates and airflow may be shown on the plans or the calculations can be presented in a spreadsheet.

01	02	03	04	05	06	07	08	09
Space Name of Item Tag	Occupancy Type ⁴	Conditioned Floor Area (ft ²)	# of Shower heads/ toilets	# of people ⁵	Required Min OA CFM	Required Min CFM	Provided per Design CFM	DCV or Sensor Controls per §120.1(d)(3), §120.1(d)(5), and §120.1(d)(6) ⁶
Classroom B1	Lecture/ postsecondary classroom	960		364.8	0	0	0	DCV Provided per §120.1(d)(4) Occ Sensor NA: Not required space type
Total System Required Min OA CFM			365	18	Ventilation for this System Complies?		Yes	

C. COMPLIANCE RESULTS

Table C will indicate if the project data input into the compliance document is compliant with mechanical requirements. This table is not editable by the user. If this table says "DOES NOT COMPLY" or "COMPLIES with Exceptional Conditions" refer to Table D, or the table indicated as not compliant for guidance.

01	02	03	04	05	06	07	08	09
System Summary §110.1, §110.2, §140.4	Pumps §140.4(b)	Fans/Economizers §140.4(c), §140.4(e)	System Controls §110.2, §120.2, §140.4(f)	Ventilation §120.1	Terminal Box Controls §140.4(g)	Distribution §120.3, §140.4(h)	Cooling Towers §110.2(b)(7)	Compliance Results
(See Table F)	(See Table G)	(See Table H)	(See Table I)	(See Table J)	(See Table K)	(See Table L)	(See Table M)	COMPLIES

D. EXCEPTIONAL CONDITIONS
This table is auto-filled with uneditable comments because of selections made or data entered in tables throughout the form.

E. ADDITIONAL REMARKS
This table includes remarks made by the permit applicant to the Authority Having Jurisdiction.

H. FAN SYSTEMS & AIR ECONOMIZERS

System Name	HP-1 / B-2	Economizer ¹	Fixed Temperature	Economizer Controls	Designed per §140.4(e) and (m)	System Fan Type	Variable Air Volume
01	02	03	04	05	06	07	08
Fan Name or Item Tag	Fan Function	Qty	Maximum Design Supply Airflow (CFM)	HP Unit ²	Design HP	Fan Power Pressure Drop Adjustment - Table 140.4-B	Design Airflow through Device (CFM)
SF	Supply	1	1800	BHP	0.66	Maximum System Fan Power (BHP)	
Total System Design Supply Airflow (CFM):			1800	Total System Design (BHP):		0.66	Maximum System Fan Power (BHP):

J. VENTILATION AND INDOOR AIR QUALITY

04	05	06	07			
System Name	HP-1 / B-2	System Design OA CFM Airflow ³	365	System Design Transfer Air CFM	0	Air Filtration per §120.1(c) and §141.0(b)(2) ²
System Name	HP-1 / B-3	System Design OA CFM Airflow ³	365	System Design Transfer Air CFM	0	Air Filtration per §120.1(c) and §141.0(b)(2) ²
System Name	HP-1 / B-5	System Design OA CFM Airflow ³	365	System Design Transfer Air CFM	0	Air Filtration per §120.1(c) and §141.0(b)(2) ²

F. HVAC SYSTEM SUMMARY (DRY & WET SYSTEMS)

This table is used to demonstrate compliance for mechanical equipment with mandatory requirements found in §110.1 and §110.2(a) and prescriptive requirements found in §140.4(d), §140.4(h) and §140.4(i), or §141.0(b)2 for alterations.

01	02	03	04	05	06	07	08	09	10	11
Name or Item Tag	Equipment Category per Tables 110.2	Equipment Type per Tables 110.2 / Title 20	Smallest Size Available ¹ §140.4(a)	Per Design (kBtu/h)	Rated (kBtu/h)	Supp. Heating Output (kBtu/h)	Sensible Per Design (kBtu/h)	Rated (kBtu/h)	Total Heating Load (kBtu/h)	Total Sensible Cooling Load (kBtu/h)
HP-1 / B-1	Unitary Heat Pumps	Air-cooled, pkg (3 phase)	NA: Load Controls	70.44	54.86	36.18	55.65	46.32	59.29	62.08
HP-1 / B-2	Unitary Heat Pumps	Air-cooled, pkg (3 phase)	NA: Load Controls	70.44	54.86	36.18	53.92	46.32	56.45	59.57
HP-1 / B-3	Unitary AC/ Condensers	AC, air-cooled pkg (3 phase)	NA: Load Controls	49	49	0	52.26	44.73	56.19	59.79
HP-1 / B-4	Unitary AC/ Condensers	AC, air-cooled pkg (3 phase)	NA: Load Controls	49	49	0	52.26	44.73	56.19	59.79
HP-1 / B-5	Unitary AC/ Condensers	AC, air-cooled pkg (3 phase)	NA: Load Controls	49	49	0	52.29	44.73	59.04	61.39

¹FOOTNOTES: Equipment shall be the smallest size, within the available options of the desired equipment line, necessary to meet the design heating and cooling loads of the building per §140.4(a). Healthcare facilities are exempt.
²It is common practice to show rated output capacity on the equipment schedule. Sensible cooling output comes from specification sheet tables.
³If equipment is heating only, leave cooling output and load blank. If equipment is cooling only, leave heating output and load blank.
⁴Authority Having Jurisdiction may ask for load calculations used for compliance per §140.4(h).

H. FAN SYSTEMS & AIR ECONOMIZERS

System Name	HP-1 / B-5	Economizer ¹	Fixed Temperature	Economizer Controls	Designed per §140.4(e) and (m)	System Fan Type	Variable Air Volume
01	02	03	04	05	06	07	08
Fan Name or Item Tag	Fan Function	Qty	Maximum Design Supply Airflow (CFM)	HP Unit ²	Design HP	Fan Power Pressure Drop Adjustment - Table 140.4-B	Design Airflow through Device (CFM)
SF	Supply	1	1800	BHP	0.72	Maximum System Fan Power (BHP)	
Total System Design Supply Airflow (CFM):			1800	Total System Design (BHP):		0.72	Maximum System Fan Power (BHP):

¹FOOTNOTES: Computer room economizers must meet requirements of §140.3(a) and will be documented on the NRCC-PRC-E document.
²The unit used for HP must be consistent for all fans within a system.

I. SYSTEM CONTROLS

This table is used to demonstrate compliance with mandatory controls in §110.2 and §120.2, and prescriptive controls in §140.4(f) and (n) or requirements in §141.0(b)(2) for altered space conditioning systems.

01	02	03	04	05	06	07	08	09
System Name	System Zoning	Conditioned Floor Area Being Served (ft ²)	Thermostats §110.2(b) & (c) ¹ , §120.2(a)(b), §141.0(b)(2)	Shut-Off Controls §120.2(a)	Isolation Zone Controls §120.2(a)	Demand Response §110.12 and §120.2(b)	Supply Air Temp. Reset §140.4(b)	Window Interlocks per §140.4(n)
HP-1 / B-1	Single zone	<= 25,000 ft ²	Setback	Auto Timer Switch	4 Hour Timer	EMCS	Included	Provided
HP-1 / B-2	Single zone	<= 25,000 ft ²	Setback	Auto Timer Switch	4 Hour Timer	EMCS	Included	Provided
HP-1 / B-3	Single zone	<= 25,000 ft ²	Setback	Auto Timer Switch	4 Hour Timer	EMCS	Included	Provided
HP-1 / B-4	Single zone	<= 25,000 ft ²	Setback	Auto Timer Switch	4 Hour Timer	EMCS	Included	Provided
HP-1 / B-5	Single zone	<= 25,000 ft ²	Setback	Auto Timer Switch	4 Hour Timer	EMCS	Included	Provided

J. VENTILATION AND INDOOR AIR QUALITY

04	05	06	07			
System Name	HP-1 / B-4	System Design OA CFM Airflow ³	365	System Design Transfer Air CFM	0	Air Filtration per §120.1(c) and §141.0(b)(2) ²
System Name	HP-1 / B-5	System Design OA CFM Airflow ³	365	System Design Transfer Air CFM	0	Air Filtration per §120.1(c) and §141.0(b)(2) ²

ROOSEVELT ELEMENTARY SCHOOL
MODERNIZATION
2324 VERDE STREET
FOR
BAKERSFIELD CITY SCHOOL DISTRICT
BAKERSFIELD, KERN COUNTY, CALIFORNIA



1601 NEW STINE ROAD, SUITE 280
BAKERSFIELD, CA 93309
PH: (661) 397-4377
FAX: (661) 397-4378
WWW.SCARCHITECT.COM



CHECK AND VERIFY ALL DIMENSIONS BEFORE PROCEEDING WITH THE WORK. REPORT DISCREPANCIES TO THE ARCHITECT. ALL CONSTRUCTION SHALL CONFORM TO THE C.B.C.

BUILDING 'B'
TITLE-24


MARK	DATE	REVISIONS
△		
△		
△		

JOB NO. 1317
DRAWN: B.S.
CHECKED: M.B.
DATE: 8/5/21

M 7.0



1601 NEW STINE ROAD, SUITE 280
BAKERSFIELD, CA 93309
PH: (661) 397-4377
FAX: (661) 397-4378
WWW.SCARCHITECT.COM



CHECK AND VERIFY ALL DIMENSIONS BEFORE PROCEEDING WITH THE WORK. REPORT DISCREPANCIES TO THE ARCHITECT. ALL CONSTRUCTION SHALL CONFORM TO THE C.B.C.

**BUILDING 'B'
TITLE-24**

MARK	DATE	REVISIONS
△		
△		
△		

JOB NO.
1317
DRAWN:
B.S.
CHECKED:
M.B.
DATE:
8/5/21



bme BASKIN MECHANICAL ENGINEERS
175 Fulton Street
Fresno, CA 93721
Tel: (559) 237-0376
Job: 21146
Pit: 12-13-22

STATE OF CALIFORNIA
Mechanical Systems
NRCC-MCH-E CALIFORNIA ENERGY COMMISSION
CERTIFICATE OF COMPLIANCE NRCC-MCH-E
Project Name: Roosevelt Elementary HVAC Upgrades Bid B Report Page: (Page 12 of 16)
Project Address: 2324 Verde Street Date Prepared: 12/9/2022

L. DISTRIBUTION (DUCTWORK and PIPING)

In other unconditioned spaces

15	<input type="checkbox"/>	The scope of the project includes extending an existing duct system, which is constructed, insulated or sealed with asbestos.
16	<input type="checkbox"/>	The scope of the project includes an existing duct system that is documented to have been previously sealed as confirmed through field verification and diagnostic testing in accordance with procedures in the Reference Nonresidential Appendix NA2.
17	Yes	Duct system shall be sealed in accordance with the California Mechanical Code

The answers to the questions below apply to the following duct systems: HP-1/B-2 Duct leakage testing triggered for these systems? No

11	No	The scope of the project includes only duct systems serving healthcare facilities
12	Yes	Duct system provides conditioned air to an occupiable space for a constant volume, single zone, space-conditioning system.
13	Yes	The space conditioning system serves less than 5,000 ft ² of conditioned floor area.
14	No	The combined surface area of the ducts in the following locations is more than 25% of the total surface area of the entire duct system:

Outdoors
 In a space directly under a roof that has a U-factor greater than the u-factor of the ceiling, or if the roof does not meet the requirements of §140.3(a)(1) or if the roof has fixed vents or openings to the outside/unconditioned spaces
 In an unconditioned crawl space
 In other unconditioned spaces

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
Registration Date/Time: Report Version: 2019.1.003
Registration Provider: Energysoft
Report Generated: 2022-12-09 14:58:26
Schema Version: rev 20200601

STATE OF CALIFORNIA
Mechanical Systems
NRCC-MCH-E CALIFORNIA ENERGY COMMISSION
CERTIFICATE OF COMPLIANCE NRCC-MCH-E
Project Name: Roosevelt Elementary HVAC Upgrades Bid B Report Page: (Page 13 of 16)
Project Address: 2324 Verde Street Date Prepared: 12/9/2022

O. DECLARATION OF REQUIRED CERTIFICATES OF ACCEPTANCE

Selections have been made based on information provided in previous tables of this document. If any selection needs to be changed, please explain why in Table E Additional Remarks. These documents must be provided to the building inspector during construction and can be found online at https://www.energy.ca.gov/title24/2019standards/2019_compliance_documents/Nonresidential_Documents/NRCA/

Form/Title	Systems/Spaces To Be Field Verified	Field Inspector	
		Pass	Fail
NRCA-MCH-16-A Supply Air Temperature Reset Controls	Carrier 50GCCQM06; Carrier 50GCCQM06; Carrier 48GCCQM06; Carrier 48GCCQM06; Carrier 48GCCQM06	<input type="checkbox"/>	<input type="checkbox"/>
NRCA-MCH-18-A Energy Management Control Systems	Carrier 50GCCQM06; Carrier 50GCCQM06; Carrier 48GCCQM06; Carrier 48GCCQM06; Carrier 48GCCQM06	<input type="checkbox"/>	<input type="checkbox"/>

P. DECLARATION OF REQUIRED CERTIFICATES OF VERIFICATION
There are no NRCC forms required for this project.

Q. MANDATORY MEASURES DOCUMENTATION LOCATION

This table is used to indicate where mandatory measures are documented in the plan set or construction documentation.

Compliance with Mandatory Measures documented through MCH	02
Mandatory Measures Note Block	Yes
M-Sheds	

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
Registration Date/Time: Report Version: 2019.1.003
Registration Provider: Energysoft
Report Generated: 2022-12-09 14:58:26
Schema Version: rev 20200601

STATE OF CALIFORNIA
Mechanical Systems
NRCC-MCH-E CALIFORNIA ENERGY COMMISSION
CERTIFICATE OF COMPLIANCE NRCC-MCH-E
Project Name: Roosevelt Elementary HVAC Upgrades Bid B Report Page: (Page 11 of 16)
Project Address: 2324 Verde Street Date Prepared: 12/9/2022

L. DISTRIBUTION (DUCTWORK and PIPING)

In other unconditioned spaces

15	<input type="checkbox"/>	The scope of the project includes extending an existing duct system, which is constructed, insulated or sealed with asbestos.
16	<input type="checkbox"/>	The scope of the project includes an existing duct system that is documented to have been previously sealed as confirmed through field verification and diagnostic testing in accordance with procedures in the Reference Nonresidential Appendix NA2.
17	Yes	Duct system shall be sealed in accordance with the California Mechanical Code

The answers to the questions below apply to the following duct systems: HP-1/B-2 Duct leakage testing triggered for these systems? No

11	No	The scope of the project includes only duct systems serving healthcare facilities
12	Yes	Duct system provides conditioned air to an occupiable space for a constant volume, single zone, space-conditioning system.
13	Yes	The space conditioning system serves less than 5,000 ft ² of conditioned floor area.
14	No	The combined surface area of the ducts in the following locations is more than 25% of the total surface area of the entire duct system:

Outdoors
 In a space directly under a roof that has a U-factor greater than the u-factor of the ceiling, or if the roof does not meet the requirements of §140.3(a)(1) or if the roof has fixed vents or openings to the outside/unconditioned spaces
 In an unconditioned crawl space
 In other unconditioned spaces

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
Registration Date/Time: Report Version: 2019.1.003
Registration Provider: Energysoft
Report Generated: 2022-12-09 14:58:26
Schema Version: rev 20200601

STATE OF CALIFORNIA
Mechanical Systems
NRCC-MCH-E CALIFORNIA ENERGY COMMISSION
CERTIFICATE OF COMPLIANCE NRCC-MCH-E
Project Name: Roosevelt Elementary HVAC Upgrades Bid B Report Page: (Page 14 of 16)
Project Address: 2324 Verde Street Date Prepared: 12/9/2022

O. DECLARATION OF REQUIRED CERTIFICATES OF ACCEPTANCE

Selections have been made based on information provided in previous tables of this document. If any selection needs to be changed, please explain why in Table E Additional Remarks. These documents must be provided to the building inspector during construction and can be found online at https://www.energy.ca.gov/title24/2019standards/2019_compliance_documents/Nonresidential_Documents/NRCA/

Form/Title	Systems/Spaces To Be Field Verified	Field Inspector	
		Pass	Fail
NRCA-MCH-02-A - Outdoor Air must be submitted for all newly installed HVAC units. Note: MCH-02-A can be performed in conjunction with MCH-07-A Supply Fan VFD Acceptance (if applicable) since testing activities overlap.	Carrier 50GCCQM06; Carrier 50GCCQM06; Carrier 48GCCQM06; Carrier 48GCCQM06; Carrier 48GCCQM06	<input type="checkbox"/>	<input type="checkbox"/>
NRCA-MCH-05-A - Air Economizer Controls	Carrier 50GCCQM06; Carrier 50GCCQM06; Carrier 48GCCQM06; Carrier 48GCCQM06; Carrier 48GCCQM06	<input type="checkbox"/>	<input type="checkbox"/>
NRCA-MCH-06-A Demand Control Ventilation Systems must be submitted for all systems required to employ demand controlled ventilation (refer to §120.3(c)(2)) can vary outside ventilation flow rates based on maintaining interior carbon dioxide (CO ₂) concentration setpoints.	Carrier 50GCCQM06; Carrier 50GCCQM06; Carrier 48GCCQM06; Carrier 48GCCQM06; Carrier 48GCCQM06	<input type="checkbox"/>	<input type="checkbox"/>
NRCA-MCH-11-A Automatic Demand Shed Controls	Carrier 50GCCQM06; Carrier 50GCCQM06; Carrier 48GCCQM06; Carrier 48GCCQM06; Carrier 48GCCQM06	<input type="checkbox"/>	<input type="checkbox"/>
NRCA-MCH-12-A FDD for Packaged Direct Expansion Units	Carrier 50GCCQM06; Carrier 50GCCQM06; Carrier 48GCCQM06; Carrier 48GCCQM06; Carrier 48GCCQM06	<input type="checkbox"/>	<input type="checkbox"/>

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
Registration Date/Time: Report Version: 2019.1.003
Registration Provider: Energysoft
Report Generated: 2022-12-09 14:58:26
Schema Version: rev 20200601

STATE OF CALIFORNIA
Mechanical Systems
NRCC-MCH-E CALIFORNIA ENERGY COMMISSION
CERTIFICATE OF COMPLIANCE NRCC-MCH-E
Project Name: Roosevelt Elementary HVAC Upgrades Bid B Report Page: (Page 16 of 16)
Project Address: 2324 Verde Street Date Prepared: 12/9/2022

DOCUMENTATION AUTHOR'S DECLARATION STATEMENT
I certify that this Certificate of Compliance documentation is accurate and complete.

Documentation Author Name: Mark Baskin
Documentation Author Signature: Mark Baskin, P.E., Mark Baskin, P.E., 2022.12.09 14:59:17-0800
Signature Date: 2022-12-09
Company: Baskin Mechanical Engineers
Address: 175 Fulton St., Fresno CA 93721
City/State/Zip: Fresno CA 93721
Phone: (559) 237-0376

RESPONSIBLE PERSON'S DECLARATION STATEMENT
I certify the following under penalty of perjury, under the laws of the State of California:
1. The information provided on this Certificate of Compliance is true and correct.
2. I am eligible under Division 3 of the Business and Professions Code to accept responsibility for the building design or system design identified on this Certificate of Compliance (responsible designer).
3. The energy features and performance specifications, materials, components, and manufactured devices for the building design or system design identified on this Certificate of Compliance conform to the requirements of Title 24, Part 1 and Part 6 of the California Code of Regulations.
4. The building design features or system design features identified on this Certificate of Compliance are consistent with the information provided on other applicable compliance documents, worksheets, calculations, plans and specifications submitted to the enforcement agency for approval with the building permit application.
5. I will ensure that a completed signed copy of this Certificate of Compliance shall be made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections. I understand that a completed signed copy of this Certificate of Compliance is required to be included with the documentation the building permit(s) issued for the building.

Responsible Designer Name: Mark Baskin, P.E.
Responsible Designer Signature: Mark Baskin, P.E., 2022.12.09 14:59:34-0800
Signature Date: 2022-12-09
Company: Baskin Mechanical Engineers
Address: 175 Fulton St., Fresno CA 93721
City/State/Zip: Fresno CA 93721
Phone: (559) 237-0376

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
Registration Date/Time: Report Version: 2019.1.003
Registration Provider: Energysoft
Report Generated: 2022-12-09 14:58:26
Schema Version: rev 20200601

STATE OF CALIFORNIA
Mechanical Systems
NRCC-MCH-E CALIFORNIA ENERGY COMMISSION
CERTIFICATE OF COMPLIANCE NRCC-MCH-E
Project Name: Roosevelt Elementary HVAC Upgrades Bid B Report Page: (Page 10 of 16)
Project Address: 2324 Verde Street Date Prepared: 12/9/2022

I. VENTILATION AND INDOOR AIR QUALITY

¹ All filtration requirements apply to the following three system types per §120.3(c)(1): space conditioning systems utilizing ducts to supply air to occupiable spaces; supply-only ventilation systems providing outside air to occupiable spaces; supply side of balanced ventilation systems including heat recovery and energy recovery ventilation systems providing outside air to occupiable spaces.

² Uniform Mechanical Code may have more stringent ventilation requirements; the most stringent code requirement takes precedence.

³ See Standards Tables 120.1-A and 120.1-B.

⁴ For lecture halls with fixed seating, the expected number of occupants shall be that determined in accordance with the California Building Code.

⁵ §120.2(c) requires systems serving rooms that are required by §130.1(c) to have lighting occupancy sensing controls to also have occupancy sensing zone controls for ventilation. Examples of spaces which require lighting occupancy sensors include offices 250ft² or smaller, multipurpose rooms less than 1,000 ft², classrooms, conference rooms, restrooms, aisles and open areas in warehouses, library book stack aisles, corridors, stairwells, parking garages, and loading and unloading zones, unless excepted by §130.1(c).

K. TERMINAL BOX CONTROLS
This section does not apply to this project.

L. DISTRIBUTION (DUCTWORK and PIPING)

In other unconditioned spaces

15	<input type="checkbox"/>	The scope of the project includes extending an existing duct system, which is constructed, insulated or sealed with asbestos.
16	<input type="checkbox"/>	The scope of the project includes an existing duct system that is documented to have been previously sealed as confirmed through field verification and diagnostic testing in accordance with procedures in the Reference Nonresidential Appendix NA2.
17	Yes	Duct system shall be sealed in accordance with the California Mechanical Code

The answers to the questions below apply to the following duct systems: HP-1/B-1 Duct leakage testing triggered for these systems? No

11	No	The scope of the project includes only duct systems serving healthcare facilities
12	Yes	Duct system provides conditioned air to an occupiable space for a constant volume, single zone, space-conditioning system.
13	Yes	The space conditioning system serves less than 5,000 ft ² of conditioned floor area.
14	No	The combined surface area of the ducts in the following locations is more than 25% of the total surface area of the entire duct system:

Outdoors
 In a space directly under a roof that has a U-factor greater than the u-factor of the ceiling, or if the roof does not meet the requirements of §140.3(a)(1) or if the roof has fixed vents or openings to the outside/unconditioned spaces
 In an unconditioned crawl space
 In other unconditioned spaces

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
Registration Date/Time: Report Version: 2019.1.003
Registration Provider: Energysoft
Report Generated: 2022-12-09 14:58:26
Schema Version: rev 20200601

STATE OF CALIFORNIA
Mechanical Systems
NRCC-MCH-E CALIFORNIA ENERGY COMMISSION
CERTIFICATE OF COMPLIANCE NRCC-MCH-E
Project Name: Roosevelt Elementary HVAC Upgrades Bid B Report Page: (Page 13 of 16)
Project Address: 2324 Verde Street Date Prepared: 12/9/2022

L. DISTRIBUTION (DUCTWORK and PIPING)

In other unconditioned spaces

15	<input type="checkbox"/>	The scope of the project includes extending an existing duct system, which is constructed, insulated or sealed with asbestos.
16	<input type="checkbox"/>	The scope of the project includes an existing duct system that is documented to have been previously sealed as confirmed through field verification and diagnostic testing in accordance with procedures in the Reference Nonresidential Appendix NA2.
17	Yes	Duct system shall be sealed in accordance with the California Mechanical Code

M. COOLING TOWERS
This section does not apply to this project.

N. DECLARATION OF REQUIRED CERTIFICATES OF INSTALLATION

Selections have been made based on information provided in previous tables of this document. If any selection needs to be changed, please explain why in Table E Additional Remarks. These documents must be provided to the building inspector during construction and can be found online at https://www.energy.ca.gov/title24/2019standards/2019_compliance_documents/Nonresidential_Documents/NRCA/

Form/Title	Field Inspector	
	Pass	Fail
NRC-MCH-01-E - Must be submitted for all buildings	<input type="checkbox"/>	<input type="checkbox"/>

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
Registration Date/Time: Report Version: 2019.1.003
Registration Provider: Energysoft
Report Generated: 2022-12-09 14:58:26
Schema Version: rev 20200601

CERTIFICATE OF COMPLIANCE
 This document is used to demonstrate compliance for mechanical systems that are within the scope of the permit application and are demonstrating compliance using the prescriptive path outlined in §140.4, or §141.0(b)(2), for alterations.
 Project Name: Roosevelt Elementary HVAC Upgrades Bid C Report Page: (Page 1 of 18)
 Project Address: 2324 Verde Street Date Prepared: 12/9/2022

A. GENERAL INFORMATION

01 Project Location (city)	Bakersfield	04 Total Conditioned Floor Area	6210
02 Climate Zone	13	05 Total Unconditioned Floor Area	0
03 Occupancy Types Within Project:		06 # of Stories (Nabtable Above Grade)	1
<input type="checkbox"/> Office (B)	<input type="checkbox"/> Retail (M)	<input type="checkbox"/> Non-refrigerated Warehouse (S)	
<input type="checkbox"/> Hotel/ Motel Guest Rooms (R-1)	<input type="checkbox"/> School (E)	<input type="checkbox"/> Healthcare Facility (I)	
<input type="checkbox"/> High-Rise Residential (R-2/R-3)	<input type="checkbox"/> Relocatable Class Bldg (E)	<input type="checkbox"/> Other (write in)	See Table J

B. PROJECT SCOPE
 This table includes mechanical systems or components that are within the scope of the permit application and are demonstrating compliance using the prescriptive path outlined in §140.4, or §141.0(b)(2), for alterations.

01	02	03
Air System(s)	Wet System Components	Dry System Components
<input checked="" type="checkbox"/> Heating Air System	<input type="checkbox"/> Water Economizer	<input checked="" type="checkbox"/> Air Economizer
<input checked="" type="checkbox"/> Cooling Air System	<input type="checkbox"/> Pumps	<input type="checkbox"/> Electric Resistance Heat
Mechanical Controls	<input type="checkbox"/> System Piping	<input type="checkbox"/> Fan Systems
<input checked="" type="checkbox"/> Mechanical Controls (existing to remain, altered or new)	<input type="checkbox"/> Cooling Towers	<input type="checkbox"/> Ductwork (existing to remain, altered or new)
	<input type="checkbox"/> Chillers	<input checked="" type="checkbox"/> Ventilation
	<input type="checkbox"/> Boilers	<input type="checkbox"/> Zonal Systems/ Terminal Boxes

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
 Registration Date/Time: 2019.1.003 Schema Version: rev 20200601
 Registration Provider: Energsoft
 Report Generated: 2022-12-09 15:18:10

CERTIFICATE OF COMPLIANCE
 Project Name: Roosevelt Elementary HVAC Upgrades Bid C Report Page: (Page 4 of 18)
 Project Address: 2324 Verde Street Date Prepared: 12/9/2022

F. HVAC SYSTEM SUMMARY (DRY & WET SYSTEMS)

Dry System Equipment Efficiency (other than Package Terminal Air Conditioners (PTAC) and Package Terminal Heat Pumps (PTHP))

01	02	03	04	05	06	07	08	09
Name or Item Tag	Size Category (Btu/h)	Rating Condition (°F)	Efficiency Unit	Minimum Efficiency Required per Tables 110.2 / Title 20	Design Efficiency	Efficiency Unit	Minimum Efficiency Required per Tables 110.2 / Title 20	Design Efficiency
HP-1 / C-1	<65,000		HSPF	7.7	8.3	SEER	13.0	16.2
HP-1 / C-2	<65,000		HSPF	7.7	8.3	SEER	13.0	16.2
HP-1 / C-3	<65,000		AFUE	0.80	0.81	SEER	13.0	16.1
HP-1 / C-4	<65,000		AFUE	0.80	0.81	SEER	13.0	16.1
HP-1 / C-5	<65,000		AFUE	0.80	0.81	SEER	13.0	16.1
HP-2 / Work room	<65,000		HSPF	7.7	8.2	SEER	13.0	14.5

G. PUMPS
 This section does not apply to this project.

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
 Registration Date/Time: 2019.1.003 Schema Version: rev 20200601
 Registration Provider: Energsoft
 Report Generated: 2022-12-09 15:18:10

CERTIFICATE OF COMPLIANCE
 Project Name: Roosevelt Elementary HVAC Upgrades Bid C Report Page: (Page 7 of 18)
 Project Address: 2324 Verde Street Date Prepared: 12/9/2022

I. SYSTEM CONTROLS

This table is used to demonstrate compliance with mandatory controls in §110.2 and §120.2, and prescriptive controls in §140.4(i) and (n) or requirements in §141.0(b)(2) for altered space conditioning systems.

01	02	03	04	05	06	07	08	09
System Name	System Zoning	Conditioned Floor Area Being Served (ft²)	Thermostats §110.2(a) & (c), §120.2(a) or §141.0(b)(2)	Shut-Off Controls §120.2(e)	Isolation Zone Controls §120.2(d)	Demand Response §110.12 and §120.2(b)	Supply Air Temp. Reset §140.4(f)	Window Interlocks per §140.4(n)
HP-1 / C-1	Single zone	<= 25,000 ft²	Setback	Auto Timer Switch	4 Hour Timer	EMCS	Included	Provided
HP-2 / C-2	Single zone	<= 25,000 ft²	Setback	Auto Timer Switch	4 Hour Timer	EMCS	Included	Provided
HP-1 / C-3	Single zone	<= 25,000 ft²	Setback	Auto Timer Switch	4 Hour Timer	EMCS	Included	Provided
HP-1 / C-4	Single zone	<= 25,000 ft²	Setback	Auto Timer Switch	4 Hour Timer	EMCS	Included	Provided
HP-1 / C-5	Single zone	<= 25,000 ft²	Setback	Auto Timer Switch	4 Hour Timer	EMCS	Included	Provided
HP-2 / Work room	Single zone	<= 25,000 ft²	Setback	Auto Timer Switch	4 Hour Timer	EMCS	Included	Provided

FOOTNOTES: Gravity gas wall heaters, gravity floor heaters, gravity room heaters, non-central electric heaters, fireplaces or decorative gas appliances, wood stoves are not required to have setback thermostats.
 *Notes: Controls with a * require a note in the space below explaining how compliance is achieved. EX: system 1: SA Temp Reset: Exempt because zones compliant with §140.4(d); EXCEPTION 1 to §140.4(d)

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
 Registration Date/Time: 2019.1.003 Schema Version: rev 20200601
 Registration Provider: Energsoft
 Report Generated: 2022-12-09 15:18:10

CERTIFICATE OF COMPLIANCE
 Project Name: Roosevelt Elementary HVAC Upgrades Bid C Report Page: (Page 2 of 18)
 Project Address: 2324 Verde Street Date Prepared: 12/9/2022

C. COMPLIANCE RESULTS

Table C will indicate if the project data input into the compliance document is compliant with mechanical requirements. This table is not editable by the user. If this table says "DOES NOT COMPLY" or "COMPLIES with Exceptional Conditions" refer to Table D, or the table indicated as not compliant for guidance.

01	02	03	04	05	06	07	08	09
System Summary §110.1, §110.2, §140.4	AND Pumps §140.4(k)	AND Fans/Economizers §140.4(c), §140.4(e)	AND System Controls §110.2, §120.2, §140.4(f)	AND Ventilation §120.1	AND Terminal Box Controls §140.4(g)	AND Distribution §120.3, §140.4(i)	AND Cooling Towers §110.2(a)(2)	Compliance Results
(See Table F)	(See Table G)	(See Table H)	(See Table I)	(See Table J)	(See Table K)	(See Table L)	(See Table M)	COMPLIES
Yes	AND	AND	AND	AND	AND	AND	AND	COMPLIES

D. EXCEPTIONAL CONDITIONS
 This table is auto-filled with uneditable comments because of selections made or data entered in tables throughout the form.

E. ADDITIONAL REMARKS
 This table includes remarks made by the permit applicant to the Authority Having Jurisdiction.

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
 Registration Date/Time: 2019.1.003 Schema Version: rev 20200601
 Registration Provider: Energsoft
 Report Generated: 2022-12-09 15:18:10

CERTIFICATE OF COMPLIANCE
 Project Name: Roosevelt Elementary HVAC Upgrades Bid C Report Page: (Page 5 of 18)
 Project Address: 2324 Verde Street Date Prepared: 12/9/2022

H. FAN SYSTEMS & AIR ECONOMIZERS

This table is used to demonstrate compliance with prescriptive requirements found in §140.4(c), §140.4(e) and §140.4(m) for fan systems. Fan systems serving only process loads are exempt from these requirements and do not need to be included in Table H.

System Name:	HP-1 / C-1	Economizer: ¹	Fixed Temperature	Economizer Controls:	Designed per §140.4(e) and (m)	System Fan Type:	Variable Air Volume
01	02	03	04	05	06	07	08
Fan Name or Item Tag	Fan Function	Qty	Maximum Design Supply Airflow (CFM)	HP Unit ²	Design HP	Fan Power Pressure Drop Adjustment - Table 140.4-B	Device
SF	Supply	1	1800	BHP	0.66		
Total System Design Supply Airflow (CFM):			1800	Total System Design (BHP):	0.66	Maximum System Fan Power (BHP):	

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
 Registration Date/Time: 2019.1.003 Schema Version: rev 20200601
 Registration Provider: Energsoft
 Report Generated: 2022-12-09 15:18:10

CERTIFICATE OF COMPLIANCE
 Project Name: Roosevelt Elementary HVAC Upgrades Bid C Report Page: (Page 8 of 18)
 Project Address: 2324 Verde Street Date Prepared: 12/9/2022

J. VENTILATION AND INDOOR AIR QUALITY

This table is used to demonstrate compliance with mandatory ventilation requirements in §120.1 and §120.2(e)(3) for all nonresidential, high-rise residential and hotel/motel occupancies. For alterations, only ventilation systems being altered within the scope of the permit application need to be documented in this table. In lieu of this table, the required outdoor ventilation rates and airflow may be shown on the plans or the calculations can be presented in a spreadsheet.

01	02	03	04	05	06	07	08	09
<input type="checkbox"/>	Check the box if the project is showing ventilation calculations on the plans, or attaching the calculations instead of completing this table.							
<input checked="" type="checkbox"/>	Check this box if the project included Nonresidential or Hotel/Motel spaces.							
<input type="checkbox"/>	Check this box if the project included new or altered high-rise residential dwelling units.							
<input type="checkbox"/>	Check the box if the project is using natural ventilation in any nonresidential or hotel/motel spaces to meet required ventilation rates per §120.1(c)(2).							
System Name	HP-1 / C-1	System Design OA CFM Airflow ¹	10	11	12	13	14	15
08	09	10	11	12	13	14	15	16
Space Name or Item Tag	Occupancy Type ²	Conditioned Floor Area (ft²)	# of Shower/heads/toilets	# of people ³	Required Min OA CFM	Required Min CFM	Provided per Design CFM	DCV or Sensor Controls per §120.1(d)(3), §120.1(d)(5), and §120.1(e)(3) ⁴
Classroom C1	Lecture/ postsecondary classroom	960			364.8	0	0	DCV Provided per §120.1(d)(4) Occ Sensor NA: Not required space type
17	Total System Required Min OA CFM				365	18	Ventilation for this System Complies? ⁷	Yes

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
 Registration Date/Time: 2019.1.003 Schema Version: rev 20200601
 Registration Provider: Energsoft
 Report Generated: 2022-12-09 15:18:10

CERTIFICATE OF COMPLIANCE
 Project Name: Roosevelt Elementary HVAC Upgrades Bid C Report Page: (Page 3 of 18)
 Project Address: 2324 Verde Street Date Prepared: 12/9/2022

F. HVAC SYSTEM SUMMARY (DRY & WET SYSTEMS)

This table is used to demonstrate compliance for mechanical equipment with mandatory requirements found in §110.1 and §110.2(a) and prescriptive requirements found in §140.4(d), §140.4(e), and §140.4(i) for alterations.

Dry System Equipment Sizing (includes air conditioners, condensers, heat pumps, VRF, furnaces and unit heaters)

01	02	03	04	05	06	07	08	09	10	11
Name or Item Tag	Equipment Category per Tables 110.2	Equipment Type per Tables 110.2 / Title 20	Smallest Size Available ¹ §140.4(a)	Heating Output ^{2,3}			Cooling Output ^{2,3}			Total Sensible Cooling Load (kBtu/h)
HP-1 / C-1	Unitary Heat Pumps	Air-cooled, pkg (3 phase)	NA: Load Controls	70.44	54.86	36.18	35.65	46.32	59.29	62.08
HP-1 / C-2	Unitary Heat Pumps	Air-cooled, pkg (3 phase)	NA: Load Controls	70.44	54.86	36.18	35.92	46.32	56.45	59.57
HP-1 / C-3	Unitary AC/ Condensers	AC, air-cooled pkg (3 phase)	NA: Load Controls	49	49	0	52.26	44.73	56.19	59.79
HP-1 / C-4	Unitary AC/ Condensers	AC, air-cooled pkg (3 phase)	NA: Load Controls	49	49	0	52.26	44.73	56.19	59.79
HP-1 / C-5	Unitary AC/ Condensers	AC, air-cooled pkg (3 phase)	NA: Load Controls	49	49	0	52.29	44.73	59.04	61.39
HP-2 / Work room	Unitary Heat Pumps	Air-cooled, pkg (3 phase)	NA: Load Controls	32.41	22.38	18.43	22.31	17.63	48.54	55.29

FOOTNOTES: Equipment shall be the smallest size, within the available options of the desired equipment line, necessary to meet the design heating and cooling loads of the building per §140.4(e). Healthcare facilities are exempt.
² It is common practice to show rated output capacity on the equipment schedule. Sensible cooling output comes from specification sheet tables.
³ If equipment is heating only, leave cooling output and load blank. If equipment is cooling only, leave heating output and load blank.
⁴ Authority Having Jurisdiction may ask for load calculations used for compliance per §140.4(d).

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
 Registration Date/Time: 2019.1.003 Schema Version: rev 20200601
 Registration Provider: Energsoft
 Report Generated: 2022-12-09 15:18:10

CERTIFICATE OF COMPLIANCE
 Project Name: Roosevelt Elementary HVAC Upgrades Bid C Report Page: (Page 5 of 18)
 Project Address: 2324 Verde Street Date Prepared: 12/9/2022

H. FAN SYSTEMS & AIR ECONOMIZERS

System Name:	HP-1 / C-4	Economizer: ¹	Fixed Temperature	Economizer Controls:	Designed per §140.4(e) and (m)	System Fan Type:	Variable Air Volume
01	02	03	04	05	06	07	08
Fan Name or Item Tag	Fan Function	Qty	Maximum Design Supply Airflow (CFM)	HP Unit ²	Design HP	Fan Power Pressure Drop Adjustment - Table 140.4-B	Device
SF	Supply	1	1800	BHP	0.72		
Total System Design Supply Airflow (CFM):			1800	Total System Design (BHP):	0.72	Maximum System Fan Power (BHP):	

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
 Registration Date/Time: 2019.1.003 Schema Version: rev 20200601
 Registration Provider: Energsoft
 Report Generated: 2022-12-09 15:18:10

CERTIFICATE OF COMPLIANCE
 Project Name: Roosevelt Elementary HVAC Upgrades Bid C Report Page: (Page 8 of 18)
 Project Address: 2324 Verde Street Date Prepared: 12/9/2022

J. VENTILATION AND INDOOR AIR QUALITY

01	02	03	04	05	06	07	08	09
<input type="checkbox"/>	Check the box if the project is showing ventilation calculations on the plans, or attaching the calculations instead of completing this table.							
<input checked="" type="checkbox"/>	Check this box if the project included Nonresidential or Hotel/Motel spaces.							
<input type="checkbox"/>	Check this box if the project included new or altered high-rise residential dwelling units.							
<input type="checkbox"/>	Check the box if the project is using natural ventilation in any nonresidential or hotel/motel spaces to meet required ventilation rates per §120.1(c)(2).							
System Name	HP-1 / C-3	System Design OA CFM Airflow ¹	10	11	12	13	14	15
08	09	10	11	12	13	14	15	16
Space Name or Item Tag	Occupancy Type ²	Conditioned Floor Area (ft²)	# of Shower/heads/toilets	# of people ³	Required Min OA CFM	Required Min CFM	Provided per Design CFM	DCV or Sensor Controls per §120.1(d)(3), §120.1(d)(5), and §120.1(e)(3) ⁴
Classroom C2	Lecture/ postsecondary classroom	960			364.8	0	0	DCV Provided per §120.1(d)(4) Occ Sensor NA: Not required space type
17	Total System Required Min OA CFM				365	18	Ventilation for this System Complies? ⁷	Yes

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
 Registration Date/Time: 2019.1.003 Schema Version: rev 20200601
 Registration Provider: Energsoft
 Report Generated: 2022-12-09 15:18:10

ROOSEVELT ELEMENTARY SCHOOL
 MODERNIZATION
 2324 VERDE STREET
 FOR
 BAKERSFIELD CITY SCHOOL DISTRICT
 BAKERSFIELD, KERN COUNTY, CALIFORNIA



1601 NEW STINE ROAD, SUITE 280
 BAKERSFIELD, CA 93309
 PH: (661) 397-4377
 FAX: (661) 397-4378
 WWW.SCARCHITECT.COM



CHECK AND VERIFY ALL DIMENSIONS BEFORE PROCEEDING WITH THE WORK. REPORT DISCREPANCIES TO THE ARCHITECT. ALL CONSTRUCTION SHALL CONFORM TO THE C.B.C.

**BUILDING 'C'
 TITLE-24**

MARK	DATE	REVISIONS
△		
△		
△		

JOB NO.
 1317
 DRAWN:
 B.S.
 CHECKED:
 M.B.
 DATE:
 8/5/21



bme BASKIN MECHANICAL ENGINEERS
 175 Fulton Street
 Fresno, CA 93721
 Tel: (559) 237-0376
 Job: 21146
 PIt: 12-13-22

STATE OF CALIFORNIA
Mechanical Systems
NRC-MCH-1 CALIFORNIA ENERGY COMMISSION
NRC-MCH-1
CERTIFICATE OF COMPLIANCE
Project Name: Roosevelt Elementary HVAC Upgrades Bid C (Report Page: 12/7/2022)
Project Address: 2324 Verde Street (Date Prepared: 12/7/2022)

J. VENTILATION AND INDOOR AIR QUALITY

Space Name or Item Tag	Occupancy Type ¹	Conditioned Floor Area (ft ²)	# of Shower heads/toilets	# of people ²	Required Min OA CFM	Required Min CFM	Provided per Design CFM	Exh. Vent per §120.1(d)(4)		DCV or Sensor Controls per §120.1(d)(3), §120.1(d)(5), and §120.1(e)(3) ³
								Required Min OA CFM	Required Min CFM	
Classroom C4	Lecture/ postsecondary classroom	960			364.8	0	0			DCV Provided per §120.1(d)(4)
17	Total System Required Min OA CFM									
04										
05										
06										
07										
08										
09										
10										
11										
12										
13										
14										
15										
16										
17										

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
Registration Date/Time: Report Version: 2019.1.003
Registration Provider: Energysoft
Report Generated: 2022-12-09 15:18:10
Schema Version: rev 20200601

STATE OF CALIFORNIA
Mechanical Systems
NRC-MCH-1 CALIFORNIA ENERGY COMMISSION
NRC-MCH-1
CERTIFICATE OF COMPLIANCE
Project Name: Roosevelt Elementary HVAC Upgrades Bid C (Report Page: 12/7/2022)
Project Address: 2324 Verde Street (Date Prepared: 12/7/2022)

L. DISTRIBUTION (DUCTWORK AND PIPING)

The answers to the questions below apply to the following duct systems: HP-1 / C-3 Duct leakage testing triggered for these systems? No

11	No	The scope of the project includes only duct systems serving healthcare facilities
12	Yes	The space conditioning system serves less than 5,000 ft ² of conditioned floor area.
13	Yes	The space conditioning system serves less than 5,000 ft ² of conditioned floor area.
14	No	The combined surface area of the ducts in the following locations is more than 25% of the total surface area of the entire duct system: <input type="checkbox"/> Outdoors <input type="checkbox"/> In a space directly under a roof that has a U-factor greater than the u-factor of the ceiling, or if the roof does not meet the requirements of §140.3(a)(1)B or if the roof has fixed vents or openings to the outside/ unconditioned spaces <input type="checkbox"/> In an unconditioned crawl space <input type="checkbox"/> In other unconditioned spaces
15		The scope of the project includes extending an existing duct system, which is constructed, insulated or sealed with asbestos.
16		The scope of the project includes an existing duct system that is documented to have been previously sealed as confirmed through field verification and diagnostic testing in accordance with procedures in the Reference Nonresidential Appendix NA2.
17	Yes	Duct system shall be sealed in accordance with the California Mechanical Code

The answers to the questions below apply to the following duct systems: HP-1 / C-4 Duct leakage testing triggered for these systems? No

11	No	The scope of the project includes only duct systems serving healthcare facilities
12	Yes	The space conditioning system serves less than 5,000 ft ² of conditioned floor area.
13	Yes	The space conditioning system serves less than 5,000 ft ² of conditioned floor area.
14	No	The combined surface area of the ducts in the following locations is more than 25% of the total surface area of the entire duct system: <input type="checkbox"/> Outdoors <input type="checkbox"/> In a space directly under a roof that has a U-factor greater than the u-factor of the ceiling, or if the roof does not meet the requirements of §140.3(a)(1)B or if the roof has fixed vents or openings to the outside/ unconditioned spaces <input type="checkbox"/> In an unconditioned crawl space <input type="checkbox"/> In other unconditioned spaces
15		The scope of the project includes extending an existing duct system, which is constructed, insulated or sealed with asbestos.
16		The scope of the project includes an existing duct system that is documented to have been previously sealed as confirmed through field verification and diagnostic testing in accordance with procedures in the Reference Nonresidential Appendix NA2.
17	Yes	Duct system shall be sealed in accordance with the California Mechanical Code

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
Registration Date/Time: Report Version: 2019.1.003
Registration Provider: Energysoft
Report Generated: 2022-12-09 15:18:10
Schema Version: rev 20200601

STATE OF CALIFORNIA
Mechanical Systems
NRC-MCH-1 CALIFORNIA ENERGY COMMISSION
NRC-MCH-1
CERTIFICATE OF COMPLIANCE
Project Name: Roosevelt Elementary HVAC Upgrades Bid C (Report Page: 12/7/2022)
Project Address: 2324 Verde Street (Date Prepared: 12/7/2022)

O. DECLARATION OF REQUIRED CERTIFICATES OF ACCEPTANCE

Selectors have been made based on information provided in previous tables of this document. If any selection needs to be changed, please explain why in Table E Additional Remarks. These documents must be provided to the building inspector during construction and can be found online at: https://www.energy.ca.gov/title24/2019standards/2019_compliance_documents/Nonresidential_Documents/NRCA/

Form/Title	Systems/Spaces To Be Field Verified	Field Inspector	
		Pass	Fail
NRCA-MCH-02-A - Outdoor Air must be submitted for all newly installed HVAC units. Note: MCH-02-A can be performed in conjunction with MCH-07-A Supply Fan VFD Acceptance (if applicable) since testing activities overlap.	Carrier 50GCGM06; Carrier 50GCGM06; Carrier 48GCGM06; Carrier 48GCGM06; Carrier 48GCGM06; Carrier 50VT-C24;	<input type="checkbox"/>	<input type="checkbox"/>
NRCA-MCH-03-A - Constant Volume Single Zone HVAC NOTE: This form does not automatically move to "Yes". If Constant Volume Single Zone HVAC Systems are included in the scope, permit applicant should move this form to "Yes".	Carrier 50GCGM06; Carrier 48GCGM06; Carrier 48GCGM06; Carrier 48GCGM06; Carrier 50VT-C24;	<input type="checkbox"/>	<input type="checkbox"/>
NRCA-MCH-05-A - Air Economizer Controls	Carrier 50GCGM06; Carrier 48GCGM06; Carrier 48GCGM06; Carrier 48GCGM06; Carrier 50VT-C24;	<input type="checkbox"/>	<input type="checkbox"/>
NRCA-MCH-06-A Demand Control Ventilation Systems must be submitted for all systems required to employ demand controlled ventilation (refer to §120.1(d)(3) 1) can vary outside ventilation flow rates based on maintaining interior carbon dioxide (CO ₂) concentration setpoints.	Carrier 50GCGM06; Carrier 50GCGM06; Carrier 48GCGM06; Carrier 48GCGM06; Carrier 48GCGM06; Carrier 50VT-C24;	<input type="checkbox"/>	<input type="checkbox"/>
NRCA-MCH-11-A Automatic Demand Shed Controls	Carrier 50GCGM06; Carrier 50GCGM06; Carrier 48GCGM06; Carrier 48GCGM06; Carrier 50VT-C24;	<input type="checkbox"/>	<input type="checkbox"/>

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
Registration Date/Time: Report Version: 2019.1.003
Registration Provider: Energysoft
Report Generated: 2022-12-09 15:18:10
Schema Version: rev 20200601

STATE OF CALIFORNIA
Mechanical Systems
NRC-MCH-1 CALIFORNIA ENERGY COMMISSION
NRC-MCH-1
CERTIFICATE OF COMPLIANCE
Project Name: Roosevelt Elementary HVAC Upgrades Bid C (Report Page: 12/7/2022)
Project Address: 2324 Verde Street (Date Prepared: 12/7/2022)

J. VENTILATION AND INDOOR AIR QUALITY

Space Name or Item Tag	Occupancy Type ¹	Conditioned Floor Area (ft ²)	# of Shower heads/toilets	# of people ²	Required Min OA CFM	Required Min CFM	Provided per Design CFM	Exh. Vent per §120.1(d)(4)		DCV or Sensor Controls per §120.1(d)(3), §120.1(d)(5), and §120.1(e)(3) ³
								Required Min OA CFM	Required Min CFM	
Classroom C1	Lecture/ postsecondary classroom	960			364.8	0	0			DCV Provided per §120.1(d)(4)
Work room	Office space	450			67.5	0	0			DCV NA: Not required space type
17	Total System Required Min OA CFM									

¹ FOOTNOTES: System CFM should include both mechanical and natural ventilation for the zone/system
² Air filtration requirements apply to the following three system types per §120.1(d)(1): space conditioning systems utilizing ducts to supply air to occupiable space; supply-only ventilation systems providing outside air to occupiable space; supply side of balanced ventilation systems including heat recovery and energy recovery ventilation systems providing outside air to occupiable space.
³ Uniform Mechanical Code may have more stringent ventilation requirements; the most stringent code requirement takes precedence.
⁴ See Standards Tables 120.1-A and 120.1-B.
⁵ For lecture halls with fixed seating, the expected number of occupants shall be determined in accordance with the California Building Code.
⁶ §120.2(d)(2) requires systems serving rooms that are required by §120.1(d)(1) to have lighting occupancy sensing controls to also have occupancy sensing zone controls for ventilation. Examples of spaces which require lighting occupancy sensors include offices, 2500 ft² or smaller, multipurpose rooms less than 1,000 ft², classrooms, conference rooms, restrooms, aisles and open areas in warehouses, library book stack aisles, corridors, stairwells, parking garages, and loading and unloading zones, unless excepted by §120.1(d)(1).

K. TERMINAL BOX CONTROLS
This section does not apply to this project.

L. DISTRIBUTION (DUCTWORK AND PIPING)
This table is used to show compliance with mandatory pipe insulation requirements found in §120.3 and prescriptive requirements found in §140.4(f) for duct leakage testing.

Duct Leakage Sealing

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
Registration Date/Time: Report Version: 2019.1.003
Registration Provider: Energysoft
Report Generated: 2022-12-09 15:18:10
Schema Version: rev 20200601

STATE OF CALIFORNIA
Mechanical Systems
NRC-MCH-1 CALIFORNIA ENERGY COMMISSION
NRC-MCH-1
CERTIFICATE OF COMPLIANCE
Project Name: Roosevelt Elementary HVAC Upgrades Bid C (Report Page: 12/7/2022)
Project Address: 2324 Verde Street (Date Prepared: 12/7/2022)

L. DISTRIBUTION (DUCTWORK AND PIPING)

The answers to the questions below apply to the following duct systems: HP-1 / C-5 Duct leakage testing triggered for these systems? No

11	No	The scope of the project includes only duct systems serving healthcare facilities
12	Yes	The space conditioning system serves less than 5,000 ft ² of conditioned floor area.
13	Yes	The space conditioning system serves less than 5,000 ft ² of conditioned floor area.
14	No	The combined surface area of the ducts in the following locations is more than 25% of the total surface area of the entire duct system: <input type="checkbox"/> Outdoors <input type="checkbox"/> In a space directly under a roof that has a U-factor greater than the u-factor of the ceiling, or if the roof does not meet the requirements of §140.3(a)(1)B or if the roof has fixed vents or openings to the outside/ unconditioned spaces <input type="checkbox"/> In an unconditioned crawl space <input type="checkbox"/> In other unconditioned spaces
15		The scope of the project includes extending an existing duct system, which is constructed, insulated or sealed with asbestos.
16		The scope of the project includes an existing duct system that is documented to have been previously sealed as confirmed through field verification and diagnostic testing in accordance with procedures in the Reference Nonresidential Appendix NA2.
17	Yes	Duct system shall be sealed in accordance with the California Mechanical Code

The answers to the questions below apply to the following duct systems: HP-2 / Work room Duct leakage testing triggered for these systems? No

11	No	The scope of the project includes only duct systems serving healthcare facilities
12	Yes	The space conditioning system serves less than 5,000 ft ² of conditioned floor area.
13	Yes	The space conditioning system serves less than 5,000 ft ² of conditioned floor area.
14	No	The combined surface area of the ducts in the following locations is more than 25% of the total surface area of the entire duct system: <input type="checkbox"/> Outdoors <input type="checkbox"/> In a space directly under a roof that has a U-factor greater than the u-factor of the ceiling, or if the roof does not meet the requirements of §140.3(a)(1)B or if the roof has fixed vents or openings to the outside/ unconditioned spaces <input type="checkbox"/> In an unconditioned crawl space <input type="checkbox"/> In other unconditioned spaces
15		The scope of the project includes extending an existing duct system, which is constructed, insulated or sealed with asbestos.
16		The scope of the project includes an existing duct system that is documented to have been previously sealed as confirmed through field verification and diagnostic testing in accordance with procedures in the Reference Nonresidential Appendix NA2.
17	Yes	Duct system shall be sealed in accordance with the California Mechanical Code

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
Registration Date/Time: Report Version: 2019.1.003
Registration Provider: Energysoft
Report Generated: 2022-12-09 15:18:10
Schema Version: rev 20200601

STATE OF CALIFORNIA
Mechanical Systems
NRC-MCH-1 CALIFORNIA ENERGY COMMISSION
NRC-MCH-1
CERTIFICATE OF COMPLIANCE
Project Name: Roosevelt Elementary HVAC Upgrades Bid C (Report Page: 12/7/2022)
Project Address: 2324 Verde Street (Date Prepared: 12/7/2022)

O. DECLARATION OF REQUIRED CERTIFICATES OF ACCEPTANCE

Selectors have been made based on information provided in previous tables of this document. If any selection needs to be changed, please explain why in Table E Additional Remarks. These documents must be provided to the building inspector during construction and can be found online at: https://www.energy.ca.gov/title24/2019standards/2019_compliance_documents/Nonresidential_Documents/NRCA/

Form/Title	Systems/Spaces To Be Field Verified	Field Inspector	
		Pass	Fail
NRCA-MCH-12-A FDD for Packaged Direct Expansion Units	Carrier 50GCGM06; Carrier 50GCGM06; Carrier 48GCGM06; Carrier 48GCGM06; Carrier 50VT-C24;	<input type="checkbox"/>	<input type="checkbox"/>
NRCA-MCH-16-A Supply Air Temperature Reset Controls	Carrier 50GCGM06; Carrier 50GCGM06; Carrier 48GCGM06; Carrier 48GCGM06; Carrier 50VT-C24;	<input type="checkbox"/>	<input type="checkbox"/>
NRCA-MCH-18-A Energy Management Control Systems	Carrier 50GCGM06; Carrier 50GCGM06; Carrier 48GCGM06; Carrier 48GCGM06; Carrier 50VT-C24;	<input type="checkbox"/>	<input type="checkbox"/>

P. DECLARATION OF REQUIRED CERTIFICATES OF VERIFICATION
There are no NRCC forms required for this project.

Q. MANDATORY MEASURES DOCUMENTATION LOCATION
This table is used to indicate where mandatory measures are documented in the plan set or construction documentation.

01	02
Compliance with Mandatory Measures documented through MCH Mandatory Measures Note Block	Yes
	M-Sheets

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
Registration Date/Time: Report Version: 2019.1.003
Registration Provider: Energysoft
Report Generated: 2022-12-09 15:18:10
Schema Version: rev 20200601

STATE OF CALIFORNIA
Mechanical Systems
NRC-MCH-1 CALIFORNIA ENERGY COMMISSION
NRC-MCH-1
CERTIFICATE OF COMPLIANCE
Project Name: Roosevelt Elementary HVAC Upgrades Bid C (Report Page: 12/7/2022)
Project Address: 2324 Verde Street (Date Prepared: 12/7/2022)

L. DISTRIBUTION (DUCTWORK AND PIPING)

The answers to the questions below apply to the following duct systems: HP-1 / C-1 Duct leakage testing triggered for these systems? No

11	No	The scope of the project includes only duct systems serving healthcare facilities
12	Yes	The space conditioning system serves less than 5,000 ft ² of conditioned floor area.
13	Yes	The space conditioning system serves less than 5,000 ft ² of conditioned floor area.
14	No	The combined surface area of the ducts in the following locations is more than 25% of the total surface area of the entire duct system: <input type="checkbox"/> Outdoors <input type="checkbox"/> In a space directly under a roof that has a U-factor greater than the u-factor of the ceiling, or if the roof does not meet the requirements of §140.3(a)(1)B or if the roof has fixed vents or openings to the outside/ unconditioned spaces <input type="checkbox"/> In an unconditioned crawl space <input type="checkbox"/> In other unconditioned spaces
15		The scope of the project includes extending an existing duct system, which is constructed, insulated or sealed with asbestos.
16		The scope of the project includes an existing duct system that is documented to have been previously sealed as confirmed through field verification and diagnostic testing in accordance with procedures in the Reference Nonresidential Appendix NA2.
17	Yes	Duct system shall be sealed in accordance with the California Mechanical Code

The answers to the questions below apply to the following duct systems: HP-1 / C-2 Duct leakage testing triggered for these systems? No

11	No	The scope of the project includes only duct systems serving healthcare facilities
12	Yes	The space conditioning system serves less than 5,000 ft ² of conditioned floor area.
13	Yes	The space conditioning system serves less than 5,000 ft ² of conditioned floor area.
14	No	The combined surface area of the ducts in the following locations is more than 25% of the total surface area of the entire duct system: <input type="checkbox"/> Outdoors <input type="checkbox"/> In a space directly under a roof that has a U-factor greater than the u-factor of the ceiling, or if the roof does not meet the requirements of §140.3(a)(1)B or if the roof has fixed vents or openings to the outside/ unconditioned spaces <input type="checkbox"/> In an unconditioned crawl space <input type="checkbox"/> In other unconditioned spaces
15		The scope of the project includes extending an existing duct system, which is constructed, insulated or sealed with asbestos.
16		The scope of the project includes an existing duct system that is documented to have been previously sealed as confirmed through field verification and diagnostic testing in accordance with procedures in the Reference Nonresidential Appendix NA2.
17	Yes	Duct system shall be sealed in accordance with the California Mechanical Code

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
Registration Date/Time: Report Version: 2019.1.003
Registration Provider: Energysoft
Report Generated: 2022-12-09 15:18:10
Schema Version: rev 20200601

STATE OF CALIFORNIA
Mechanical Systems
NRC-MCH-1 CALIFORNIA ENERGY COMMISSION
NRC-MCH-1
CERTIFICATE OF COMPLIANCE
Project Name: Roosevelt Elementary HVAC Upgrades Bid C (Report Page: 12/7/2022)
Project Address: 2324 Verde Street (Date Prepared: 12/7/2022)

M. COOLING TOWERS
This section does not apply to this project.

N. DECLARATION OF REQUIRED CERTIFICATES OF INSTALLATION
Selections have been made based on information provided in previous tables of this document. If any selection needs to be changed, please explain why in Table E Additional Remarks. These documents must be provided to the building inspector during construction and can be found online at: https://www.energy.ca.gov/title24/2019standards/2019_compliance_documents/Nonresidential_Documents/NRCC/

Form/Title	Field Inspector
Pass	Fail
NRCC-MCH-01-E - Must be submitted for all buildings	<input type="checkbox"/>

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
Registration Date/Time: Report Version: 2019.1.003
Registration Provider: Energysoft
Report Generated: 2022-12-09 15:18:10
Schema Version: rev 20200601

STATE OF CALIFORNIA
Mechanical Systems
NRC-MCH-1 CALIFORNIA ENERGY COMMISSION
NRC-MCH-1
CERTIFICATE OF COMPLIANCE
Project Name: Roosevelt Elementary HVAC Upgrades Bid C (Report Page: 12/7/2022)
Project Address: 2324 Verde Street (Date Prepared: 12/7/2022)

DOCUMENTATION AUTHOR'S DECLARATION STATEMENT
I certify that this Certificate of Compliance documentation is accurate and complete.

Documentation Author Name: Mark Baskin	Documentation Author Signature: Mark Baskin, P.E. 2022.12.09 15:19:08'00'
Company: Baskin Mechanical Engineers	Signature Date: 2022-12-09
Address: 175 Fulton St. Fresno CA 93721	CAIA/MEAS Certification Identification (if applicable): M26578
Phone: 5592370376	

RESPONSIBLE PERSON'S DECLARATION STATEMENT
I certify the following under penalty of perjury under the laws of the State of California:
1. The information provided on this Certificate of Compliance is true and correct.
2. I am eligible under Division 3 of the Business and Professions Code to accept responsibility for the building design or system design identified on this Certificate of Compliance (responsible designer).
3. The energy features and performance specifications, materials, components, and manufactured devices for the building design or system design identified on this Certificate of Compliance conform to the requirements of Title 24, Part 1 and Part 6 of the California Code of Regulations.
4. The building design features or system design features identified on this Certificate of Compliance are consistent with the information provided on other applicable compliance documents, worksheets, calculations, plans and specifications submitted to the enforcement agency for approval with this building permit application.
5. I will ensure that a completed signed copy of this Certificate of Compliance shall be made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections. I understand that a completed signed copy of this Certificate of Compliance is required to be included with the documentation the builder provides to the building owner at occupancy.

Responsible Designer Name: Mark Baskin, P.E.	Responsible Designer Signature: Mark Baskin, P.E. 2022.12.09 15:19:33-08'00'
Company: Baskin Mechanical Engineers	Date Signed: 2022-12-09
Address: 175 Fulton Fresno CA 93721	CAIA/MEAS Certification Identification (if applicable): M26578
Phone: (559) 237-0376	

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
Registration Date/Time: Report Version: 2019.1.003
Registration Provider: Energysoft
Report Generated: 2022-12-09 15:18:10
Schema Version: rev 20200601

PTN: 63321- FILE: 15-6

ROOSEVELT ELEMENTARY SCHOOL
MODERNIZATION
2324 VERDE STREET
FOR
BAKERSFIELD CITY SCHOOL DISTRICT
BAKERSFIELD, KERN COUNTY, CALIFORNIA



1601 NEW STINE ROAD, SUITE 280
BAKERSFIELD, CA 93309
PH: (661) 397-4377
FAX: (661) 397-4378
WWW.SCARCHITECT.COM



CHECK AND VERIFY ALL DIMENSIONS BEFORE PROCEEDING WITH THE WORK. REPORT DISCREPANCIES TO THE ARCHITECT. ALL CONSTRUCTION SHALL CONFORM TO THE C.B.C.

BUILDING 'C'
TITLE-24

MARK	DATE	REVISIONS
△		
△		
△		

JOB NO. 1317
DRAWN: B.S.
CHECKED: M.B.
DATE: 8/5/21

bme BASKIN MECHANICAL ENGINEERS
175 Fulton Street
Fresno, CA 93721
Tel: (559) 237-0376
Job: 21146
Pit: 12-13-22





1601 NEW STINE ROAD, SUITE 280
BAKERSFIELD, CA 93309
PH: (661) 397-4377
FAX: (661) 397-4378
WWW.SCARCHITECT.COM



CHECK AND VERIFY ALL DIMENSIONS BEFORE PROCEEDING WITH THE WORK. REPORT DISCREPANCIES TO THE ARCHITECT. ALL CONSTRUCTION SHALL CONFORM TO THE C.B.C.

**BUILDING 'D'
TITLE-24**

MARK	DATE	REVISIONS
▲		
▲		
▲		

JOB NO.
1317
DRAWN:
B.S.
CHECKED:
M.B.
DATE:
8/5/21



bme BASKIN
MECHANICAL
ENGINEERS
175 Fulton Street
Fresno, CA 93721
Tel: (559) 237-0376
Job: 21146
Pit: 12-13-22

STATE OF CALIFORNIA
Mechanical Systems
NRC-MCH-E CALIFORNIA ENERGY COMMISSION
NRC-MCH-E
CERTIFICATE OF COMPLIANCE NRC-MCH-E
Project Name: Roosevelt Elementary HVAC Upgrades Bid D Report Page: (Page 12 of 16)
Project Address: 2324 Verde Street Date Prepared: 12/9/2022

L. DISTRIBUTION (DUCTWORK and PIPING)

	<input type="checkbox"/>	In other unconditioned spaces
15	<input type="checkbox"/>	The scope of the project includes extending an existing duct system, which is constructed, insulated or sealed with asbestos.
16	<input type="checkbox"/>	The scope of the project includes an existing duct system that is documented to have been previously sealed as confirmed through field verification and diagnostic testing in accordance with procedures in the Reference Nonresidential Appendix NA2.
17	<input type="checkbox"/>	Yes Duct system shall be sealed in accordance with the California Mechanical Code
The answers to the questions below apply to the following duct systems: <input type="checkbox"/> HP-1 / D-1 <input type="checkbox"/> Duct leakage testing triggered for these systems? <input type="checkbox"/> No		
11	<input type="checkbox"/>	No The scope of the project includes only duct systems serving healthcare facilities
12	<input type="checkbox"/>	Yes Duct system provides conditioned air to an occupiable space for a constant volume, single zone, space-conditioning system.
13	<input type="checkbox"/>	Yes The space conditioning system serves less than 5,000 ft ² of conditioned floor area.
14	<input type="checkbox"/>	No The combined surface area of the ducts in the following locations is more than 25% of the total surface area of the entire duct system:
<input type="checkbox"/> Outdoors		
<input type="checkbox"/> In a space directly under a roof that has a U-factor greater than the u-factor of the ceiling, or if the roof does not meet the requirements of §140.3(a)18 or if the roof has fixed vents or openings to the outside/ unconditioned spaces		
<input type="checkbox"/> In an unconditioned crawl space		
<input type="checkbox"/> In other unconditioned spaces		
15	<input type="checkbox"/>	The scope of the project includes extending an existing duct system, which is constructed, insulated or sealed with asbestos.
16	<input type="checkbox"/>	The scope of the project includes an existing duct system that is documented to have been previously sealed as confirmed through field verification and diagnostic testing in accordance with procedures in the Reference Nonresidential Appendix NA2.
17	<input type="checkbox"/>	Yes Duct system shall be sealed in accordance with the California Mechanical Code
The answers to the questions below apply to the following duct systems: <input type="checkbox"/> HP-1 / D-1 <input type="checkbox"/> Duct leakage testing triggered for these systems? <input type="checkbox"/> No		
11	<input type="checkbox"/>	No The scope of the project includes only duct systems serving healthcare facilities
12	<input type="checkbox"/>	Yes Duct system provides conditioned air to an occupiable space for a constant volume, single zone, space-conditioning system.
13	<input type="checkbox"/>	Yes The space conditioning system serves less than 5,000 ft ² of conditioned floor area.
14	<input type="checkbox"/>	No The combined surface area of the ducts in the following locations is more than 25% of the total surface area of the entire duct system:
<input type="checkbox"/> Outdoors		
<input type="checkbox"/> In a space directly under a roof that has a U-factor greater than the u-factor of the ceiling, or if the roof does not meet the requirements of §140.3(a)18 or if the roof has fixed vents or openings to the outside/ unconditioned spaces		
<input type="checkbox"/> In an unconditioned crawl space		

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
Registration Date/Time: Report Version: 2019.1.003
Registration Provider: Energysoft Schema Version: rev 20200601 Report Generated: 2022-12-09 15:22:09

STATE OF CALIFORNIA
Mechanical Systems
NRC-MCH-E CALIFORNIA ENERGY COMMISSION
NRC-MCH-E
CERTIFICATE OF COMPLIANCE NRC-MCH-E
Project Name: Roosevelt Elementary HVAC Upgrades Bid D Report Page: (Page 13 of 16)
Project Address: 2324 Verde Street Date Prepared: 12/9/2022

O. DECLARATION OF REQUIRED CERTIFICATES OF ACCEPTANCE

Selections have been made based on information provided in previous tables of this document. If any selection needs to be changed, please explain why in Table E Additional Remarks. These documents must be provided to the building inspector during construction and can be found online at https://www.energy.ca.gov/title24/2019standards/2019_compliance_documents/Nonresidential_Documents/NRCA/

Form/Title	Systems/Spaces To Be Field Verified	Field Inspector	
		Pass	Fail
NRCA-MCH-16-A Supply Air Temperature Reset Controls	Carrier 50GCGM06; Carrier 50GCGM06; Carrier 48GCGM06; Carrier 48GCGM06; Carrier 48GCGM06;	<input type="checkbox"/>	<input type="checkbox"/>
NRCA-MCH-18-A Energy Management Control Systems	Carrier 50GCGM06; Carrier 50GCGM06; Carrier 48GCGM06; Carrier 48GCGM06; Carrier 48GCGM06;	<input type="checkbox"/>	<input type="checkbox"/>

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
Registration Date/Time: Report Version: 2019.1.003
Registration Provider: Energysoft Schema Version: rev 20200601 Report Generated: 2022-12-09 15:22:09

P. DECLARATION OF REQUIRED CERTIFICATES OF VERIFICATION

There are no NRCV forms required for this project.

Compliance with Mandatory Measures documented through MCH	01	02
Mandatory Measures Note Block	Yes	M-Sheets

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
Registration Date/Time: Report Version: 2019.1.003
Registration Provider: Energysoft Schema Version: rev 20200601 Report Generated: 2022-12-09 15:22:09

STATE OF CALIFORNIA
Mechanical Systems
NRC-MCH-E CALIFORNIA ENERGY COMMISSION
NRC-MCH-E
CERTIFICATE OF COMPLIANCE NRC-MCH-E
Project Name: Roosevelt Elementary HVAC Upgrades Bid D Report Page: (Page 11 of 16)
Project Address: 2324 Verde Street Date Prepared: 12/9/2022

L. DISTRIBUTION (DUCTWORK and PIPING)

	<input type="checkbox"/>	In other unconditioned spaces
15	<input type="checkbox"/>	The scope of the project includes extending an existing duct system, which is constructed, insulated or sealed with asbestos.
16	<input type="checkbox"/>	The scope of the project includes an existing duct system that is documented to have been previously sealed as confirmed through field verification and diagnostic testing in accordance with procedures in the Reference Nonresidential Appendix NA2.
17	<input type="checkbox"/>	Yes Duct system shall be sealed in accordance with the California Mechanical Code
The answers to the questions below apply to the following duct systems: <input type="checkbox"/> HP-1 / D-2 <input type="checkbox"/> Duct leakage testing triggered for these systems? <input type="checkbox"/> No		
11	<input type="checkbox"/>	No The scope of the project includes only duct systems serving healthcare facilities
12	<input type="checkbox"/>	Yes Duct system provides conditioned air to an occupiable space for a constant volume, single zone, space-conditioning system.
13	<input type="checkbox"/>	Yes The space conditioning system serves less than 5,000 ft ² of conditioned floor area.
14	<input type="checkbox"/>	No The combined surface area of the ducts in the following locations is more than 25% of the total surface area of the entire duct system:
<input type="checkbox"/> Outdoors		
<input type="checkbox"/> In a space directly under a roof that has a U-factor greater than the u-factor of the ceiling, or if the roof does not meet the requirements of §140.3(a)18 or if the roof has fixed vents or openings to the outside/ unconditioned spaces		
<input type="checkbox"/> In an unconditioned crawl space		
<input type="checkbox"/> In other unconditioned spaces		
15	<input type="checkbox"/>	The scope of the project includes extending an existing duct system, which is constructed, insulated or sealed with asbestos.
16	<input type="checkbox"/>	The scope of the project includes an existing duct system that is documented to have been previously sealed as confirmed through field verification and diagnostic testing in accordance with procedures in the Reference Nonresidential Appendix NA2.
17	<input type="checkbox"/>	Yes Duct system shall be sealed in accordance with the California Mechanical Code
The answers to the questions below apply to the following duct systems: <input type="checkbox"/> HP-1 / D-3 <input type="checkbox"/> Duct leakage testing triggered for these systems? <input type="checkbox"/> No		
11	<input type="checkbox"/>	No The scope of the project includes only duct systems serving healthcare facilities
12	<input type="checkbox"/>	Yes Duct system provides conditioned air to an occupiable space for a constant volume, single zone, space-conditioning system.
13	<input type="checkbox"/>	Yes The space conditioning system serves less than 5,000 ft ² of conditioned floor area.
14	<input type="checkbox"/>	No The combined surface area of the ducts in the following locations is more than 25% of the total surface area of the entire duct system:
<input type="checkbox"/> Outdoors		
<input type="checkbox"/> In a space directly under a roof that has a U-factor greater than the u-factor of the ceiling, or if the roof does not meet the requirements of §140.3(a)18 or if the roof has fixed vents or openings to the outside/ unconditioned spaces		
<input type="checkbox"/> In an unconditioned crawl space		

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
Registration Date/Time: Report Version: 2019.1.003
Registration Provider: Energysoft Schema Version: rev 20200601 Report Generated: 2022-12-09 15:22:09

STATE OF CALIFORNIA
Mechanical Systems
NRC-MCH-E CALIFORNIA ENERGY COMMISSION
NRC-MCH-E
CERTIFICATE OF COMPLIANCE NRC-MCH-E
Project Name: Roosevelt Elementary HVAC Upgrades Bid D Report Page: (Page 14 of 16)
Project Address: 2324 Verde Street Date Prepared: 12/9/2022

O. DECLARATION OF REQUIRED CERTIFICATES OF ACCEPTANCE

Selections have been made based on information provided in previous tables of this document. If any selection needs to be changed, please explain why in Table E Additional Remarks. These documents must be provided to the building inspector during construction and can be found online at https://www.energy.ca.gov/title24/2019standards/2019_compliance_documents/Nonresidential_Documents/NRCA/

Form/Title	Systems/Spaces To Be Field Verified	Field Inspector	
		Pass	Fail
NRCA-MCH-02-A - Outdoor Air must be submitted for all newly installed HVAC units. Note: MCH-02-A can be performed in conjunction with MCH-07-A Supply Fan VFD Acceptance (if applicable) since testing activities overlap.	Carrier 50GCGM06; Carrier 50GCGM06; Carrier 48GCGM06; Carrier 48GCGM06;	<input type="checkbox"/>	<input type="checkbox"/>
NRCA-MCH-05-A - Air Economizer Controls	Carrier 50GCGM06; Carrier 50GCGM06; Carrier 48GCGM06; Carrier 48GCGM06;	<input type="checkbox"/>	<input type="checkbox"/>
NRCA-MCH-06-A Demand Control Ventilation Systems must be submitted for all systems required to employ demand controlled ventilation (refer to §120.3(i)(1)) can vary outside ventilation flow rates based on maintaining interior carbon dioxide (CO2) concentration setpoints.	Carrier 50GCGM06; Carrier 50GCGM06; Carrier 48GCGM06; Carrier 48GCGM06;	<input type="checkbox"/>	<input type="checkbox"/>
NRCA-MCH-11-A Automatic Demand Shed Controls	Carrier 50GCGM06; Carrier 50GCGM06; Carrier 48GCGM06; Carrier 48GCGM06;	<input type="checkbox"/>	<input type="checkbox"/>
NRCA-MCH-12-A FDD for Packaged Direct Expansion Units	Carrier 50GCGM06; Carrier 50GCGM06; Carrier 48GCGM06; Carrier 48GCGM06;	<input type="checkbox"/>	<input type="checkbox"/>

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
Registration Date/Time: Report Version: 2019.1.003
Registration Provider: Energysoft Schema Version: rev 20200601 Report Generated: 2022-12-09 15:22:09

STATE OF CALIFORNIA
Mechanical Systems
NRC-MCH-E CALIFORNIA ENERGY COMMISSION
NRC-MCH-E
CERTIFICATE OF COMPLIANCE NRC-MCH-E
Project Name: Roosevelt Elementary HVAC Upgrades Bid D Report Page: (Page 16 of 16)
Project Address: 2324 Verde Street Date Prepared: 12/9/2022

DOCUMENTATION AUTHOR'S DECLARATION STATEMENT

I certify that this Certificate of Compliance documentation is accurate and complete.

Documentation Author Name: Mark Baskin	Documentation Author Signature: Mark Baskin, P.E.
Company: Baskin Mechanical Engineers	Signature Date: 2022-12-09
Address: 175 Fulton St, Fresno CA 93721	CEA/HERS Certification Identification (if applicable): M26578
Phone: (559) 237-0376	Phone: (559) 237-0376

RESPONSIBLE PERSON'S DECLARATION STATEMENT

I certify the following under penalty of perjury, under the laws of the State of California:

- The information provided on this Certificate of Compliance is true and correct.
- I am eligible under Division 3 of the Business and Professions Code to accept responsibility for the building design or system design identified on this Certificate of Compliance (responsible design).
- The energy features and performance specifications, materials, components and manufacturer devices for the building design or system design identified on this Certificate of Compliance conform to the requirements of Title 24, Part 1 and Part 6 of the California Code of Regulations.
- The building design features or system design features identified on this Certificate of Compliance are consistent with the information provided on other applicable compliance documents, worksheets, calculations, plans and specifications submitted to the enforcement agency for approval with this building permit application.
- I warrant that a completed agreed copy of this Certificate of Compliance shall be made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections. I understand that a completed agreed copy of this Certificate of Compliance is required to be included with the documentation the builder provides to the building owner at occupancy.

Responsible Designer Name: Mark Baskin, P.E.	Responsible Designer Signature: Mark Baskin, P.E.
Company: Baskin Mechanical Engineers	Date Signed: 2022-12-09
Address: 175 Fulton St, Fresno CA 93721	Address: 175 Fulton St, Fresno CA 93721
Phone: (559) 237-0376	Phone: (559) 237-0376

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
Registration Date/Time: Report Version: 2019.1.003
Registration Provider: Energysoft Schema Version: rev 20200601 Report Generated: 2022-12-09 15:22:09

STATE OF CALIFORNIA
Mechanical Systems
NRC-MCH-E CALIFORNIA ENERGY COMMISSION
NRC-MCH-E
CERTIFICATE OF COMPLIANCE NRC-MCH-E
Project Name: Roosevelt Elementary HVAC Upgrades Bid D Report Page: (Page 10 of 16)
Project Address: 2324 Verde Street Date Prepared: 12/9/2022

L. VENTILATION AND INDOOR AIR QUALITY

¹ Air filtration requirements apply to the following three system types per §120.1(c)(1): space conditioning systems utilizing ducts to supply air to occupiable spaces; supply-only ventilation systems providing outside air to occupiable space; supply side of balanced ventilation systems including heat recovery and energy recovery ventilation systems providing outside air to occupiable space.

² Uniform Mechanical Code may have more stringent ventilation requirements; the most stringent code requirement takes precedence.

³ See Standards Tables 120.14 and 120.18.

⁴ For lecture halls with fixed seating, the expected number of occupants shall be determined in accordance with the California Building Code.

⁵ §120.2(i)(3) requires systems serving rooms that are required by §130.1(c) to have lighting occupancy sensing controls to also have occupancy sensing zone controls for ventilation. Examples of spaces which require lighting occupancy sensors include offices 250ft² or smaller, multipurpose rooms less than 1,000 ft², classrooms, conference rooms, restrooms, aisles and open areas in warehouses, library book stack aisles, corridors, storerooms, parking garages, and loading and unloading zones, unless excepted by §130.1(c).

K. TERMINAL BOX CONTROLS

This section does not apply to this project.

L. DISTRIBUTION (DUCTWORK and PIPING)

This table is used to show compliance with mandatory pipe insulation requirements found in §120.3 and prescriptive requirements found in §140.4(i) for duct leakage testing.

The answers to the questions below apply to the following duct systems: HP-1 / D-1 Duct leakage testing triggered for these systems? No

11	<input type="checkbox"/>	No The scope of the project includes only duct systems serving healthcare facilities
12	<input type="checkbox"/>	Yes Duct system provides conditioned air to an occupiable space for a constant volume, single zone, space-conditioning system.
13	<input type="checkbox"/>	Yes The space conditioning system serves less than 5,000 ft ² of conditioned floor area.
14	<input type="checkbox"/>	No The combined surface area of the ducts in the following locations is more than 25% of the total surface area of the entire duct system:
<input type="checkbox"/> Outdoors		
<input type="checkbox"/> In a space directly under a roof that has a U-factor greater than the u-factor of the ceiling, or if the roof does not meet the requirements of §140.3(a)18 or if the roof has fixed vents or openings to the outside/ unconditioned spaces		
<input type="checkbox"/> In an unconditioned crawl space		

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
Registration Date/Time: Report Version: 2019.1.003
Registration Provider: Energysoft Schema Version: rev 20200601 Report Generated: 2022-12-09 15:22:09

STATE OF CALIFORNIA
Mechanical Systems
NRC-MCH-E CALIFORNIA ENERGY COMMISSION
NRC-MCH-E
CERTIFICATE OF COMPLIANCE NRC-MCH-E
Project Name: Roosevelt Elementary HVAC Upgrades Bid D Report Page: (Page 13 of 16)
Project Address: 2324 Verde Street Date Prepared: 12/9/2022

L. DISTRIBUTION (DUCTWORK and PIPING)

	<input type="checkbox"/>	In other unconditioned spaces
15	<input type="checkbox"/>	The scope of the project includes extending an existing duct system, which is constructed, insulated or sealed with asbestos.
16	<input type="checkbox"/>	The scope of the project includes an existing duct system that is documented to have been previously sealed as confirmed through field verification and diagnostic testing in accordance with procedures in the Reference Nonresidential Appendix NA2.
17	<input type="checkbox"/>	Yes Duct system shall be sealed in accordance with the California Mechanical Code

M. COOLING TOWERS

This section does not apply to this project.

N. DECLARATION OF REQUIRED CERTIFICATES OF INSTALLATION

Selections have been made based on information provided in previous tables of this document. If any selection needs to be changed, please explain why in Table E Additional Remarks. These documents must be provided to the building inspector during construction and can be found online at https://www.energy.ca.gov/title24/2019standards/2019_compliance_documents/Nonresidential_Documents/NRCA/

Form/Title	Field Inspector	
	Pass	Fail
NRC-MCH-01-E - Must be submitted for all buildings	<input type="checkbox"/>	<input type="checkbox"/>

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
Registration Date/Time: Report Version: 2019.1.003
Registration Provider: Energysoft Schema Version: rev 20200601 Report Generated: 2022-12-09 15:22:09

CERTIFICATE OF COMPLIANCE
This document is used to demonstrate compliance for mechanical systems that are within the scope of the permit application and are demonstrating compliance using the prescriptive path outlined in §140.4, or §141.0(b)(2) for alterations.
Project Name: Roosevelt Elementary HVAC Upgrades Bldg I [Report Page: (Page 1 of 11)]
Project Address: 2324 Verde Street [Date Prepared: 12/9/2022]

A. GENERAL INFORMATION

01 Project Location (City)	Bakersfield	04 Total Conditioned Floor Area	2696
02 Climate Zone	13	05 Total Unconditioned Floor Area	0
03 Occupancy Types Within Project:		06 # of Stories (Excl. Above Grade)	1
<input checked="" type="checkbox"/> Office (O)	<input type="checkbox"/> Retail (M)	<input type="checkbox"/> Non-refrigerated Warehouse (S)	
<input type="checkbox"/> Hotel/ Motel Guest Rooms (R-1)	<input type="checkbox"/> School (E)	<input type="checkbox"/> Healthcare Facility (H)	
<input type="checkbox"/> High-Rise Residential (R-2/R-3)	<input type="checkbox"/> Relocatable Class Bldg (L)	<input checked="" type="checkbox"/> Other (write in)	See Table J

B. PROJECT SCOPE
This table includes mechanical systems or components that are within the scope of the permit application and are demonstrating compliance using the prescriptive path outlined in §140.4, or §141.0(b)(2) for alterations.

01 Air System(s)	02 Wet System Components	03 Dry System Components
<input checked="" type="checkbox"/> Heating Air System	<input type="checkbox"/> Water Economizer	<input checked="" type="checkbox"/> Air Economizer
<input checked="" type="checkbox"/> Cooling Air System	<input type="checkbox"/> Pumps	<input type="checkbox"/> Electric Resistance Heat
<input type="checkbox"/> Mechanical Controls	<input type="checkbox"/> System Piping	<input type="checkbox"/> Fan Systems
<input checked="" type="checkbox"/> Mechanical Controls (existing to remain, altered or new)	<input type="checkbox"/> Cooling Towers	<input checked="" type="checkbox"/> Ductwork (existing to remain, altered or new)
	<input type="checkbox"/> Chillers	<input checked="" type="checkbox"/> Ventilation
	<input type="checkbox"/> Boilers	<input type="checkbox"/> Zonal Systems/ Terminal Boxes

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
Registration Date/Time: Report Version: 2019.1.003
Registration Provider: Energoft Schema Version: rev.20200601
Report Generated: 2022-12-09 16:07:50

CERTIFICATE OF COMPLIANCE
Project Name: Roosevelt Elementary HVAC Upgrades Bldg I [Report Page: (Page 4 of 11)]
Project Address: 2324 Verde Street [Date Prepared: 12/9/2022]

F. HVAC SYSTEM SUMMARY (DRY & WET SYSTEMS)
Dry System Equipment Efficiency (other than Package Terminal Air Conditioners (PTAC) and Package Terminal Heat Pumps (PTHP))

01	02	03	04	05	06	07	08	09
Name or Item Tag	Site Category	Rating Condition (°F)	Efficiency Unit	Minimum Efficiency Required per Tables 110.2.2 / Title 20	Design Efficiency	Efficiency Unit	Minimum Efficiency Required per Tables 110.2.2 / Title 20	Design Efficiency
HP-1 / E-1	>=65,000 and <135,000		CDP	3.3	3.6	EER	11	11.2
HP-2 / E-2	>=65,000 and <135,000		CDP	3.3	3.6	EER	11	11.2

G. PUMPS
This section does not apply to this project.

H. FAN SYSTEMS & AIR ECONOMIZERS
This table is used to demonstrate compliance with prescriptive requirements found in §140.4(c), §140.4(e), and §140.4(m) for fan systems. Fan systems serving only process loads are exempt from these requirements and do not need to be included in Table H.

01	02	03	04	05	06	07	08	09
System Name	HP-1 / E-1	Economizer ¹	Fixed Temperature	Economizer Controls	Designed per §140.4(e) and (m)	System Fan Type:	Variable Air Volume	
SF	Supply	1	2100	BHP	0.83	Device	Design Airflow through Device (CFM)	
Total System Design Supply Airflow (CFM):			2100	Total System Design (BHP):	0.83	Maximum System Fan Power (BHP):		

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
Registration Date/Time: Report Version: 2019.1.003
Registration Provider: Energoft Schema Version: rev.20200601
Report Generated: 2022-12-09 16:07:50

CERTIFICATE OF COMPLIANCE
Project Name: Roosevelt Elementary HVAC Upgrades Bldg I [Report Page: (Page 7 of 11)]
Project Address: 2324 Verde Street [Date Prepared: 12/9/2022]

L. VENTILATION AND INDOOR AIR QUALITY

Space Name or Item Tag	Mechanical Ventilation Required per §120.1(c)(3) ²	Exh. Vent per §120.1(c)(4)	DCV or Sensor Controls per §120.1(d)(3), §120.1(d)(5), and §120.1(e)(1) ³
Classroom E2	Lecture/postsecondary classroom	1230	DCV: Provided per §120.1(d)(4) Occ Sensor: NA: Not required space type
Work Room	Office space	236	DCV: NA: Not required per §120.1(d)(3) Occ Sensor: NA: Not required space type
17	Total System Required Min OA CFM	503	Ventilation for this System Complies? Yes

¹ FOOTNOTES: System CFM should include both mechanical and natural ventilation for the zone/system.
² Air filtration requirements apply to the following three system types per §120.1(c)(1): space conditioning systems utilizing ducts to supply air to occupiable space; supply-only ventilation systems providing outside air to occupiable space; supply side of balanced ventilation systems including heat recovery and energy recovery ventilation systems providing outside air to occupiable space.
³ Uniform Mechanical Code may have more stringent ventilation requirements; the most stringent code requirement takes precedence.
⁴ See Standards Tables 120.1-A and 120.1-B.
⁵ For lecture halls with fixed seating, the expected number of occupants shall be determined in accordance with the California Building Code.
⁶ §120.2(d) requires systems serving rooms that are required by §120.1(d) to have lighting occupancy sensing controls to also have occupancy sensing zone controls for ventilation. Examples of spaces which require lighting occupancy sensors include offices >200² or smaller, multipurpose rooms less than 1,000², classrooms, conference rooms, restrooms, aisles and open areas in warehouses, library book stack aisles, corridors, stairwells, parking garages, and loading and unloading zones, unless excepted by §120.3(c).

K. TERMINAL BOX CONTROLS
This section does not apply to this project.

L. DISTRIBUTION (DUCTWORK AND PIPING)
This table is used to show compliance with mandatory pipe insulation requirements found in §120.3 and prescriptive requirements found in §140.4(f) for duct leakage testing.

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
Registration Date/Time: Report Version: 2019.1.003
Registration Provider: Energoft Schema Version: rev.20200601
Report Generated: 2022-12-09 16:07:50

CERTIFICATE OF COMPLIANCE
Project Name: Roosevelt Elementary HVAC Upgrades Bldg I [Report Page: (Page 2 of 11)]
Project Address: 2324 Verde Street [Date Prepared: 12/9/2022]

C. COMPLIANCE RESULTS
Table C will indicate if the project data input into the compliance document is compliant with mechanical requirements. This table is not editable by the user. If this table says "DOES NOT COMPLY" or "COMPLIES with Exceptional Conditions" refer to Table D, or the table indicated as not compliant for guidance.

01	02	03	04	05	06	07	08	09
System Summary	Pumps	Fans/Economizers	System Controls	Ventilation	Terminal Box Controls	Distribution	Cooling Towers	Compliance Results
§120.3, §110.2, §140.4	§140.4(f)	§140.4(c), §140.4(e), §140.4(m)	§120.2, §120.2, §140.4(f)	§120.1	§120.3, §140.4(d)	§120.3, §140.4(f)	§110.2(a)(2)	COMPLIES
(See Table G)	(See Table G)	(See Table H)	(See Table I)	(See Table J)	(See Table K)	(See Table L)	(See Table M)	COMPLIES
Yes AND	AND	Yes AND	Yes AND	Yes AND	AND	Yes AND	AND	COMPLIES

D. EXCEPTIONAL CONDITIONS
This table is auto-filled with uneditable comments because of selections made or data entered in tables throughout the form.

E. ADDITIONAL REMARKS
This table includes remarks made by the permit applicant to the Authority Having Jurisdiction.

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
Registration Date/Time: Report Version: 2019.1.003
Registration Provider: Energoft Schema Version: rev.20200601
Report Generated: 2022-12-09 16:07:50

CERTIFICATE OF COMPLIANCE
Project Name: Roosevelt Elementary HVAC Upgrades Bldg I [Report Page: (Page 5 of 11)]
Project Address: 2324 Verde Street [Date Prepared: 12/9/2022]

H. FAN SYSTEMS & AIR ECONOMIZERS

System Name	HP-2 / E-2	Economizer ¹	Fixed Temperature	Economizer Controls	Designed per §140.4(e) and (m)	System Fan Type:	Variable Air Volume
SF	Supply	1	2100	BHP	0.83	Device	Design Airflow through Device (CFM)
Total System Design Supply Airflow (CFM):			2100	Total System Design (BHP):	0.83	Maximum System Fan Power (BHP):	

¹ FOOTNOTES: Computer room economizers must meet requirements of §140.3(a), and will be documented on the NRC-MCH-E document.
² The unit used for HP must be consistent for all fans within a system.

I. SYSTEM CONTROLS
This table is used to demonstrate compliance with mandatory controls in §120.2 and §120.2 and prescriptive controls in §140.4(f), (g), and (n) or requirements in §141.0(b)(2), for altered space conditioning systems.

01	02	03	04	05	06	07	08	09
System Name	System Zoning	Conditioned Floor Area Being Served (ft ²)	Thermostats §120.2(b) & (c) ¹ , §120.2(a)(b), §141.0(b)(2)	Shut Off Controls §120.2(a)	Isolation Zone Controls §120.2(a)	Demand Response §120.12 and §120.2(b)	Supply Air Temp. Reset §140.4(f)	Window Interlocks per §140.4(n)
HP-1 / E-1	Single zone	<= 25,000 ft ²	Setback	Auto Timer Switch	4 Hour Timer	EMCS	Included	Provided
HP-2 / E-2	Single zone	<= 25,000 ft ²	Setback	Auto Timer Switch	4 Hour Timer	EMCS	Included	Provided

¹ FOOTNOTES: Gravity gas wall heaters, gravity floor heaters, gravity room heaters, non-central electric heaters, preheaters or decorative gas appliances, wood stoves are not required to have setback thermostats.
² *Notes: Controls with a * require a note in the space below explaining how compliance is achieved. EX. system 1: SA Temp Reset. Exempt because zones compliant with §140.4(d); EXCEPTION 1 to §140.4(f).

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
Registration Date/Time: Report Version: 2019.1.003
Registration Provider: Energoft Schema Version: rev.20200601
Report Generated: 2022-12-09 16:07:50

CERTIFICATE OF COMPLIANCE
Project Name: Roosevelt Elementary HVAC Upgrades Bldg I [Report Page: (Page 8 of 11)]
Project Address: 2324 Verde Street [Date Prepared: 12/9/2022]

L. DISTRIBUTION (DUCTWORK AND PIPING)

11	12	13	14	15	16	17
11	No	The scope of the project includes only duct systems serving healthcare facilities	HP-1 / E-1	Duct leakage testing triggered for these systems?	No	
12	Yes	Duct system provides conditioned air to an occupiable space for a constant volume, single zone, space-conditioning system.				
13	Yes	The space conditioning system serves less than 5,000 ² of conditioned floor area.				
14	No	The combined surface area of the ducts in the following locations is more than 25% of the total surface area of the entire duct system:				
		<input type="checkbox"/> Outdoors				
		<input type="checkbox"/> In a space directly under a roof that has a U-factor greater than the u-factor of the ceiling, or if the roof does not meet the requirements of §140.3(a)(1) or if the roof has fixed vents or openings to the outside/unconditioned spaces				
		<input type="checkbox"/> In an unconditioned crawl space				
		<input type="checkbox"/> In other unconditioned spaces				
15		The scope of the project includes extending an existing duct system, which is constructed, insulated or sealed with asbestos.				
16		The scope of the project includes an existing duct system that is documented to have been previously sealed as confirmed through field verification and diagnostic testing in accordance with procedures in the Reference Nonresidential Appendix NA2.				
17	Yes	Duct system shall be sealed in accordance with the California Mechanical Code	HP-2 / E-2	Duct leakage testing triggered for these systems?	No	
11	No	The scope of the project includes only duct systems serving healthcare facilities				
12	Yes	Duct system provides conditioned air to an occupiable space for a constant volume, single zone, space-conditioning system.				
13	Yes	The space conditioning system serves less than 5,000 ² of conditioned floor area.				
14	No	The combined surface area of the ducts in the following locations is more than 25% of the total surface area of the entire duct system:				
		<input type="checkbox"/> Outdoors				
		<input type="checkbox"/> In a space directly under a roof that has a U-factor greater than the u-factor of the ceiling, or if the roof does not meet the requirements of §140.3(a)(1) or if the roof has fixed vents or openings to the outside/unconditioned spaces				
		<input type="checkbox"/> In an unconditioned crawl space				
		<input type="checkbox"/> In other unconditioned spaces				
15		The scope of the project includes extending an existing duct system, which is constructed, insulated or sealed with asbestos.				
16		The scope of the project includes an existing duct system that is documented to have been previously sealed as confirmed through field verification and diagnostic testing in accordance with procedures in the Reference Nonresidential Appendix NA2.				
17	Yes	Duct system shall be sealed in accordance with the California Mechanical Code				

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
Registration Date/Time: Report Version: 2019.1.003
Registration Provider: Energoft Schema Version: rev.20200601
Report Generated: 2022-12-09 16:07:50

CERTIFICATE OF COMPLIANCE
Project Name: Roosevelt Elementary HVAC Upgrades Bldg I [Report Page: (Page 3 of 11)]
Project Address: 2324 Verde Street [Date Prepared: 12/9/2022]

F. HVAC SYSTEM SUMMARY (DRY & WET SYSTEMS)
This table is used to demonstrate compliance for mechanical equipment with mandatory requirements found in §120.1 and §120.2(a) and prescriptive requirements found in §140.4(a), §140.4(b), and §140.4(f) or §141.0(b)(2) for alterations.

01	02	03	04	05	06	07	08	09	10	11
Name or Item Tag	Equipment Category per Tables 110.2	Equipment Type per Tables 110.2 / Title 20	Smallest Size Available ¹ §140.4(a)	Per Design (kBtu/h)	Rated (kBtu/h)	Supp. Heating Output (kBtu/h)	Sensible Per Design (kBtu/h)	Rated (kBtu/h)	Total Heating Load (kBtu/h)	Total Sensible Cooling Load (kBtu/h)
HP-1 / E-1	Unitary Heat Pumps	Air-cooled, pkg (3 phase)	NA: Load Controls	75.87	63.55	36.18	66.92	55.3	76.17	80.52
HP-2 / E-2	Unitary Heat Pumps	Air-cooled, pkg (3 phase)	NA: Load Controls	75.87	63.55	36.18	67.31	55.3	86.81	89.88

¹ FOOTNOTES: Equipment shall be the smallest size, within the available options of the desired equipment line, necessary to meet the design heating and cooling loads of the building per §140.4(g). Healthcare facilities are exempt.
² It is common practice to show rated output capacity on the equipment schedule. Sensible cooling output comes from specification sheet tables.
³ If equipment is heating only, leave cooling output and load blank. If equipment is cooling only, leave heating output and load blank.
⁴ Authority Having Jurisdiction may ask for load calculations used for compliance per §140.4(b).

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
Registration Date/Time: Report Version: 2019.1.003
Registration Provider: Energoft Schema Version: rev.20200601
Report Generated: 2022-12-09 16:07:50

CERTIFICATE OF COMPLIANCE
Project Name: Roosevelt Elementary HVAC Upgrades Bldg I [Report Page: (Page 6 of 11)]
Project Address: 2324 Verde Street [Date Prepared: 12/9/2022]

J. VENTILATION AND INDOOR AIR QUALITY
This table is used to demonstrate compliance with mandatory ventilation requirements in §120.1 and §120.2(a)(2) for all nonresidential, high-rise residential and hotel/motel occupancies. For alterations, only ventilation systems being altered within the scope of the permit application need to be documented in this table. In lieu of this table, the required outdoor ventilation rates and airflow may be shown on the plans or the calculations can be presented in a spreadsheet.

01	02	03	04	05	06	07
System Name	HP-1 / E-1	System Design OA CFM Airflow ¹	468	System Design Transfer Air CFM	0	Air Filtration per §120.1(c) and §141.0(b)(2) ²
08	09	10	11	12	13	14
Mechanical Ventilation Required per §120.1(c)(3) ³						
Space Name or Item Tag	Occupancy Type ⁴	Conditioned Floor Area (ft ²)	# of Shower heads/toilets	# of people ⁵	Required Min OA CFM	Provided per Design CFM
Classroom E1	Lecture/postsecondary classroom	1230		467.4	0	0
17	Total System Required Min OA CFM	467	18	Ventilation for this System Complies?	Yes	

¹ *Notes: Controls with a * require a note in the space below explaining how compliance is achieved. EX. system 1: SA Temp Reset. Exempt because zones compliant with §140.4(d); EXCEPTION 1 to §140.4(f).

M. COOLING TOWERS
This section does not apply to this project.

N. DECLARATION OF REQUIRED CERTIFICATES OF INSTALLATION
Selections have been made based on information provided in previous tables of this document. If any selection needs to be changed, please explain why in Table E Additional Remarks. These documents must be provided to the building inspector during construction and can be found online at https://www.energy.ca.gov/title24/2019standards/2019_compliance_documents/Nonresidential_Documents/NR/C/

Form/Title	Field Inspector	Pass	Fail
NRCH-MCH-01-E - Must be submitted for all buildings		<input type="checkbox"/>	<input type="checkbox"/>

O. DECLARATION OF REQUIRED CERTIFICATES OF ACCEPTANCE
Selections have been made based on information provided in previous tables of this document. If any selection needs to be changed, please explain why in Table E Additional Remarks. These documents must be provided to the building inspector during construction and can be found online at https://www.energy.ca.gov/title24/2019standards/2019_compliance_documents/Nonresidential_Documents/NR/C/

Form/Title	Systems/Spaces To Be Field Verified	Field Inspector	Pass	Fail
NRCA-MCH-03-A - Outdoor Air must be submitted for all newly installed HVAC units. Note: MCH-02-A can be performed in conjunction with MCH-07-A Supply Fan VFD Acceptance (if applicable) since testing activities overlap.	Carrier SOGCM07; Carrier SOGCM07;		<input type="checkbox"/>	<input type="checkbox"/>
NRCA-MCH-05-A - Air Economizer Controls	Carrier SOGCM07; Carrier SOGCM07;		<input type="checkbox"/>	<input type="checkbox"/>
NRCA-MCH-06-A Demand Control Ventilation Systems must be submitted for all systems required to employ demand controlled ventilation (refer to §120.1(c)(1)) can vary outside ventilation flow rates based on maintaining indoor carbon dioxide (CO2) concentration setpoints.	Carrier SOGCM07; Carrier SOGCM07;		<input type="checkbox"/>	<input type="checkbox"/>
NRCA-MCH-11-A Automatic Demand Shed Controls	Carrier SOGCM07; Carrier SOGCM07;		<input type="checkbox"/>	<input type="checkbox"/>
NRCA-MCH-12-A FDD for Packaged Direct Expansion Units	Carrier SOGCM07; Carrier SOGCM07;		<input type="checkbox"/>	<input type="checkbox"/>
NRCA-MCH-16-A Supply Air Temperature Reset Controls	Carrier SOGCM07; Carrier SOGCM07;		<input type="checkbox"/>	<input type="checkbox"/>
NRCA-MCH-18-A Energy Management Control Systems	Carrier SOGCM07; Carrier SOGCM07;		<input type="checkbox"/>	<input type="checkbox"/>

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
Registration Date/Time: Report Version: 2019.1.003
Registration Provider: Energoft Schema Version: rev.20200601
Report Generated: 2022-12-09 16:07:50

ROOSEVELT ELEMENTARY SCHOOL
MODERNIZATION
2324 VERDE STREET
FOR
BAKERSFIELD CITY SCHOOL DISTRICT
BAKERSFIELD, KERN COUNTY, CALIFORNIA



1601 NEW STINE ROAD, SUITE 280
BAKERSFIELD, CA 93309
PH: (661) 397-4377
FAX: (661) 397-4378
WWW.SCARCHITECT.COM



CHECK AND VERIFY ALL DIMENSIONS BEFORE PROCEEDING WITH THE WORK. REPORT DISCREPANCIES TO THE ARCHITECT. ALL CONSTRUCTION SHALL CONFORM TO THE C.B.C.

BUILDING 'E'
TITLE-24

MARK	DATE	REVISIONS
△		
△		
△		

JOB NO. 1317
DRAWN: B.S.
CHECKED: M.B.
DATE: 8/5/21



IDENTIFICATION STAMP
 DIV. OF THE STATE ARCHITECT
 APP: 03-122920 INC:
 REVIEWED FOR
 SS FLS ACS
 DATE: 07/05/2023

PTN: 63321- FILE: 15-6

STATE OF CALIFORNIA
Mechanical Systems
 NRCC-MCH-E CALIFORNIA ENERGY COMMISSION

CERTIFICATE OF COMPLIANCE
 Project Name: Roosevelt Elementary HVAC Upgrades Bld E Report Page: (Page 10 of 11)
 Project Address: 2324 Verde Street Date Prepared: 12/9/2022

P. DECLARATION OF REQUIRED CERTIFICATES OF VERIFICATION
 There are no NRCV forms required for this project.

Q. MANDATORY MEASURES DOCUMENTATION LOCATION
 This table is used to indicate where mandatory measures are documented in the plan set or construction documentation.

Measure	Location
Compliance with Mandatory Measures documented through MCH Mandatory Measures Note Block	Yes M-Sheets

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
 Registration Date/Time: Report Version: 2019.1.003 Schema Version: rev 20200601
 Registration Provider: Energysoft
 Report Generated: 2022-12-09 16:07:50

STATE OF CALIFORNIA
Mechanical Systems
 NRCC-MCH-E CALIFORNIA ENERGY COMMISSION

CERTIFICATE OF COMPLIANCE
 Project Name: Roosevelt Elementary HVAC Upgrades Bld E Report Page: (Page 11 of 11)
 Project Address: 2324 Verde Street Date Prepared: 12/9/2022

DOCUMENTATION AUTHOR'S DECLARATION STATEMENT
 I certify that this Certificate of Compliance documentation is accurate and complete.

Documentation Author Name: Mark Baskin	Documentation Author Signature: Mark Baskin, P.E.
Company: Baskin Mechanical Engineers	Signature Date: 2022-12-09
Address: 175 Fulton St.	CAIA/HERO Certification Identification (if applicable): M26578
City/State/Zip: Fresno CA 93721	Phone: (559) 237-0376

RESPONSIBLE PERSON'S DECLARATION STATEMENT
 I certify the following under penalty of perjury, under the laws of the State of California:

- The information provided on this Certificate of Compliance is true and correct.
- I am eligible under Division 3 of the Business and Professions Code to accept responsibility for the building design or system design identified on this Certificate of Compliance (responsible designer).
- The energy features and performance specifications, materials, components, and manufactured devices for the building design or system design identified on this Certificate of Compliance conform to the requirements of Title 24, Part 1 and Part 6 of the California Code of Regulations.
- The building design features or system design features identified on this Certificate of Compliance are consistent with the information provided on other applicable compliance documents, worksheets, calculations, plans and specifications submitted to the enforcement agency for approval with this building permit application.
- I will ensure that a completed signed copy of this Certificate of Compliance shall be made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections. I understand that a completed signed copy of this Certificate of Compliance is required to be included with the documentation the builder provides to the building owner at occupancy.

Responsible Designer Name: Mark Baskin, P.E.	Responsible Designer Signature: Mark Baskin, P.E.
Company: Baskin Mechanical Engineers	Date Signed: 2022-12-09
Address: 175 Fulton	License: M26578
City/State/Zip: Fresno CA 93721	Phone: (559) 237-0376

Registration Number: CA Building Energy Efficiency Standards - 2019 Nonresidential Compliance
 Registration Date/Time: Report Version: 2019.1.003 Schema Version: rev 20200601
 Registration Provider: Energysoft
 Report Generated: 2022-12-09 16:07:50


ROOSEVELT ELEMENTARY SCHOOL
 MODERNIZATION
 2324 VERDE STREET
 FOR
 BAKERSFIELD CITY SCHOOL DISTRICT
 BAKERSFIELD, KERN COUNTY, CALIFORNIA



1601 NEW STINE ROAD, SUITE 280
 BAKERSFIELD, CA 93309
 PH: (661) 397-4377
 FAX: (661) 397-4378
 WWW.SCARCHITECT.COM

Stephen C. Carr
 LICENSED ARCHITECT
 No. M2867
 Exp. 8-30-24
 BAKERSFIELD, CALIFORNIA

CHECK AND VERIFY ALL DIMENSIONS BEFORE PROCEEDING WITH THE WORK. REPORT DISCREPANCIES TO THE ARCHITECT. ALL CONSTRUCTION SHALL CONFORM TO THE C.B.C.



BUILDING 'E'
TITLE-24

MARK	DATE	REVISIONS
△		
△		
△		

JOB NO.
1317
 DRAWN:
 B.S.
 CHECKED:
 M.B.
 DATE:
 8/5/21

M
7.7

bme BASKIN MECHANICAL ENGINEERS
 175 Fulton Street
 Fresno, CA 93721
 Tel: (559) 237-0376
 Job: 21146
 Plt: 12-13-22

