

Project: Restroom Building
Relocatable Classrooms at Myra A. Noble

Change Order No. 3
Job No. 976.3
File 15-6
Application: 03-104224
Date: February 11, 2004

Contractor: Bakersfield City School District
1501 Feliz Drive
Bakersfield, California 93307

ITEM	DESCRIPTION OF CHANGE	ADD	DEDUCT
9.	Refer to Drawings Sheet E1.0:		
a.	DELETE: All work to the Toilet Building	\$0.00	\$0.00
b.	ADD: All labor, materials and equipment as required for the relocatable Toilet Building as shown attached per Drawing #12.		
	REASON: District Request.		
10.	Refer to Drawings Sheet E2, Detail #2		
a.	REVISE: Feeder to the Toilet building Keynote #10 to 1½" C-3#2 + 1 #8 GND.	\$0.00	\$0.00
	REASON: District Request.		
11.	Refer to Drawings Sheet E3		
a.	DELETE: The lighting, power and signal plans work shown to the Toilet building including	\$0.00	\$0.00
b.	REVISE: FA voltage drop calculation to the relocatable toilet building alarm devices per attached drawing No. 12.		
	REASON: District Request.		
TOTAL ADDITIONS AND DEDUCTIONS			
TOTAL CHANGE IN CONTRACT PRICE		\$0.00	\$0.00
Original Contract Price		\$0.00	\$0.00
Change Order No. 1		\$ 0.00	\$ 0.00
ADJUSTED CONTRACT PRICE		\$0.00	\$ 0.00
CONFORMANCE WITH SPECIFICATIONS AND CONTRACT		\$0.00	\$ 0.00

All work performed under this Change Order shall be in conformance with the Specifications as they apply to work of a similar nature and shall be subject to the provisions of the contract for the above

SUBMITTED BY:

Bakersfield City School District

ACCEPTED BY:

Bakersfield City School District

By: _____

By: _____

Date: _____


Date: _____

SC ARCHITECT, INC.

By: _____

Stephen J. Corbin, NCARB AIA
Principal Architect

Date: _____



APPROVED
DIV. OF THE STATE ARCHITECT
LOS ANGELES BASIN REGIONAL OFFICE

AC NN F/L EV SS MC

APPL. NO. _____ DATE 1-27-05