

Mechanical Mandatory Measures

Equipment and Systems Efficiency

- Any appliance for which there is a California Standard established in the Appliance Efficiency Requirements with, or comply with, the applicable standards.
- Fan type central furnaces shall not have pilot lights.
- Piping, except that conveying fluids 105 degrees Fahrenheit, or within HVAC equipment, shall be insulated in accordance with Standards Section 123.
- Air handling duct systems shall be installed and insulated in compliance with Sections 601, 603 and 604 of the Uniform Mechanical Code.
- Each space conditioning system shall be installed with one of the following:
 - Each space conditioning system serving building types such as offices and manufacturing facilities (and all others not explicitly exempt from the requirements of section 122(d)) shall be installed with an automatic holdover switch with an override manual switch that allows operation of the system during off-hours for up to 4 hours. The time switch shall be capable of programming different schedules for weekdays and weekends, incorporate an automatic holdover feature that turns off all loads for at least 24 hours, then resumes the normally scheduled operation, and has program backup capabilities that prevent the loss of the device's program and time settings for at least 10 hours if power is interrupted; or
 - An occupancy sensor to control the operating period of the systems; or
 - A 4-hour timer that can be manually operated to control the operating period of the system.
- Each space conditioning system shall be installed with controls that temporarily restart and temporarily operate the system as required to maintain a setback heating and/or a setup cooling thermostat setpoint.
- Each space conditioning system serving multiple zones with combined conditioned floor area more than 25,000 square feet shall be provided with isolation zones. Each zone shall not exceed 25,000 square feet, shall be provided with square valves or dampers, that allow supply of heating or cooling to be setback or shut off independently of other isolation areas, and shall be controlled by a time control device as described above.
- Each space conditioning zone shall be controlled by an individual thermostatic control that responds to temperature within the zone. Where used to control heating, the control shall be adjustable down to 55 degrees or lower. For cooling, the control shall be adjustable up to 85 degrees or higher. Where used to control both heating and cooling, the control shall be capable of providing a dead band of at least 5 degrees within which the supply of heating and cooling is shut-off or reduced to a minimum.
- Thermostats shall have numeric setpoints in degrees Fahrenheit (F) and adjustable setpoint stops, accessible only to authorized personnel.
- Heat Pumps shall be installed with controls to prevent electric resistance supplementary heater operation when the heating load can be met by the heat pump alone.

Envelope Mandatory Measures

- §121(e)** Each space conditioning system serving building types such as offices and manufacturing facilities (and all others not explicitly exempt from the requirements of section 122(d)) shall be installed with an automatic holdover switch with an override manual switch that allows operation of the system during off-hours for up to 4 hours. The time switch shall be capable of programming different schedules for weekdays and weekends, incorporate an automatic holdover feature that turns off all loads for at least 24 hours, then resumes the normally scheduled operation, and has program backup capabilities that prevent the loss of the device's program and time settings for at least 10 hours if power is interrupted; or
- §122(f)** Each space conditioning system shall be installed with one of the following:
 - Air Balancing. The system shall be balanced in accordance with the National Environmental Balancing Bureau (NEBB) National Standards (1983), or ASHRAE National Standard (1986); or
 - Outside Air Certification: The system shall provide the minimum outside air as shown on the mechanical drawings and shall be measured and certified by the installing licensed C-20 Mechanical contractor and certified by (1) the design mechanical engineer, (2) the installing licensed C-20 mechanical contractor, or (3) the person with overall responsibility for the design of the ventilation system; or
 - Outside Air Measurement: The system shall be equipped with a calibrated local or remote device capable of measuring the quantity of outside air on a continuous basis and displaying that quantity on a ready accessible display; or
 - Another method approved by the Commission.
- §121(f)** Installed Insulating Material shall have been certified by the manufacturer to comply with California Quality Standards for Insulating material, Title 20 for §122(g)
- §118(c)** All Insulating Materials shall be installed in compliance with the flame spread rating and smoke density requirements of Sections 2002 and 707 of the Title 24, Part 2
- §119(a)** All Exterior Joints and openings in the building that are observable sources of air leakage shall be caulked, gasketed, weatherstripped or otherwise sealed.
- §116(b)** Manufactured Doors and Windows installed shall have air infiltration rates not exceeding those shown in Table Number 1-E, of standards, manufactured fenestration products must be labeled for U-value according to NRCC procedures.
- §122(c)** Demising Walls in Nonresidential Buildings. The opaque portions of the walls separating adjacent nonresidential buildings shall have insulation with an R-value of no less than R-11 between framing members.
- §118(e)** Manufactured Doors and Windows shall be caulked between the unit and the building, and shall be weatherstripped (except for unframed glass doors and fire doors).
- §117(a)** Site Constructed Doors, Windows, and Skylights shall be caulked between the unit and the building, and shall be weatherstripped (except for unframed glass doors and fire doors).
- §116(c)** All Exterior Joints and openings in the building that are observable sources of air leakage shall be caulked, gasketed, weatherstripped or otherwise sealed.
- §117(b)** Manufactured Doors and Windows installed shall have air infiltration rates not exceeding those shown in Table Number 1-E, of standards, manufactured fenestration products must be labeled for U-value according to NRCC procedures.

Mechanical Mandatory Measures – Cont.

Service Water Heating Systems

Ventilation

- Controls shall be provided to allow outside air dampers or devices to be operated at the ventilation rates as specified in these plans.
- Gravity or automatic dampers interlocked and closed on fan shutdown shall be provided on the outside air intakes and discharges of all space conditioning and exhaust systems.
- All gravity ventilating systems shall be provided with automatic or readily accessible manually operated dampers in all openings to the outside, except for combustion air openings.

- §113(b)** If a circulating hot water system is installed, it shall have a control capable of automatically turning off the hot water if not required.
- §115(b)** Lavatories in restrooms of public facilities shall be equipped with controls to limit the outlet temperature to 110°F.
- §113(b)** Lavatories in restrooms of public facilities shall be equipped within the following:
 - Outlet devices that limit the flow of hot water to a maximum of 0.5 gallons per minute.
 - Foot actuated control valves, and outlet devices that limit the flow of hot water to a maximum of 0.75 gallons per minute.
 - Proximity sensors actuated control valves, and outlet devices that limit the flow of hot water to a maximum of 0.75 gallons per minute.
 - Self-closing valves, and outlet devices that limit the flow of hot water to a maximum of 2.5 gallons per minute, and 0.25 gallons/cycle (circulating system).
 - Self-closing valves, and outlet devices that limit the flow of hot water to a maximum of 2.5 gallons per minute, and 0.50 gallons/cycle (non-circulating system).
- §113(b)** Self-closing valves, and outlet devices that limit the flow of hot water to a maximum of 2.5 gallons per minute, and 0.75 gallons/cycle (foot switches, and proximity sensor controls).
- §113(b)** Self-closing valves, and outlet devices that limit the flow of hot water to a maximum of 2.5 gallons per minute, and 0.75 gallons/cycle (foot switches, and proximity sensor controls).
- §113(b)** Tandem Wiring for One and Three Lamp Fluorescent Fixtures: All one and three lamp fluorescent fixtures are tandem wired with two lamp ballasts were required by Standards Section 132; or all three lamp fluorescents fixtures are specified with electronic high-frequency ballasts and are exempt from tandem wiring requirements.
- §113(b)** Individual Room/Area Controls: Each room and area in this building is equipped with a separate switch or occupancy sensor device for each area with floor-to-ceiling walls.
- §113(b)** Uniform Reduction for Individual Rooms Daylight Area Control: All rooms with windows and skylights, that are greater than 250 square feet per square foot of lighting, shall be controlled with Bi-level switching for uniform reduction of lighting within the room.
- §113(c)** Daylight Area Control: All rooms with windows and skylights, that are greater than 250 square feet per square foot of lighting, shall be controlled with Bi-level switching for uniform reduction of lighting within the room.
- §113(f)** Exterior mounted fixtures and served from the electrical panel inside the building are controlled with a directional photo cell control on the roof and a corresponding relay in the electrical panel.
- §113(f)** Exterior Lighting: Exterior mounted fixtures and served shall be separately switched on electrical circuits that are 20 amps or less.

Lighting Mandatory Measures

Service Water Heating Systems

- §131(d)** For every floor, all interior lighting systems shall be equipped with a separate automatic control to shut off the lighting. This automatic control shall meet the requirements of Section 119 and may be an occupancy sensor, automatic time switch or shutter device, capable of automatically shutting off the lighting. The area of override is not to exceed 5,000 square feet.
- §131(d)** **Override for Building Lighting Shut-Off** The automatic building shut-off system is provided with a manual, accessible override switch in sight of the lights.

- §131(d)** **Automatic control Devices Certified** All automatic devices specified for the project are certified and listed in the directory. All installed fixtures shall be certified, all alternate equipment shall be certified and installed as directed by the manufacturer.
- §132** **Fluorescent Ballast and Luminaries Certified** All fluorescent fixtures specified for the project are certified and listed in the directory. All installed fixtures shall be certified.
- §132** **Tandem Wiring for One and Three Lamp Fluorescent Fixtures**: All one and three lamp fluorescent fixtures are tandem wired with two lamp ballasts were required by Standards Section 132; or all three lamp fluorescents fixtures are specified with electronic high-frequency ballasts and are exempt from tandem wiring requirements.
- §132** **Individual Room/Area Controls**: Each room and area in this building is equipped with a separate switch or occupancy sensor device for each area with floor-to-ceiling walls.
- §132** **Uniform Reduction for Individual Rooms** Daylight Area Control: All rooms with windows and skylights, that are greater than 250 square feet per square foot of lighting, shall be controlled with Bi-level switching for uniform reduction of lighting within the room.
- §132** **Daylight Area Control**: All rooms with windows and skylights, that are greater than 250 square feet per square foot of lighting, shall be controlled with Bi-level switching for uniform reduction of lighting within the room.
- §131(f)** **Exterior mounted fixtures and served** from the electrical panel inside the building are controlled with a directional photo cell control on the roof and a corresponding relay in the electrical panel.
- §131(f)** **Exterior mounted fixtures and served** shall be separately switched on electrical circuits that are 20 amps or less.

AMERICAN MODULAR SYSTEMS INC.

787 Streckers Ave, Manteca, CA 95336

209-825-1921 Fax: (209)825-7018

americanmodular.com

ENERGY MANDATORY MEASURES

BASED ON PC-02-114-931

PROJECT No. M2

DATE: 07/01/2014

FLS: SS

AC: MC

DATE: 07/01/2014

FLS: SS