




BAKERSFIELD, CALIFORNIA

Sheet title: AIR CONDITIONING SCHEDULES

Sheet title:

[illegible]

Job no: 1223
Sheet:

M.5
Sheet of: 6

[illegible]

EXHAUST FAN SCHEDULE						
DESIGNATION	FE1	FE2	FE3	FE4	FE5	FE6
CFM	95	200	500	2,000	3,600	5,600
ESP (IN WC)	0.1	0.1	0.30	0.25	1.90	1.60
HP/MAITS	-/350	-/105	1/8/-	1/2/-	1 1/2/-	1/2/-
VOLTS/PHASE	120/1	120/1	120/1	120/1	208/3	208/3
HPM		1050	1079	1517	785	1,465
TYP. SPEED/SONES	-/1.3	-/2.4	3.107/4.3	5.351/11.0	5.035/8.7	6.701
DRIVE	DIRECT	DIRECT	DIRECT	DIRECT	BELT	BELT
MOUNTING	CEILING	CEILING	ROOF	ROOF	ROOF	ROOF
MANUFACTURER	TRANE	TRANE	TRANE	TRANE	TRANE	TRANE
TYPE	ZEMHR	ZEMHR	DOMEX	DOMEX	FUXER	UTILITY
MODEL NUMBER	FDH4010	FDH4020	FDH4010	FCR4135	FUR4300	CUB4135
CONTROL	①	①	SEE SPEC.	②	SEE SPEC.	SEE SPEC.
LOCATION	SEE PLANS	SEE PLANS	DISH WASH	MULTI-USE	KITCHEN	KITCHEN
OPER. WT (LBS)	20	25	40	50	230	200
ACCESSORIES	-	-	-	ACOUSTIC CURB	ACOUSTIC CURB	ACOUSTIC CURB

MAKE-UP AIR UNIT SCHEDULE	
DESIGNATION	8,000/5,330 6
HP/LOW	5
HP	460/5
VOLTS/PHASE	540/0
INPUT (MWH)	432.0
OUTPUT (MWH)	540.0
FUEL	NATURAL GAS
MANUFACTURER	8 TRANE
TYPE	HEAT/COOL
MODEL NUMBER	6/6N/C-CTD
LOCATION	KITCHEN
OPER WT (LBS)	7760
ACCESSORIES	16

① 12" CELECK EVAPORATIVE COOLER MODUL OUTSIDE AIR/RETURN AIR DAMPERS, FACTORY S.A. & R.A. PLENUM, & 2 SPEED FAN. SEE SPECS FOR ADDITIONAL INFORMATION.