



Bakersfield City School District
 Maintenance, Operations and Facilities Department
 1501 Feliz Drive
 Bakersfield, California 93307
 Office (661) 631-5883 Fax (661) 834-9986

Jason Sitton, Director I sittonj@bcسد.com
 Leonard Zasoski, Assistant Director II zasoskil@bcسد.com
 Daniel Wastafarro, Assistant Director II wastafarro@bcسد.com
 Juan Montelongo, Assistant Director II montelongoj@bcسد.com

May 03, 2024

To: All Bidders
 Re: Eissler – Bid Package 02 Fencing Rebid – Addendum No. 01

Questions & Answers:

1. Question: Please clarify climb resistant chain link fabric to be 1" 9 gauge Glass 1 Fabric.
 - Answer: Chain Link fabric for the climb resistance fence to be 9 gauge x 1".
2. Question: Is coring required at existing concrete walks?
 - Answer: Core for any post going into existing concrete walks.
3. Question: Please clarify backstops to be 10 ft high 3 rail.
 - Answer: All backstops to be 30' of 8' high 9 gage chain link with 1-5/8 with a top, middle and bottom rail.
4. Question: Please clarify if low bidder is based on base bid with or without alternate?
 - Answer: The contract will be awarded on the base bid only. The alternate is not to be included in the base bid.
5. Question: Please clarify the thickness of concrete curb of east property line where 6-7 inch above grade was discussed at job walk.
 - Answer: Concrete curb for the east property line fence is to be 12" wide x 7" above finish grade and 6" below finish grade.

Please date, sign and return this form via email to Brenda Orozco at orozcob@bcسد.com.

 Date Print Name Signature

 Print Company Name

Sincerely,

Leonard Zasoski
 Assistant Director II
 Maintenance, Operations and Facilities
 Bakersfield City School District