



Bakersfield City School District
Maintenance, Operations and Facilities Department
1501 Feliz Drive
Bakersfield, California 93307
Office (661) 631-5883 Fax (661) 834-9986

Jason Sitton, Director | sittonj@bcسد.com
Leonard Zasoski Jr., Assistant Director II | zasoskil@bcسد.com
Daniel Wastafarro, Assistant Director II | wastafarro@bcسد.com
Juan Montelongo, Assistant Director II | montelongoj@bcسد.com

February 26, 2026

To: All Bidders
Re: Frank West ES Asphalt Replacement Project– Addendum No. 02

Pre-Construction Job-Walk – BCSD Discussion / Contractor Questions:

1. Per BCSD the trash enclosure will be moved during the construction project for the demolition of AC paving and concrete and for the installation of the new concrete slab and paving.
2. Per BCSD fog sealing of the paving will be per the notes on the plans
3. Are there any other options for fog / slurry sealing?
 - BCSD Response: Slurry sealing of existing pavement will be per the specifications as listed on the scope of work.

Contractor Questions / RFI:

1. Cement treatment of the sub-grade material verses aggregate base as shown on the plans.
 - Districts Response: Aggregate base is to be installed per the plans and scope of work.

Please date, sign and return this form via email to Brenda Orozco at orozcob@bcسد.com.

Date Print Name Signature

Print Company Name

Sincerely,

Leonard Zasoski, Jr.
Assistant Director II
Maintenance, Operations and Facilities
Bakersfield City School District