

NOTE: DUCT MUST BE RAISED TO PROVIDE COLLAR CLEARANCE & REMAIN BELOW ROOF PURLINS

DIRECTION OF AIR FLOW IN DUCT

EXTRACTOR RECOMMENDED - 12 x 12 TO STRAIGHTEN AIR FLOW

10 GA. COLLAR
MIN. 3/4" SHEET ROCK
GYPSUM BOARD
VERIFY W/ FIRE MARSHALL
CLOSE TIGHT

FUSIBLE LINK

FIRE DAMPER - CALIF. STATE FIRE MARSHALL APPROVED TYPE
"AIR BALANCE" HORIZONTAL TYPE "A"

FIRE RATED CEILING

3/2" DROP

3 1/8"

3/4"

3 1/8"

DROP FRAME DIFFUSER CONTROL AIR RMD-DF.

APPROVED
STATE FIRE MARSHALL
STATE OF CALIFORNIA
DATE JUN 20 1966
BY *[Signature]*

STATE OF CALIFORNIA - DEPARTMENT OF GENERAL SERVICES
BUREAU OF ARCHITECTURE AND CONSTRUCTION

27755 APPROVED JUN 20 1966

APPLICATION No. *[Signature]* PER *[Signature]* PRINCIPAL STRUCTURAL ENGINEER



[Signature]

BAKERSFIELD CITY SCHOOL DISTRICT 1300 BAKER - BAKERSFIELD, CALIF. EDUCATION CENTER		JOB NO. 753
SCALE: NONE	APPROVED BY:	DRAWN BY L. A.
DATE: JUNE 20/66		REVISED
MOBILE RENTALS CORPORATION 400 NORTH LUCAS AVE. ST. MARYS, CALIF.		DRAWING NUMBER FD-1
FIRE DAMPER		