

**From:** [Lisa Lum](#)  
**To:** [Daniel Wastaferra](#)  
**Cc:** [Curtis Flynn](#); [Felipe Ceballos](#); [Sean Parker](#)  
**Subject:** RE: BCSD - Sigler HVAC - Revised Submittal  
**Date:** Friday, August 25, 2023 10:48:01 AM

---

Good Morning Daniel,

The review of revised submittal applies to equipment tags HP-1A, 4A, 7 to 12.  
Supplier addressed items from initial review dated August 17, 2023:

1. Weight of proposed Micrometl roof curb is 105 lbs. and is less than specified weight of 107 lbs.
2. MERV 13 filters are included.
3. Refrigerant line sets are included.

Therefore, the review comment is No Exceptions Taken.



**Lisa Lum, P.E.**  
**Mechanical Engineer**  
**Associate**  
**Integrated Designs by SOMAM, Inc.**  
6011 North Fresno Street, Suite 130  
Fresno, CA 93710  
**P:** 559-436-0881 **F:** 559-436-0887  
[llum@somam.com](mailto:llum@somam.com)  
[www.integrateddesigns.com](http://www.integrateddesigns.com)

---

**From:** Daniel Wastaferra <wastaferrrod@bcسد.com>  
**Sent:** Wednesday, August 23, 2023 11:20 AM  
**To:** Lisa Lum <llum@somam.com>  
**Cc:** Curtis Flynn <cflynn@somam.com>; Felipe Ceballos <fcebaldos@somam.com>; Sean Parker <sparker@somam.com>  
**Subject:** BCSD - Sigler HVAC - Revised Submittal

Hello Lisa,

Please find the link below to access/download the revised submittal provided by Sigler for the BCSD – HVAC Equipment Bid.

<http://mot.bcsd.com/Construction%20Consultants/HVAC%20Equipment/BCSD%20HVAC%20Equipment%20and%20Exhaust%20Fans%20-%20Sigler%20Submittal%20-%20Integrated%20Design.pdf>

Please let me know if you have any issue accessing the document.

Thank you,

**Daniel Wastaferra**  
Assistant Director II  
Maintenance, Operations & Facilities  
Bakersfield City School District  
 (661) 631-5883  (661) 834-9986  
[wastaferrrod@bcسد.com](mailto:wastaferrrod@bcسد.com)

