

LEGEND

NEW BUILDINGS MAY HAVE BEEN ADDED TO THIS SITE. SEE NEW SITES/NEW BUILDING TAB.

SISC

SAFETY & LOSS CONTROL

INSPECTION DATE	DRAWING NUMBER
02/27 - 03/29/2001	024COV

AHERA COMPLIANCE PROGRAM

060027-024
 BAKERSFIELD CITY SCHOOL DISTRICT
 MUNSEY ELEMENTARY SCHOOL
 SITE MAP

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
Building #: **001 - MULTIPURPOSE ROOM**
Inspection Dates: **02/27/2001 To 03/29/2001**
Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 001

Material Category: **MISCELLANEOUS** Location: **ON FLOOR UNDER TILE** Material Description: **MASTIC**
Damage Category: **ACBM WITH POTENTIAL FOR DAMAGE** Reason for Damage Category: **MATERIAL IN GOOD CONDITION** Potential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
ASSUMED		08/07/1995	JAY OLSEN				

Asbestos: **Y** Friable: **N** ACM Status: **Non-Friable Assumed**

MATERIAL QUANTITIES

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: **O&M MAINTAIN AND MONITOR** Priority: **3** Preventative Measures: **USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT, TRANSITE, TILE UNDERLAY & SCRATCH COATS**

Action Election: _____ Response Action Schedule
Start Date _____ Completion Date _____
Inspector's Comments: _____
=====

MATERIAL SHOULD BE SAMPLED PRIOR TO ABATEMENT TO VERIFY ASBESTOS CONTENT.

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
Building #: **001 - MULTIPURPOSE ROOM**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 002

Material Category: **MISCELLANEOUS** Location: **THROUGHOUT EXCEPT STAGE** Material Description: **VINYL FLOOR TILE**

Damage Category: **ACBM WITH POTENTIAL FOR DAMAGE** Reason for Damage Category: **MATERIAL IN GOOD CONDITION** Potential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61276	10	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **Y** Friable: **N** ACM Status: **Non-Friable ACBM**

MATERIAL QUANTITIES

4,520 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: **O&M MAINTAIN AND MONITOR** Priority: **3** Preventative Measures: **USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT, TRANSITE, TILE UNDERLAY & SCRATCH COATS**

Action Election: _____ Response Action Schedule
Start Date _____ Completion Date _____
Inspector's Comments: _____

9 X 9 DARK BROWN W/RED & WHITE UNDER NEW 1 X 1 WHITE TILE EXCEPT AT E & W EXITS ON STAGE.

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
 Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
 Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
 Building #: **001 - MULTIPURPOSE ROOM**
 Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
 Certification#: **3023**
 State: **CA**
 Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 003

Material Category: **MISCELLANEOUS** Location: **TEACHER'S DINING ROOM** Material Description: **LINOLEUM**

Damage Category: **ACBM WITH POTENTIAL FOR DAMAGE** Reason for Damage Category: **MATERIAL IN GOOD CONDITION** Potential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61281	45	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **Y** Friable: **N** ACM Status: **Non-Friable ACBM**

MATERIAL QUANTITIES

50 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: **O&M MAINTAIN AND MONITOR** Priority: **3** Preventative Measures: **USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT, TRANSITE, TILE UNDERLAY & SCRATCH COATS**

Action Election: _____ Response Action Schedule

Start Date	Completion Date
=====	=====

Inspector's Comments: **UNDER NEW 12 X 12 VINYL FLOOR TILE.**

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
 Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
 Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
 Building #: **001 - MULTIPURPOSE ROOM**
 Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
 Certification#: **3023**
 State: **CA**
 Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 004

Material Category: **MISCELLANEOUS** Location: **KITCHEN** Material Description: **VINYL FLOOR TILE**

Damage Category: **ACBM WITH POTENTIAL FOR DAMAGE** Reason for Damage Category: **MATERIAL IN GOOD CONDITION** Potential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61290	10	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **Y** Friable: **N** ACM Status: **Non-Friable ACBM**

MATERIAL QUANTITIES

980 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: **O&M MAINTAIN AND MONITOR** Priority: **3** Preventative Measures: **USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT, TRANSITE, TILE UNDERLAY & SCRATCH COATS**

Action Election: _____ Response Action Schedule

Start Date	Completion Date
=====	=====

Inspector's Comments:
12 X 12 TAN W/BROWN & WHITE

SISO AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
Building #: **001 - MULTIPURPOSE ROOM**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 005

Material Category: **SURFACING MATERIALS** Location: **KITCHEN/PANRY/RESTROOMS** Material Description: **HARDWALL/CEILING PLASTER**

Damage Category: **N/A** Reason for Damage Category: Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61282	0	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

4,600 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:

Action Election:

Response Action Schedule

Start Date Completion Date

Inspector's Comments:

SISC - AHERA COMPLIANCE PROGRAM

County: KERN
Project #: 060027 - BAKERSFIELD CITY SCHOOL DISTRICT
Campus #: 024 - MILLIE GARDETTE MUNSEY SCHOOL
Building #: 001 - MULTIPURPOSE ROOM
Inspection Dates: 02/27/2001 To 03/29/2001

Inspected by: HAL GOUNDER
Certification#: 3023
State: CA
Gross Square Ft: 0

INSPECTION RESULTS UNIFIED SAMPLING AREA - 006

Material Category: MISCELLANEOUS
Location: MPR/BKSTAGE HALLS/TEACHRS DINING
Material Description: ACOUSTICAL TILE (1X1)

Damage Category: N/A
Reason for Damage Category:
Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61285	0	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: N Friable: N/A ACM Status: No Suspect Material

MATERIAL QUANTITIES

4,120 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:

Action Election:

Response Action Schedule

Start Date Completion Date

Inspector's Comments:

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
 Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
 Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
 Building #: **001 - MULTIPURPOSE ROOM**
 Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
 Certification#: **3023**
 State: **CA**
 Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 007

Material Category: **MISCELLANEOUS** Location: **KITCHEN** Material Description: **ACOUSTICAL TILE (1X1)**

Damage Category: **N/A** Reason for Damage Category: Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61291	0	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

980 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
 Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
 Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
 Building #: **001 - MULTIPURPOSE ROOM**
 Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
 Certification#: **3023**
 State: **CA**
 Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 008

Material Category:
SURFACING MATERIALS

Location:
**THROUGHOUT EXCEPT
 KITCHEN/STORAGE
 /PANTRY/RESTROOMS**

Material Description:
HARDWALL/CEILING PLASTER

Damage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61306	0	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

8,220 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:


Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:



LEGEND

NON-ASBESTOS VINYL FLOOR TILE

NON-ASBESTOS CEILING TILES

NON-ASBESTOS SPRAY / TROWEL APPLIED MATERIAL

ASBESTOS CONTAINING VINYL FLOOR TILE

ASBESTOS CONTAINING CEILING TILES

ASBESTOS CONTAINING SPRAY / TROWEL APPLIED MATERIAL

SISC

SAFETY & LOSS CONTROL

INSPECTION DATE
02/27 - 03/29/2001

DRAWING NUMBER
024001

AHERA COMPLIANCE PROGRAM

060027-024-001
BAKERSFIELD CITY SCHOOL DISTRICT
MUNSEY ELEMENTARY SCHOOL
MPR

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
 Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
 Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
 Building #: **002 - OFFICE/RESTROOMS**
 Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
 Certification#: **3023**
 State: **CA**
 Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 001

Material Category:
MISCELLANEOUS

Location:
ON FLOOR UNDER TILE

Material Description:
MASTIC

Damage Category:
ACBM WITH POTENTIAL FOR DAMAGE

Reason for Damage Category:
MATERIAL IN GOOD CONDITION

Potential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
ASSUMED		08/07/1995	JAY OLSEN				

Asbestos: **Y** Friable: **N** ACM Status: **Non-Friable Assumed**

MATERIAL QUANTITIES

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: **O&M MAINTAIN AND MONITOR** Priority: **3** Preventative Measures: **USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT, TRANSITE, TILE UNDERLAY & SCRATCH COATS**

Action Election: _____ Response Action Schedule

Start Date	Completion Date
=====	=====

Inspector's Comments:
MATERIAL SHOULD BE SAMPLED PRIOR TO ABATEMENT TO VERIFY ASBESTOS CONTENT.

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
Building #: **002 - OFFICE/RESTROOMS**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 002

Material Category:
MISCELLANEOUS

Location:
PRINCIPAL'S RESTROOM

Material Description:
LINOLEUM

Damage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61326	0	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

10 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:

Action Election:

Response Action Schedule

Start Date Completion Date

Inspector's Comments:

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
Building #: **002 - OFFICE/RESTROOMS**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 003

Material Category: **SURFACING MATERIALS** Location: **RESTROOMS** Material Description: **HARDWALL/CEILING PLASTER**

Damage Category: **N/A** Reason for Damage Category: Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61330	0	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

975 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
 Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
 Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
 Building #: **002 - OFFICE/RESTROOMS**
 Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
 Certification#: **3023**
 State: **CA**
 Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 005

Material Category:
SURFACING MATERIALS

Location:
BOOKROOM

Material Description:
HARDWALL/CEILING PLASTER

Damage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61339	0	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

620 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
Building #: **002 - OFFICE/RESTROOMS**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

***** INSPECTION RESULTS UNIFIED SAMPLING AREA - 006 *****

Material Category:
MISCELLANEOUS

Location:
MAIN OFFICE

Material Description:
LINOLEUM

Damage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61342	0	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

10 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:

Action Election:

Response Action Schedule

Start Date Completion Date

Inspector's Comments:

COUNTER TOP(?)

SISC - AHERA COMPLIANCE PROGRAM

County: KERN
Project #: 060027 - BAKERSFIELD CITY SCHOOL DISTRICT
Campus #: 024 - MILLIE GARDETTE MUNSEY SCHOOL
Building #: 002 - OFFICE/RESTROOMS
Inspection Dates: 02/27/2001 To 03/29/2001
Inspected by: HAL GOUNDER
Certification#: 3023
State: CA
Gross Square Ft: 0

INSPECTION RESULTS UNIFIED SAMPLING AREA - 007

Material Category: MISCELLANEOUS
Location: MAIN OFFICE/WORKROOM/DITTO ROOM
Material Description: LINOLEUM

Damage Category: N/A
Reason for Damage Category:
Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61348	0	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: N Friable: N/A ACM Status: No Suspect Material

MATERIAL QUANTITIES

200 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:

Action Election:

Response Action Schedule

Start Date Completion Date

Inspector's Comments:

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
Building #: **002 - OFFICE/RESTROOMS**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 008

Material Category: **MISCELLANEOUS** Location: **THROUGHOUT EXCEPT RESTROOMS/BOOKRM** Material Description: **ACOUSTICAL TILE (1X1)**

Damage Category: **N/A** Reason for Damage Category: Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61350	0	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

1,900 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:

Action Election:

Response Action Schedule

Start Date Completion Date

Inspector's Comments:

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
 Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
 Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
 Building #: **002 - OFFICE/RESTROOMS**
 Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
 Certification#: **3023**
 State: **CA**
 Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 009

Material Category:
MISCELLANEOUS

Location:
THROUGHOUT MAIN OFFICE

Material Description:
VINYL FLOOR TILE

Damage Category:
N/A

Reason for Damage Category:

Potential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
ASSUMED		08/02/1995	JAY OLSEN				

Asbestos: **Y** Friable: **N** ACM Status: **Non-Friable Assumed**

MATERIAL QUANTITIES

2,350 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: **O&M MAINTAIN AND MONITOR** Priority: **3** Preventative Measures:

Action Election:

Response Action Schedule


Start Date

Completion Date

Inspector's Comments:

9 X 9 DARK BROWN W/RED & WHITE UNDER NEW 1 X 1 WHITE SPECKLED VINYL FLOOR TILE.

TO KINDERGARTEN
BUILDING 003



LEGEND

NON-ASBESTOS
VINYL FLOOR TILE

NON-ASBESTOS
CEILING TILES

NON-ASBESTOS
SPRAY / TROWEL
APPLIED MATERIAL

ASBESTOS
CONTAINING
VINYL FLOOR TILE

ASBESTOS
CONTAINING
CEILING TILES

ASBESTOS
CONTAINING
SPRAY / TROWEL
APPLIED MATERIAL

SISC

SAFETY & LOSS CONTROL

INSPECTION
DATE
02/27 - 03/29/2001

DRAWING
NUMBER
024002

**AHERA
COMPLIANCE PROGRAM**

060027-024-002
BAKERSFIELD CITY SCHOOL DISTRICT
MUNSEY ELEMENTARY SCHOOL
OFFICE / RESTROOMS

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
 Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
 Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
 Building #: **003 - KINDERGARTEN**
 Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
 Certification#: **3023**
 State: **CA**
 Gross Square Ft: **0**

***** INSPECTION RESULTS UNIFIED SAMPLING AREA - 001 *****

Material Category: **MISCELLANEOUS** Location: **ON FLOOR UNDER TILE** Material Description: **MASTIC**

Damage Category: **ACBM WITH POTENTIAL FOR DAMAGE** Reason for Damage Category: **MATERIAL IN GOOD CONDITION** Potential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
ASSUMED		08/07/1995	JAY OLSEN				

Asbestos: **Y** Friable: **N** ACM Status: **Non-Friable Assumed**

MATERIAL QUANTITIES

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: **O&M MAINTAIN AND MONITOR** Priority: **3** Preventative Measures: **USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT, TRANSITE, TILE UNDERLAY & SCRATCH COATS**

Action Election: _____ Response Action Schedule

Start Date	Completion Date
=====	=====

Inspector's Comments: **MATERIAL SHOULD BE SAMPLED PRIOR TO ABATEMENT TO VERIFY ASBESTOS CONTENT.**

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
Building #: **003 - KINDERGARTEN**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

***** INSPECTION RESULTS UNIFIED SAMPLING AREA - 002 *****

Material Category: **MISCELLANEOUS** Location: **CLASSROOMS/STORAGE** Material Description: **LINOLEUM**

Damage Category: **N/A** Reason for Damage Category: Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61317	0	12/09/1988	CTL ENVIRONMENTAL	61340	0	12/09/1988	CTL ENVIRONMENTAL

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

150 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
Building #: **003 - KINDERGARTEN**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 003

Material Category: **MISCELLANEOUS** Location: **THROUGHOUT EXCEPT RESTROOMS** Material Description: **ACOUSTICAL TILE (1X1)**

Damage Category: **N/A** Reason for Damage Category: Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61324	0	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

2,800 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:

Action Election:

Response Action Schedule

Start Date Completion Date

Inspector's Comments:

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
Building #: **003 - KINDERGARTEN**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

***** INSPECTION RESULTS UNIFIED SAMPLING AREA - 004 *****

Material Category: **SURFACING MATERIALS** Location: **RESTROOMS** Material Description: **HARDWALL/CEILING PLASTER**

Damage Category: **N/A** Reason for Damage Category: Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61325	0	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

2,000 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:

Action Election:

Response Action Schedule

Start Date Completion Date

Inspector's Comments:

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
 Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
 Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
 Building #: **003 - KINDERGARTEN**
 Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
 Certification#: **3023**
 State: **CA**
 Gross Square Ft: **0**

***** INSPECTION RESULTS UNIFIED SAMPLING AREA - 005 *****

Material Category: **MISCELLANEOUS** Location: **THROUGHOUT** Material Description: **VINYL FLOOR TILE**

Damage Category: **N/A** Reason for Damage Category: Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61321	20	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **Y** Friable: **N** ACM Status: **Non-Friable ACBM**

MATERIAL QUANTITIES

3,200 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:

Action Election:


Response Action Schedule

 Start Date Completion Date

Inspector's Comments:

9 X 9 DARK BROWN W/RED & WHITE UNDER 1 X 1 WHITE SPECKLED TILE.

NEW TILE OVER OLD 9 X 9 TILE



LEGEND

NON-ASBESTOS VINYL FLOOR TILE

NON-ASBESTOS CEILING TILES

NON-ASBESTOS SPRAY / TROWEL APPLIED MATERIAL

ASBESTOS CONTAINING VINYL FLOOR TILE

ASBESTOS CONTAINING CEILING TILES

ASBESTOS CONTAINING SPRAY / TROWEL APPLIED MATERIAL

SISC
SAFETY & LOSS CONTROL

INSPECTION DATE
02/27 - 03/29/2001

DRAWING NUMBER
024003

AHERA
COMPLIANCE PROGRAM

060027-024-003
BAKERSFIELD CITY SCHOOL DISTRICT
MUNSEY ELEMENTARY SCHOOL
KINDERGARTEN

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
Building #: **004 - CLASSROOMS 5-9**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 001

Material Category: **MISCELLANEOUS** Location: **ROOM 9** Material Description: **LINOLEUM**

Damage Category: **ACBM WITH POTENTIAL FOR DAMAGE** Reason for Damage Category: **MATERIAL IN GOOD CONDITION** Potential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61232	20	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **Y** Friable: **N** ACM Status: **Non-Friable ACBM**

MATERIAL QUANTITIES

15 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: **O&M MAINTAIN AND MONITOR** Priority: **3** Preventative Measures: **USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT, TRANSITE, TILE UNDERLAY & SCRATCH COATS**

Action Election: _____ Response Action Schedule

Start Date	Completion Date
=====	=====

Inspector's Comments: _____

SISC AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
Building #: **004 - CLASSROOMS 5-9**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 002

Material Category: **MISCELLANEOUS** Location: **ON FLOOR UNDER TILE** Material Description: **MASTIC**

Damage Category: **ACBM WITH POTENTIAL FOR DAMAGE** Reason for Damage Category: **MATERIAL IN GOOD CONDITION** Potential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
ASSUMED		08/07/1995	JAY OLSEN				

Asbestos: **Y** Friable: **N** ACM Status: **Non-Friable Assumed**

MATERIAL QUANTITIES

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: **O&M MAINTAIN AND MONITOR** Priority: **3** Preventative Measures: **USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT, TRANSITE, TILE UNDERLAY & SCRATCH COATS**

Action Election: _____ Response Action Schedule

Start Date	Completion Date
=====	=====

Inspector's Comments: **MATERIAL SHOULD BE SAMPLED PRIOR TO ABATEMENT TO VERIFY ASBESTOS CONTENT.**

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
Building #: **004 - CLASSROOMS 5-9**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 003

Material Category:
MISCELLANEOUS

Location:
CUSTODIAN

Material Description:
VINYL FLOOR TILE

Damage Category:
ACBM WITH POTENTIAL FOR DAMAGE

Reason for Damage Category:
MATERIAL IN GOOD CONDITION

Potential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61287	5	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **Y** Friable: **N** ACM Status: **Non-Friable ACBM**

MATERIAL QUANTITIES

150 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

O&M MAINTAIN AND MONITOR

Priority:

3

Preventative Measures:

USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT, TRANSITE, TILE UNDERLAY & SCRATCH COATS

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

12 X 12 WHITE W/GOLD & GRAY

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
Building #: **004 - CLASSROOMS 5-9**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 004

Material Category: **MISCELLANEOUS** Location: **CLASSROOMS** Material Description: **VINYL FLOOR TILE**

Damage Category: **ACBM WITH POTENTIAL FOR DAMAGE** Reason for Damage Category: **MATERIAL IN GOOD CONDITION** Potential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61315	10	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **Y** Friable: **N** ACM Status: **Non-Friable ACBM**

MATERIAL QUANTITIES

4,825 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: **O&M MAINTAIN AND MONITOR** Priority: **3** Preventative Measures: **USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT, TRANSITE, TILE UNDERLAY & SCRATCH COATS**

Action Election: _____ Response Action Schedule
Start Date _____ Completion Date _____
Inspector's Comments: _____

9 X 9 DARK BROWN W/RED & WHITE UNDER WHITE 12X12 VINYL FLOOR TILE AND CARPET.

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
 Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
 Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
 Building #: **004 - CLASSROOMS 5-9**
 Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
 Certification#: **3023**
 State: **CA**
 Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 005

Material Category: **MISCELLANEOUS** Location: **BOILER ROOM** Material Description: **TRANSITE PIPE**

Damage Category: **ACBM WITH POTENTIAL FOR DAMAGE** Reason for Damage Category: **MATERIAL IN GOOD CONDITION** Potential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
ASSUMED		12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **Y** Friable: **N** ACM Status: **Non-Friable Assumed**

MATERIAL QUANTITIES

30 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: **O&M MAINTAIN AND MONITOR** Priority: **3** Preventative Measures: **USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT, TRANSITE, TILE UNDERLAY & SCRATCH COATS**

Action Election:

Response Action Schedule	
Start Date	Completion Date
=====	=====

Inspector's Comments:

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
Building #: **004 - CLASSROOMS 5-9**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 006

Material Category: **MISCELLANEOUS** Location: **CLASSROOMS** Material Description: **LINOLEUM**

Damage Category: **N/A** Reason for Damage Category: Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61258	0	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

400 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**

Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**

Inspected by: **HAL GOUNDER**

Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**

Certification#: **3023**

Building #: **004 - CLASSROOMS 5-9**

State: **CA**

Inspection Dates: **02/27/2001 To 03/29/2001**

Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 007

Material Category:
MISCELLANEOUS

Location:
CLASSROOMS

Material Description:
ACOUSTICAL TILE (1X1)

Damage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61260	0	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

4,825 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**

Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**

Inspected by: **HAL GOUNDER**

Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**

Certification#: **3023**

Building #: **004 - CLASSROOMS 5-9**

State: **CA**

Inspection Dates: **02/27/2001 To 03/29/2001**

Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 008

Material Category:
SURFACING MATERIALS

Location:
CUSTODIAN/BOILER ROOM

Material Description:
HARDWALL/CEILING PLASTER

Damage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61318	0	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

1,600 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

Priority:

Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
Building #: **004 - CLASSROOMS 5-9**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 009

Material Category: **MISCELLANEOUS** Location: **ROOMS 6 & 7** Material Description: **LINOLEUM**

Damage Category: **N/A** Reason for Damage Category: Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61319	0	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

30 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
Building #: **004 - CLASSROOMS 5-9**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 010

Material Category: **SURFACING MATERIALS** Location: **RESTROOMS** Material Description: **HARDWALL/CEILING PLASTER**

Damage Category: **N/A** Reason for Damage Category: Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61341	0	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

950 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:


Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:



LEGEND

NON-ASBESTOS VINYL FLOOR TILE

NON-ASBESTOS CEILING TILES

NON-ASBESTOS SPRAY / TROWEL APPLIED MATERIAL

ASBESTOS CONTAINING VINYL FLOOR TILE

ASBESTOS CONTAINING CEILING TILES

ASBESTOS CONTAINING SPRAY / TROWEL APPLIED MATERIAL

SISC
SAFETY & LOSS CONTROL

INSPECTION DATE
02/27 - 03/29/2001

DRAWING NUMBER
024004

AHERA
COMPLIANCE PROGRAM

060027-024-004
BAKERSFIELD CITY SCHOOL DISTRICT
MUNSEY ELEMENTARY SCHOOL
CLASSROOMS 5-9

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
 Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
 Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
 Building #: **005 - CLASSROOMS 10-14**
 Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
 Certification#: **3023**
 State: **CA**
 Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 001

Material Category: **MISCELLANEOUS** Location: **ROOM 11B** Material Description: **LINOLEUM**

Damage Category: **ACBM WITH POTENTIAL FOR DAMAGE** Reason for Damage Category: **MATERIAL IN GOOD CONDITION** Potential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61313	20	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **Y** Friable: **N** ACM Status: **Non-Friable ACBM**

MATERIAL QUANTITIES

120 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: **O&M MAINTAIN AND MONITOR** Priority: **3** Preventative Measures: **USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT, TRANSITE, TILE UNDERLAY & SCRATCH COATS**

Action Election: _____ Response Action Schedule

Start Date	Completion Date
=====	=====

Inspector's Comments: **COUNTER TOP**

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
 Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
 Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
 Building #: **005 - CLASSROOMS 10-14**
 Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
 Certification#: **3023**
 State: **CA**
 Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 002

Material Category: **MISCELLANEOUS** Location: **ON FLOOR UNDER TILE** Material Description: **MASTIC**

Damage Category: **ACBM WITH POTENTIAL FOR DAMAGE** Reason for Damage Category: **MATERIAL IN GOOD CONDITION** Potential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
ASSUMED		08/07/1995	JAY OLSEN				

Asbestos: **Y** Friable: **N** ACM Status: **Non-Friable Assumed**

MATERIAL QUANTITIES

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: **O&M MAINTAIN AND MONITOR** Priority: **3** Preventative Measures: **USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT, TRANSITE, TILE UNDERLAY & SCRATCH COATS**

Action Election: _____ Response Action Schedule

Start Date	Completion Date
=====	=====

Inspector's Comments: **MATERIAL SHOULD BE SAMPLED PRIOR TO ABATEMENT TO VERIFY ASBETOS CONTENT.**

SISC AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
Building #: **005 - CLASSROOMS 10-14**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA 003

Material Category: **MISCELLANEOUS** Location: **THROUGHOUT EXCEPT RESTROOMS** Material Description: **VINYL FLOOR TILE**

Damage Category: **ACBM WITH POTENTIAL FOR DAMAGE** Reason for Damage Category: **MATERIAL IN GOOD CONDITION** Potential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61338	10	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **Y** Friable: **N** ACM Status: **Non-Friable ACBM**

MATERIAL QUANTITIES

5,510 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: **O&M MAINTAIN AND MONITOR** Priority: **3** Preventative Measures: **USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT, TRANSITE, TILE UNDERLAY & SCRATCH COATS**

Action Election: _____ Response Action Schedule
Start Date _____ Completion Date _____
Inspector's Comments: _____

9 X 9 DARK BROWN W/RED & WHITE UNDER WHITE 12X12 VINYL FLOOR TILE AND CARPET.

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
Building #: **005 - CLASSROOMS 10-14**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA 004

Material Category: **MISCELLANEOUS** Location: **ROOM 10** Material Description: **LINOLEUM**

Damage Category: **N/A** Reason for Damage Category: Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61323	0	12/09/1988	CTL ENVIRONMENTAL	61328	0	12/09/1988	CTL ENVIRONMENTAL

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

120 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

COUNTER TOP

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**

Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**

Inspected by: **HAL GOUNDER**

Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**

Certification#: **3023**

Building #: **005 - CLASSROOMS 10-14**

State: **CA**

Inspection Dates: **02/27/2001 To 03/29/2001**

Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 005

Material Category:
SURFACING MATERIALS

Location:
RESTROOMS/STOREROOM

Material Description:
HARDWALL/CEILING PLASTER

Damage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61344	0	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

1,900 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
 Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
 Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
 Building #: **005 - CLASSROOMS 10-14**
 Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
 Certification#: **3023**
 State: **CA**
 Gross Square Ft: **0**

***** INSPECTION RESULTS UNIFIED SAMPLING AREA - 006 *****

Material Category: **MISCELLANEOUS** Location: **CLASSROOMS/TEACHER'S LOUNGE** Material Description: **ACOUSTICAL TILE (1X1)**

Damage Category: **N/A** Reason for Damage Category: Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61359	0	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

5,320 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
Building #: **005 - CLASSROOMS 10-14**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

***** INSPECTION RESULTS UNIFIED SAMPLING AREA - 007 *****

Material Category: **MISCELLANEOUS** Location: **ROOM 13** Material Description: **LINOLEUM**

Damage Category: **N/A** Reason for Damage Category: Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61327	0	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

240 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:

Action Election:


Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

COUNTERTOPS



LEGEND

NON-ASBESTOS VINYL FLOOR TILE

NON-ASBESTOS CEILING TILES

NON-ASBESTOS SPRAY / TROWEL APPLIED MATERIAL

ASBESTOS CONTAINING VINYL FLOOR TILE

ASBESTOS CONTAINING CEILING TILES

ASBESTOS CONTAINING SPRAY / TROWEL APPLIED MATERIAL

SISC

SAFETY & LOSS CONTROL

INSPECTION DATE 02/27 - 03/29/2001
DRAWING NUMBER 024005

AHERA COMPLIANCE PROGRAM

060027-024-005
BAKERSFIELD CITY SCHOOL DISTRICT
MUNSEY ELEMENTARY SCHOOL
CLASSROOMS 10-14

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
Building #: **006 - CLASSROOMS 15-19**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

***** INSPECTION RESULTS UNIFIED SAMPLING AREA - 001 *****

Material Category:
MISCELLANEOUS

Location:
ON FLOOR UNDER TILE

Material Description:
MASTIC

Damage Category:
ACBM WITH POTENTIAL FOR DAMAGE

Reason for Damage Category:
MATERIAL IN GOOD CONDITION

Potential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
ASSUMED		08/07/1995	JAY OLSEN				

Asbestos: **Y** Friable: **N** ACM Status: **Non-Friable Assumed**

MATERIAL QUANTITIES

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: **O&M MAINTAIN AND MONITOR** Priority: **3** Preventative Measures: **USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT, TRANSITE, TILE UNDERLAY & SCRATCH COATS**

Action Election: Response Action Schedule
Start Date Completion Date

Inspector's Comments:
MATERIAL SHOULD BE SAMPLED PRIOR TO ABATEMENT TO VERIFY ASBESTOS CONTENT.

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**

Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**

Inspected by: **HAL GOUNDER**

Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**

Certification#: **3023**

Building #: **006 - CLASSROOMS 15-19**

State: **CA**

Inspection Dates: **02/27/2001 To 03/29/2001**

Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 002

Material Category:
MISCELLANEOUS

Location:
CLASSROOMS/BOOKROOM

Material Description:
VINYL FLOOR TILE

Damage Category:
ACBM WITH POTENTIAL FOR DAMAGE

Reason for Damage Category:
MATERIAL IN GOOD CONDITION

Potential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61336	10	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **Y** Friable: **N** ACM Status: **Non-Friable ACBM**

MATERIAL QUANTITIES

5,200 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

Priority:

Preventative Measures:

O&M MAINTAIN AND MONITOR

3

USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT, TRANSITE, TILE UNDERLAY & SCRATCH COATS

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

9 X 9 DARK BROWN W/RED & WHITE / BELOW CARPET AND WHITE VINYL FLOOR TILE.

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
 Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
 Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
 Building #: **006 - CLASSROOMS 15-19**
 Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
 Certification#: **3023**
 State: **CA**
 Gross Square Ft: **0**

***** INSPECTION RESULTS UNIFIED SAMPLING AREA - 004 *****

Material Category: **SURFACING MATERIALS** Location: **RESTROOMS/BALLROOM** Material Description: **HARDWALL/CEILING PLASTER**

Damage Category: **N/A** Reason for Damage Category: Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61331	0	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

1,400 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
 Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
 Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
 Building #: **006 - CLASSROOMS 15-19**
 Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
 Certification#: **3023**
 State: **CA**
 Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA 005

Material Category: **MISCELLANEOUS** Location: **CLASSROOMS** Material Description: **LINOLEUM**

Damage Category: **N/A** Reason for Damage Category: Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61335	0	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

400 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
Building #: **006 - CLASSROOMS 15-19**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

***** INSPECTION RESULTS UNIFIED SAMPLING AREA - 006 *****

Material Category: **MISCELLANEOUS** Location: **CLASSROOMS** Material Description: **ACOUSTICAL TILE (1X1)**

Damage Category: **N/A** Reason for Damage Category: Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61337	0	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

5,000 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
Building #: **006 - CLASSROOMS 15-19**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

***** INSPECTION RESULTS UNIFIED SAMPLING AREA - 007 *****

Material Category: **SURFACING MATERIALS** Location: **STORAGE/BOOKROOM** Material Description: **HARDWALL/CEILING PLASTER**

Damage Category: **N/A** Reason for Damage Category: Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61345	0	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

1,550 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:


Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:



LEGEND

NON-ASBESTOS VINYL FLOOR TILE

NON-ASBESTOS CEILING TILES

NON-ASBESTOS SPRAY / TROWEL APPLIED MATERIAL

ASBESTOS CONTAINING VINYL FLOOR TILE

ASBESTOS CONTAINING CEILING TILES

ASBESTOS CONTAINING SPRAY / TROWEL APPLIED MATERIAL

SISC SAFETY & LOSS CONTROL

INSPECTION DATE
02/27 - 03/29/2001

DRAWING NUMBER
024006

AHERA COMPLIANCE PROGRAM

060027-024-006
BAKERSFIELD CITY SCHOOL DISTRICT
MUNSEY ELEMENTARY SCHOOL
CLASSROOMS 15-19

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
Building #: **007 - ROOM T-1**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 001

Material Category: **MISCELLANEOUS** Location: **ON FLOOR UNDER TILE** Material Description: **MASTIC**

Damage Category: **ACBM WITH POTENTIAL FOR DAMAGE** Reason for Damage Category: **MATERIAL IN GOOD CONDITION** Potential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
ASSUMED		08/07/1995	JAY OLSEN				

Asbestos: **Y** Friable: **N** ACM Status: **Non-Friable Assumed**

MATERIAL QUANTITIES

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: **O&M MAINTAIN AND MONITOR** Priority: **3** Preventative Measures: **USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT, TRANSITE, TILE UNDERLAY & SCRATCH COATS**

Action Election: _____ Response Action Schedule
Start Date _____ Completion Date _____
Inspector's Comments: _____
=====

MATERIAL SHOULD BE SAMPLED PRIOR TO ABATEMENT TO VERIFY ASBESTOS CONTENT.

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
Building #: **007 - ROOM T-1**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 002

Material Category: **MISCELLANEOUS** Location: **THROUGHOUT** Material Description: **VINYL FLOOR TILE**

Damage Category: **ACBM WITH POTENTIAL FOR DAMAGE** Reason for Damage Category: **MATERIAL IN GOOD CONDITION** Potential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61322	5	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **Y** Friable: **N** ACM Status: **Non-Friable ACBM**

MATERIAL QUANTITIES

960 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: **O&M MAINTAIN AND MONITOR** Priority: **3** Preventative Measures: **USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT, TRANSITE, TILE UNDERLAY & SCRATCH COATS**

Action Election: _____ Response Action Schedule

Start Date	Completion Date
=====	=====

Inspector's Comments:
9 X9 GREEN W/WHITE / UNDER 12 X12 WHITE

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
Building #: **007 - ROOM T-1**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

***** INSPECTION RESULTS UNIFIED SAMPLING AREA - 003 *****

Material Category: **MISCELLANEOUS** Location: **THROUGHOUT** Material Description: **ACOUSTICAL TILE (1X1)**

Damage Category: **N/A** Reason for Damage Category: Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61346	0	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

960 SQ FEET

MANAGEMENT PLAN RECOMMENDATION


Recommended Response Action: Priority: Preventative Measures:

Action Election:

Response Action Schedule

Inspector's Comments:

Start Date Completion Date



LEGEND

NON-ASBESTOS
VINYL FLOOR TILE

NON-ASBESTOS
CEILING TILES

NON-ASBESTOS
SPRAY / TROWEL
APPLIED MATERIAL

ASBESTOS
CONTAINING
VINYL FLOOR TILE

ASBESTOS
CONTAINING
CEILING TILES

ASBESTOS
CONTAINING
SPRAY / TROWEL
APPLIED MATERIAL

SISC
SAFETY & LOSS CONTROL

INSPECTION
DATE
02/27 - 03/29/2001

DRAWING
NUMBER
024007

**AHERA
COMPLIANCE PROGRAM**

060027-024-007
BAKERSFIELD CITY SCHOOL DISTRICT
MUNSEY ELEMENTARY SCHOOL
T-1

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
Building #: **008 - ROOM T-2**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 001

Material Category: **MISCELLANEOUS** Location: **THROUGHOUT** Material Description: **ACOUSTICAL TILE (1X1)**

Damage Category: **N/A** Reason for Damage Category: Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61347	0	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

960 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:

Action Election:

Response Action Schedule

Start Date Completion Date

Inspector's Comments:

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
 Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
 Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
 Building #: **008 - ROOM T-2**
 Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
 Certification#: **3023**
 State: **CA**
 Gross Square Ft: **912**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 002

Material Category: **MISCELLANEOUS** Location: **THROUGHOUT** Material Description: **VINYL FLOOR TILE**

Damage Category: **ACBM WITH POTENTIAL FOR DAMAGE** Reason for Damage Category: **GOOD CONDITION** Potential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
ASSUMED		03/13/2001	HAL GOUNDER				

Asbestos: **Y** Friable: **N** ACM Status: **Non-Friable Assumed**

MATERIAL QUANTITIES

MANAGEMENT PLAN RECOMMENDATION


Recommended Response Action: **O&M MAINTAIN AND MONITOR** Priority: **3** Preventative Measures: **USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT, TRANSITE, TILE UNDERLAY & SCRATCH COATS**

Action Election: _____ Response Action Schedule

Start Date	Completion Date
=====	=====



Inspector's Comments: **9X9 VINYL FLOOR TILE.**

BS 12
61347



BS 04
ASSUMED

LEGEND



SISC
SAFETY & LOSS CONTROL

INSPECTION DATE
02/27 - 03/29/2001

DRAWING NUMBER
024008

AHERA
COMPLIANCE PROGRAM

060027-024-008
BAKERSFIELD CITY SCHOOL DISTRICT
MUNSEY ELEMENTARY SCHOOL
T2

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
Building #: **009 - RSP**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **504**

***** INSPECTION RESULTS UNIFIED SAMPLING AREA - 001 *****

Material Category: **MISCELLANEOUS** Location: **THROUGHOUT** Material Description: **ACOUSTICAL TILE (1X1)**

Damage Category: **N/A** Reason for Damage Category: Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61349	0	12/09/1988	CTL ENVIRONMENTAL				



Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

520 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:

Action Election:


Response Action Schedule

Start Date Completion Date


Inspector's Comments:

S/N S0756

BS 12
61349



LEGEND



SISC

SAFETY & LOSS CONTROL

INSPECTION
DATE

02/27 - 03/29/2001

DRAWING
NUMBER

024009

**AHERA
COMPLIANCE PROGRAM**

060027-024-009
BAKERSFIELD CITY SCHOOL DISTRICT
MUNSEY ELEMENTARY SCHOOL
RSP

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
Building #: **010 - CLASSROOMS 21-25**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 001

Material Category: **MISCELLANEOUS** Location: **ON FLOOR UNDER TILE** Material Description: **MASTIC**

Damage Category: **ACBM WITH POTENTIAL FOR DAMAGE** Reason for Damage Category: **MATERIAL IN GOOD CONDITION** Potential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
=====	=====	=====	=====	=====	=====	=====	=====
ASSUMED		08/07/1995	JAY OLSEN				

Asbestos: **Y** Friable: **N** ACM Status: **Non-Friable Assumed**

MATERIAL QUANTITIES

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: **O&M MAINTAIN AND MONITOR** Priority: **3** Preventative Measures: **USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT, TRANSITE, TILE UNDERLAY & SCRATCH COATS**

Action Election:

Response Action Schedule	
Start Date	Completion Date
=====	=====

Inspector's Comments:
MATERIAL SHOULD BE SAMPLED PRIOR TO ABATEMENT TO VERIFY ASBESTOS CONTENT.

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**

Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**

Inspected by: **HAL GOUNDER**

Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**

Certification#: **3023**

Building #: **010 - CLASSROOMS 21-25**

State: **CA**

Inspection Dates: **02/27/2001 To 03/29/2001**

Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 002

Material Category:
MISCELLANEOUS

Location:
ROOMS 21-25

Material Description:
VINYL FLOOR TILE

Damage Category:
ACBM WITH POTENTIAL FOR DAMAGE

Reason for Damage Category:
MATERIAL IN GOOD CONDITION

Potential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61316	5	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **Y** Friable: **N** ACM Status: **Non-Friable ACBM**

MATERIAL QUANTITIES

4,800 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

9 X9 TAN W/DARK BROWN & WHITE;1 X 1 WHITE UNDER 12X12 WHITE AND CARPET.

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**

Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**

Inspected by: **HAL GOUNDER**

Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**

Certification#: **3023**

Building #: **010 - CLASSROOMS 21-25**

State: **CA**

Inspection Dates: **02/27/2001 To 03/29/2001**

Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 004

Material Category:
MISCELLANEOUS

Location:
CLASSROOMS

Material Description:
LINOLEUM

Damage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61279	0	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

400 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

BROWN

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
 Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
 Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
 Building #: **010 - CLASSROOMS 21-25**
 Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
 Certification#: **3023**
 State: **CA**
 Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 005

Material Category: **MISCELLANEOUS** Location: **THROUGHOUT** Material Description: **ACOUSTICAL TILE (1X1)**

Damage Category: **N/A** Reason for Damage Category: Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61351	0	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

4,800 SQ FEET

MANAGEMENT PLAN RECOMMENDATION


Recommended Response Action: Priority: Preventative Measures:

Action Election:

Response Action Schedule







 Start Date Completion Date

Inspector's Comments:



NOTE: SERIES OF 5 CONNECTED PORTABLE CLASSROOMS BUILT 1957.

LEGEND

-  NON-ASBESTOS VINYL FLOOR TILE
-  NON-ASBESTOS CEILING TILES
-  NON-ASBESTOS SPRAY / TROWEL APPLIED MATERIAL
-  ASBESTOS CONTAINING VINYL FLOOR TILE
-  ASBESTOS CONTAINING CEILING TILES
-  ASBESTOS CONTAINING SPRAY / TROWEL APPLIED MATERIAL

SISC
SAFETY & LOSS CONTROL

INSPECTION DATE
02/27 - 03/29/2001

DRAWING NUMBER
024010

AHERA
COMPLIANCE PROGRAM

060027-024-010
BAKERSFIELD CITY SCHOOL DISTRICT
MUNSEY ELEMENTARY SCHOOL
CLASSROOMS 21-25

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
 Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
 Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
 Building #: **012 - ROOM 3**
 Inspection Dates: **03/21/2003 To 03/21/2003**

Inspected by: **HAL GOUNDER**
 Certification#: **3023**
 State: **CA**
 Gross Square Ft: **960**

***** INSPECTION RESULTS UNIFIED SAMPLING AREA - 001 *****

Material Category: **MISCELLANEOUS** Location: **THROUGHOUT** Material Description: **DROP OR LAY-IN PANEL**

Damage Category: **N/A** Reason for Damage Category: Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
MGM12-1A	0	03/21/2003	HAL GOUNDER				
MGM12-1B	0	03/21/2003	HAL GOUNDER				
MGM12-1C	0	03/21/2003	HAL GOUNDER				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

960 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:


Action Election:

Response Action Schedule

 Start Date Completion Date

Inspector's Comments:

THREE TYPES OF 2X4 DROP OR LAY-IN PANELS



LEGEND

NON-ASBESTOS
VINYL FLOOR TILE

NON-ASBESTOS
CEILING TILES

NON-ASBESTOS
SPRAY / TROWEL
APPLIED MATERIAL

ASBESTOS
CONTAINING
VINYL FLOOR TILE

ASBESTOS
CONTAINING
CEILING TILES

ASBESTOS
CONTAINING
SPRAY / TROWEL
APPLIED MATERIAL

SISC

SAFETY & LOSS CONTROL

INSPECTION
DATE
02/27 - 03/29/2001

DRAWING
NUMBER
024012

**AHERA
COMPLIANCE PROGRAM**

060027-024-012
BAKERSFIELD CITY SCHOOL DISTRICT
MUNSEY ELEMENTARY SCHOOL
ROOM 3

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
 Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
 Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
 Building #: **013 - ENTIRE CAMPUS**
 Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
 Certification#: **3023**
 State: **CA**
 Gross Square Ft: **0**

***** INSPECTION RESULTS UNIFIED SAMPLING AREA - 002 *****

Material Category: **SURFACING MATERIALS** Location: **EXTERIOR WALLS** Material Description: **STUCCO, PLASTER**

Damage Category: **N/A** Reason for Damage Category: Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61284	0	12/09/1988	CTL ENVIRONMENTAL	61753	0	12/09/1988	CTL ENVIRONMENTAL
61754	0	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

15,527 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:

Action Election:

Response Action Schedule

 Start Date

 Completion Date

Inspector's Comments:

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
 Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
 Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
 Building #: **013 - ENTIRE CAMPUS**
 Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
 Certification#: **3023**
 State: **CA**
 Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 003

Material Category: **SURFACING MATERIALS** Location: **EXYERIOR WALKWAYS** Material Description: **STUCCO, PLASTER**

Damage Category: **N/A** Reason for Damage Category: Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61329	0	12/09/1988	CTL ENVIRONMENTAL	61270	0	12/09/1988	CTL ENVIRONMENTAL
61355	0	12/09/1988	CTL ENVIRONMENTAL	61320	0	12/09/1988	CTL ENVIRONMENTAL
61353	0	12/09/1988	CTL ENVIRONMENTAL	61755	0	12/09/1988	CTL ENVIRONMENTAL
61756	0	12/09/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

11,706 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
Building #: **014 - ROOM 4**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

***** INSPECTION RESULTS UNIFIED SAMPLING AREA - 001 *****

Material Category: **MISCELLANEOUS** Location: Material Description: **NO SUSPECT MATERIAL**

Damage Category: **N/A** Reason for Damage Category: Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
=====	=====	=====	=====	=====	=====	=====	=====

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

CA87-43-S-202152 & 53 SEE DISTRICT DESIGNATED PERSON FOR SPECIFIC INFORMATION ON ASBESTOS FOR THIS BUILDING.




NO SUSPECT MATERIAL


LEGEND



NON-ASBESTOS
VINYL FLOOR TILE




NON-ASBESTOS
CEILING TILES




NON-ASBESTOS
SPRAY / TROWEL
APPLIED MATERIAL



ASBESTOS
CONTAINING
VINYL FLOOR TILE



ASBESTOS
CONTAINING
CEILING TILES



ASBESTOS
CONTAINING
SPRAY / TROWEL
APPLIED MATERIAL

SISC

SAFETY & LOSS CONTROL

INSPECTION
DATE
02/27 - 03/29/2001

DRAWING
NUMBER
024014

**AHERA
COMPLIANCE PROGRAM**

060027-024-014
BAKERSFIELD CITY SCHOOL DISTRICT
MUNSEY ELEMENTARY SCHOOL
ROOM 4

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
Building #: **015 - ROOM T-4**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

***** INSPECTION RESULTS UNIFIED SAMPLING AREA - 001 *****

Material Category: **MISCELLANEOUS** Location: Material Description: **NO SUSPECT MATERIAL**

Damage Category: **N/A** Reason for Damage Category: Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
=====	=====	=====	=====	=====	=====	=====	=====

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:


Action Election:

Response Action Schedule

Start Date Completion Date


Inspector's Comments:

CA90-43-S-2005122 & 23 SEE DISTRICT DESIGNATED PERSON FOR SPECIFIC INFORMATION ON ASBESTOS FOR THIS BUILDING.



NO SUSPECT MATERIAL

LEGEND



SISC
SAFETY & LOSS CONTROL

INSPECTION DATE
02/27 - 03/29/2001

DRAWING NUMBER
024015

AHERA
COMPLIANCE PROGRAM

060027-024-015
BAKERSFIELD CITY SCHOOL DISTRICT
MUNSEY ELEMENTARY SCHOOL
ROOM T-4

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
Building #: **016 - ROOM T-5**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 001

Material Category: **MISCELLANEOUS** Location: Material Description: **NO SUSPECT MATERIAL**

Damage Category: **N/A** Reason for Damage Category: Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
=====	=====	=====	=====	=====	=====	=====	=====

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:

Action Election:

Response Action Schedule

Start Date	Completion Date
=====	=====


Inspector's Comments:

SMC-02005-045 & 046 SEE DISTRICT DESIGNATED PERSON FOR SPECIFIC INFORMATION ON ASBESTOS FOR THIS BUILDING.

(

(


(




NO SUSPECT MATERIAL

LEGEND

 NON-ASBESTOS VINYL FLOOR TILE

 NON-ASBESTOS CEILING TILES

 NON-ASBESTOS SPRAY / TROWEL APPLIED MATERIAL

 ASBESTOS CONTAINING VINYL FLOOR TILE

 ASBESTOS CONTAINING CEILING TILES

 ASBESTOS CONTAINING SPRAY / TROWEL APPLIED MATERIAL

SISC

SAFETY & LOSS CONTROL

INSPECTION DATE
02/27 - 03/29/2001

DRAWING NUMBER
024016

AHERA COMPLIANCE PROGRAM

060027-024-016
BAKERSFIELD CITY SCHOOL DISTRICT
MUNSEY ELEMENTARY SCHOOL
ROOM T-5

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
Building #: **017 - ROOM T-6**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 001

Material Category: **MISCELLANEOUS** Location: Material Description: **NO SUSPECT MATERIAL**

Damage Category: **N/A** Reason for Damage Category: Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
=====	=====	=====	=====	=====	=====	=====	=====

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:


Action Election:

Response Action Schedule

Start Date Completion Date


Inspector's Comments:


SMC-00202 491 & 492 SEE DISTRICT DESIGNATED PERSON FOR SPECIFIC INFORMATION ON ASBESTOS FOR THIS BUILDING.



NO SUSPECT MATERIAL

LEGEND


 NON-ASBESTOS VINYL FLOOR TILE

 NON-ASBESTOS CEILING TILES

 NON-ASBESTOS SPRAY / TROWEL APPLIED MATERIAL

 ASBESTOS CONTAINING VINYL FLOOR TILE

 ASBESTOS CONTAINING CEILING TILES

 ASBESTOS CONTAINING SPRAY / TROWEL APPLIED MATERIAL


SISC
SAFETY & LOSS CONTROL

INSPECTION DATE
02/27 - 03/29/2001

DRAWING NUMBER
024017


AHERA
COMPLIANCE PROGRAM

060027-024-017
BAKERSFIELD CITY SCHOOL DISTRICT
MUNSEY ELEMENTARY SCHOOL
ROOM T-6



NO SUSPECT MATERIAL

LEGEND




NON-ASBESTOS VINYL FLOOR TILE



NON-ASBESTOS CEILING TILES



NON-ASBESTOS SPRAY / TROWEL APPLIED MATERIAL



ASBESTOS CONTAINING VINYL FLOOR TILE



ASBESTOS CONTAINING CEILING TILES



ASBESTOS CONTAINING SPRAY / TROWEL APPLIED MATERIAL

SISC

SAFETY & LOSS CONTROL

INSPECTION DATE

02/27 - 03/29/2001

DRAWING NUMBER

024018


AHERA COMPLIANCE PROGRAM

060027-024-018
BAKERSFIELD CITY SCHOOL DISTRICT
MUNSEY ELEMENTARY SCHOOL
ROOM T-7

(

(

(




NO SUSPECT MATERIAL


LEGEND



NON-ASBESTOS VINYL FLOOR TILE



NON-ASBESTOS CEILING TILES



NON-ASBESTOS SPRAY / TROWEL APPLIED MATERIAL



ASBESTOS CONTAINING VINYL FLOOR TILE



ASBESTOS CONTAINING CEILING TILES



ASBESTOS CONTAINING SPRAY / TROWEL APPLIED MATERIAL

SISC

SAFETY & LOSS CONTROL

INSPECTION DATE
02/27 - 03/29/2001

DRAWING NUMBER
024019

AHERA COMPLIANCE PROGRAM

060027-024-019
BAKERSFIELD CITY SCHOOL DISTRICT
MUNSEY ELEMENTARY SCHOOL
ROOM T-8

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
Building #: **020 - ROOM T9**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **960**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 001

Material Category: **MISCELLANEOUS** Location: **CLASSROOM** Material Description: **OTHER-SEE COMMENTS**

Damage Category: **N/A** Reason for Damage Category: Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
=====	=====	=====	=====	=====	=====	=====	=====

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:

Action Election:

Response Action Schedule

Start Date Completion Date


Inspector's Comments:

SN 19830 & 31 SEE DISTRICT DESIGNATED PERSON FOR SPECIFIC INFORMATION ON ASBESTOS FOR THIS BUILDING.

(

(

(



LEGEND

NON-ASBESTOS
VINYL FLOOR TILE

NON-ASBESTOS
CEILING TILES

NON-ASBESTOS
SPRAY / TROWEL
APPLIED MATERIAL

ASBESTOS
CONTAINING
VINYL FLOOR TILE

ASBESTOS
CONTAINING
CEILING TILES

ASBESTOS
CONTAINING
SPRAY / TROWEL
APPLIED MATERIAL

SISC
SAFETY & LOSS CONTROL

INSPECTION
DATE
02/27 - 03/29/2001

DRAWING
NUMBER
024020

AHERA
COMPLIANCE PROGRAM

060027-024-020
BAKERSFIELD CITY SCHOOL DISTRICT
MUNSEY ELEMENTARY SCHOOL
ROOM T-9

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**

Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**

Inspected by: **HAL GOUNDER**

Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**

Certification#: **3023**

Building #: **021 - ROOM T-10**

State: **CA**

Inspection Dates: **02/27/2001 To 03/29/2001**

Gross Square Ft: **960**

***** INSPECTION RESULTS UNIFIED SAMPLING AREA - 001 *****

Material Category:
MISCELLANEOUS

Location:
CLASSROOM

Material Description:
OTHER-SEE COMMENTS

Damage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
=====	=====	=====	=====	=====	=====	=====	=====

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:

Action Election:

Response Action Schedule

Start Date Completion Date


Inspector's Comments:

CA90-43-S-2005033&34 SEE DISTRICT DESIGNATED PERSON FOR SPECIFIC INFORMATION ON ASBESTOS FOR THIS BUILDING.

(

(


(




LEGEND



NON-ASBESTOS
VINYL FLOOR TILE



NON-ASBESTOS
CEILING TILES



NON-ASBESTOS
SPRAY / TROWEL
APPLIED MATERIAL



ASBESTOS
CONTAINING
VINYL FLOOR TILE



ASBESTOS
CONTAINING
CEILING TILES



ASBESTOS
CONTAINING
SPRAY / TROWEL
APPLIED MATERIAL

SISC

SAFETY & LOSS CONTROL

INSPECTION
DATE
02/27 - 03/29/2001

DRAWING
NUMBER
024021

**AHERA
COMPLIANCE PROGRAM**

060027-024-021
BAKERSFIELD CITY SCHOOL DISTRICT
MUNSEY ELEMENTARY SCHOOL
ROOM T-10

SISO - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **024 - MILLIE GARDETTE MUNSEY SCHOOL**
Building #: **022 - ROOM T-11**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **960**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 001

Material Category: **MISCELLANEOUS** Location: **CLASSROOM** Material Description: **OTHER-SEE COMMENTS**

Damage Category: **N/A** Reason for Damage Category: Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
=====	=====	=====	=====	=====	=====	=====	=====

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: Priority: Preventative Measures:


Action Election:

Response Action Schedule

Start Date Completion Date


Inspector's Comments:


CA90-43-S-2005027 & 28 SEE DISTRICT DESIGNATED PERSON FOR SPECIFIC INFORMATION ON ASBESTOS FOR THIS BUILDING.




LEGEND

 NON-ASBESTOS VINYL FLOOR TILE

 NON-ASBESTOS CEILING TILES

 NON-ASBESTOS SPRAY / TROWEL APPLIED MATERIAL

 ASBESTOS CONTAINING VINYL FLOOR TILE

 ASBESTOS CONTAINING CEILING TILES

 ASBESTOS CONTAINING SPRAY / TROWEL APPLIED MATERIAL

SISC
SAFETY & LOSS CONTROL

INSPECTION DATE
02/27 - 03/29/2001

DRAWING NUMBER
024022

AHERA
COMPLIANCE PROGRAM

060027-024-022
BAKERSFIELD CITY SCHOOL DISTRICT
MUNSEY ELEMENTARY SCHOOL
ROOM T-11