


()



LEGEND	NEW BUILDINGS MAY HAVE BEEN ADDED TO THIS SITE. SEE NEW SITES/NEW BUILDING TAB.	SISC		AHERA	
		SAFETY & LOSS CONTROL		COMPLIANCE PROGRAM	
		INSPECTION DATE	DRAWING NUMBER	060027-031	
		02/27 - 03/29/2001	031COV	BAKERSFIELD CITY SCHOOL DISTRICT ROOSEVELT SCHOOL SITE MAP	

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
 Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
 Campus #: **031 - ROOSEVELT SCHOOL**
 Building #: **001 - MULTIPURPOSE RM/OFFICES**
 Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
 Certification#: **3023**
 State: **CA**
 Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 001

Material Category:
MISCELLANEOUS

Location:
KITCHEN

Material Description:
LINOLEUM

Damage Category:
ACBM WITH POTENTIAL FOR DAMAGE

Reason for Damage Category:
MATERIAL IN GOOD CONDITION

Potential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61373	35	12/16/1988	CTL ENVIRONMENTAL				

ABATED

Asbestos: **Y** Friable: **N** ACM Status: **Non-Friable ACBM**

MATERIAL QUANTITIES

200 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

O&M MAINTAIN AND MONITOR

Priority:

3

Preventative Measures:

USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT, TRANSITE, TILE UNDERLAY & SCRATCH COATS

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

WHITE/GOLD/BEIGE WALLCOVERING

SISC - AHERA COMPLIANCE PROGRAM

County: KERN
 Project #: 060027 - BAKERSFIELD CITY SCHOOL DISTRICT
 Campus #: 031 - ROOSEVELT SCHOOL
 Building #: 001 - MULTIPURPOSE RM/OFFICES
 Inspection Dates: 02/27/2001 To 03/29/2001

Inspected by: HAL GOUNDER
 Certification#: 3023
 State: CA
 Gross Square Ft: 0

*** INSPECTION RESULTS UNIFIED SAMPLING AREA - 002 ***

Material Category:
 MISCELLANEOUS

Location:
 SUPPLY/KITCHEN

Material Description:
 VINYL FLOOR TILE

Damage Category:
 ACBM WITH POTENTIAL FOR DAMAGE

Reason for Damage Category:
 MATERIAL IN GOOD CONDITION

Potential for Disturbance: SLIGHT

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61490	10	12/16/1988	CTL ENVIRONMENTAL				

ABATED

Asbestos: Y Friable: N ACM Status: Non-Friable ACBM

MATERIAL QUANTITIES

995 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

O&M MAINTAIN AND MONITOR

Priority:

3

Preventative Measures:

USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT, TRANSITE, TILE UNDERLAY & SCRATCH COATS

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

9 X 9 TAN W/BROWN

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **031 - ROOSEVELT SCHOOL**
Building #: **001 - MULTIPURPOSE RM/OFFICES**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 003

Material Category:
MISCELLANEOUS

Location:
LIBRARY

Material Description:
VINYL FLOOR TILE

Damage Category:
ACBM WITH POTENTIAL FOR DAMAGE

Reason for Damage Category:
MATERIAL IN GOOD CONDITION

Potential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61516	5	12/16/1988	CTL ENVIRONMENTAL				

Asbestos: **Y** Friable: **N** ACM Status: **Non-Friable ACBM**

MATERIAL QUANTITIES

1,102 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

O&M MAINTAIN AND MONITOR

Priority:

3

Preventative Measures:

**USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT,
TRANSITE, TILE UNDERLAY & SCRATCH COATS**

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

9 X 9 TAN/BROWN UNDER CARPET

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **031 - ROOSEVELT SCHOOL**
Building #: **001 - MULTIPURPOSE RM/OFFICES**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

***** INSPECTION RESULTS UNIFIED SAMPLING AREA - 004 *****

Material Category:
MISCELLANEOUS

Location:
ON FLOOR UNDER TILE

Material Description:
MASTIC

Damage Category:
ACBM WITH POTENTIAL FOR DAMAGE

Reason for Damage Category:
MATERIAL IN GOOD CONDITION

Potential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
=====	=====	=====	=====	=====	=====	=====	=====
ASSUMED		08/07/1995	JAY OLSEN				

Asbestos: **Y** Friable: **N** ACM Status: **Non-Friable Assumed**

MATERIAL QUANTITIES**MANAGEMENT PLAN RECOMMENDATION**

Recommended Response Action:

O&M MAINTAIN AND MONITOR

Priority:

3

Preventative Measures:

**USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT,
TRANSITE, TILE UNDERLAY & SCRATCH COATS**

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

**MATERIAL SHOULD BE SAMPLED PRIOR TO ABATEMENT TO VERIFY
ASBESTOS CONTENT.**

SISC - AHERA COMPLIANCE PROGRAM

County: KERN
 Project #: 060027 - BAKERSFIELD CITY SCHOOL DISTRICT
 Campus #: 031 - ROOSEVELT SCHOOL
 Building #: 001 - MULTIPURPOSE RM/OFFICES
 Inspection Dates: 02/27/2001 To 03/29/2001

Inspected by: HAL GOUNDER
 Certification#: 3023
 State: CA
 Gross Square Ft: 0

INSPECTION RESULTS UNIFIED SAMPLING AREA - 005

Material Category:
 MISCELLANEOUS

Location:
 PANTRY

Material Description:
 VINYL FLOOR TILE

Damage Category:
 ACBM WITH POTENTIAL FOR DAMAGE

Reason for Damage Category:
 MATERIAL IN GOOD CONDITION

Potential for Disturbance: SLIGHT

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61521	10	12/16/1988	CTL ENVIRONMENTAL				

ABATED

Asbestos: Y Friable: N ACM Status: Non-Friable ACBM

MATERIAL QUANTITIES

80 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

O&M MAINTAIN AND MONITOR

Priority:

3

Preventative Measures:

USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT, TRANSITE, TILE UNDERLAY & SCRATCH COATS

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

9 X 9 DARK GREEN W/WHITE

SISC - AHERA COMPLIANCE PROGRAM

County: KERN
 Project #: 060027 - BAKERSFIELD CITY SCHOOL DISTRICT
 Campus #: 031 - ROOSEVELT SCHOOL
 Building #: 001 - MULTIPURPOSE RM/OFFICES
 Inspection Dates: 02/27/2001 To 03/29/2001

Inspected by: HAL GOUNDER
 Certification#: 3023
 State: CA
 Gross Square Ft: 0

INSPECTION RESULTS UNIFIED SAMPLING AREA - 006

Material Category:
 THERMAL SYSTEM INSULATION

Location:
 STAGE LOFTS

Material Description:
 INTERIOR DUCT INSULATION

Damage Category:
 ACBM WITH POTENTIAL FOR DAMAGE

Reason for Damage Category:
 MATERIAL IN GOOD CONDITION

Potential for Disturbance: SLIGHT

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
ASSUMED		12/14/1988	CTL ENVIRONMENTAL				

Asbestos: Y Friable: N ACM Status: Non-Friable Assumed

MATERIAL QUANTITIES

1,050 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

Priority:

Preventative Measures:

O&M MAINTAIN AND MONITOR

3

FOR USE W/INSULATION ON BOILERS, BREECH, DUCTS, ETC

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

HVAC SUPPLY, RECTANGULAR DUCT WRAP

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
 Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
 Campus #: **031 - ROOSEVELT SCHOOL**
 Building #: **001 - MULTIPURPOSE RM/OFFICES**
 Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
 Certification#: **3023**
 State: **CA**
 Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 007

Material Category:
THERMAL SYSTEM INSULATION

Location:
MULTIPURPOSE ROOM

Material Description:
EXTERIOR DUCT INSULATION

Damage Category:
ACBM WITH POTENTIAL FOR DAMAGE

Reason for Damage Category:
MATERIAL IN GOOD CONDITION

Potential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
=====	=====	=====	=====	=====	=====	=====	=====
ASSUMED		12/14/1988	CTL ENVIRONMENTAL				

Asbestos: **Y** Friable: **N** ACM Status: **Non-Friable Assumed**

MATERIAL QUANTITIES

1,521 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

Priority:

Preventative Measures:

O&M MAINTAIN AND MONITOR

3

FOR USE W/INSULATION ON BOILERS, BREECH, DUCTS, ETC

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

RECTANGULAR DUCT

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **031 - ROOSEVELT SCHOOL**
Building #: **001 - MULTIPURPOSE RM/OFFICES**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

***** INSPECTION RESULTS UNIFIED SAMPLING AREA - 008 *****

Material Category:
THERMAL SYSTEM INSULATION

Location:
KITCHEN, ATTIC

Material Description:
PIPE COVERING

Damage Category:
ACBM WITH POTENTIAL FOR DAMAGE

Reason for Damage Category:
MATERIAL IN FAIR CONDITION

Potential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
=====	=====	=====	=====	=====	=====	=====	=====
ASSUMED		12/14/1988	CTL ENVIRONMENTAL				

ABAT 20

Asbestos: **Y** Friable: **Y** ACM Status: **Friable Assumed**

MATERIAL QUANTITIES

75 LINEAR FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action: **O&M MAINTAIN AND MONITOR** Priority: **3** Preventative Measures: **FOR USE W/PIPE INSULATION & MUDDED JOINT FITTINGS**

Action Election:

Response Action Schedule

Start Date Completion Date

Inspector's Comments:

**CANVAS JACKET IS COMPLETELY GONE. THE EXPOSED INSULATION
SHOULD BE ENCAPSULATED OR ABATED.**

SISC - AHERA COMPLIANCE PROGRAM

County: KERN
 Project #: 060027 - BAKERSFIELD CITY SCHOOL DISTRICT
 Campus #: 031 - ROOSEVELT SCHOOL
 Building #: 001 - MULTIPURPOSE RM/OFFICES
 Inspection Dates: 02/27/2001 To 03/29/2001

Inspected by: HAL GOUNDER
 Certification#: 3023
 State: CA
 Gross Square Ft: 0

INSPECTION RESULTS UNIFIED SAMPLING AREA - 009

Material Category:
 MISCELLANEOUS

Location:
 HW CLOSET

Material Description:
 TRANSITE PIPE

Damage Category:
 ACBM WITH POTENTIAL FOR DAMAGE

Reason for Damage Category:
 MATERIAL IN GOOD CONDITION

Potential for Disturbance: SLIGHT

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
=====	=====	=====	=====	=====	=====	=====	=====
ASSUMED		12/14/1988	CTL ENVIRONMENTAL				

ABATEO

Asbestos: Y Friable: N ACM Status: Non-Friable Assumed

MATERIAL QUANTITIES

10 LINEAR FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

O&M MAINTAIN AND MONITOR

Priority:

3

Preventative Measures:

USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT,
 TRANSITE, TILE UNDERLAY & SCRATCH COATS

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **031 - ROOSEVELT SCHOOL**
Building #: **001 - MULTIPURPOSE RM/OFFICES**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA 010

Material Category:
MISCELLANEOUS

Location:
BOOKROOM

Material Description:
VINYL FLOOR TILE

Damage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61395	0	12/14/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

80 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

Priority:

Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

1 X 1 YELLOW W/WHITE & BEIGE

SISC - AHERA COMPLIANCE PROGRAM

County: KERN
Project #: 060027 - BAKERSFIELD CITY SCHOOL DISTRICT
Campus #: 031 - ROOSEVELT SCHOOL
Building #: 001 - MULTIPURPOSE RM/OFFICES
Inspection Dates: 02/27/2001 To 03/29/2001

Inspected by: HAL GOUNDER
Certification#: 3023
State: CA
Gross Square Ft: 0

***** INSPECTION RESULTS UNIFIED SAMPLING AREA - 011 *****

Material Category:
MISCELLANEOUS

Location:
OFFICES/RESTROOM/TEACHER'S DINING

Material Description:
DRYWALL

Damage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61402	0	12/16/1988	CTL ENVIRONMENTAL				

Asbestos: N Friable: N/A ACM Status: No Suspect Material

MATERIAL QUANTITIES

3,834 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

Priority:

Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

SISC - AHERA COMPLIANCE PROGRAMCounty: **KERN**Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**Campus #: **031 - ROOSEVELT SCHOOL**Building #: **001 - MULTIPURPOSE RM/OFFICES**Inspection Dates: **02/27/2001 To 03/29/2001**Inspected by: **HAL GOUNDER**Certification#: **3023**State: **CA**Gross Square Ft: **0****INSPECTION RESULTS UNIFIED SAMPLING AREA - 012**Material Category:
SURFACING MATERIALSLocation:
OFFICES/HALLWAY/LIBRARYMaterial Description:
HARDWALL/CEILING PLASTERDamage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61405	0	12/14/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material****MATERIAL QUANTITIES****12,888 SQ FEET****MANAGEMENT PLAN RECOMMENDATION**

Recommended Response Action:

Priority:

Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

ROUGH

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **031 - ROOSEVELT SCHOOL**
Building #: **001 - MULTIPURPOSE RM/OFFICES**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

***** INSPECTION RESULTS UNIFIED SAMPLING AREA - 013 *****

Material Category:
MISCELLANEOUS

Location:
MULTIPURPOSE ROOM

Material Description:
VINYL FLOOR TILE

Damage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61441	0	12/14/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

3,625 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

Priority:

Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

1 X 1 WHITE W/GRAY & CHARCOAL

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **031 - ROOSEVELT SCHOOL**
Building #: **001 - MULTIPURPOSE RM/OFFICES**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 014

Material Category:
MISCELLANEOUS

Location:
N.W STORAGE OFF STAGE

Material Description:
LINOLEUM

Damage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61458	0	12/14/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

145 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

Priority:

Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

BROWN MARBLED

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **031 - ROOSEVELT SCHOOL**
Building #: **001 - MULTIPURPOSE RM/OFFICES**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

***** INSPECTION RESULTS UNIFIED SAMPLING AREA - 015 *****

Material Category:
MISCELLANEOUS

Location:
MAIN OFFICE/DITTO/CONFERENCE

Material Description:
DROP OR LAY-IN PANEL

Damage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61477	0	12/14/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

2,300 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

Priority:

Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

2 X 4 WHITE

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
 Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
 Campus #: **031 - ROOSEVELT SCHOOL**
 Building #: **001 - MULTIPURPOSE RM/OFFICES**
 Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
 Certification#: **3023**
 State: **CA**
 Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 016

Material Category:
MISCELLANEOUS

Location:
KITCHEN

Material Description:
VINYL FLOOR TILE

Damage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61485	0	12/14/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

900 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

Priority:

Preventative Measures:

Action Election:

Response Action Schedule

Inspector's Comments:

1 X 1 BROWNISH GRAY W/BROWN & WHITE

Start Date

Completion Date

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **031 - ROOSEVELT SCHOOL**
Building #: **001 - MULTIPURPOSE RM/OFFICES**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 017

Material Category:
SURFACING MATERIALS

Location:
**WORK ROOM/TCHR DINING/KITCHEN
PANTRY**

Material Description:
HARDWALL/CEILING PLASTER

Damage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61498	0	12/14/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

15,888 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

Priority:

Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

SMOOTH

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **031 - ROOSEVELT SCHOOL**
Building #: **001 - MULTIPURPOSE RM/OFFICES**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

***** INSPECTION RESULTS UNIFIED SAMPLING AREA - 018 *****

Material Category:
MISCELLANEOUS

Location:
**MAIN OFFICE/PRIN/DITTO/HALL/CONF
TCHR DINING/HEALTH**

Material Description:
LINOLEUM

Damage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61500	0	12/14/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

4,450 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

Priority:

Preventative Measures:

Action Election:

Response Action Schedule

Inspector's Comments:

Start Date

Completion Date

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **031 - ROOSEVELT SCHOOL**
Building #: **001 - MULTIPURPOSE RM/OFFICES**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

***** INSPECTION RESULTS UNIFIED SAMPLING AREA - 019 *****

Material Category:
MISCELLANEOUS

Location:
BOOK ROOM

Material Description:
VINYL FLOOR TILE

Damage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61511	0	12/14/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

700 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

Priority:

Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

1 X 1 WHITE W/TAN

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **031 - ROOSEVELT SCHOOL**
Building #: **001 - MULTIPURPOSE RM/OFFICES**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

***** INSPECTION RESULTS UNIFIED SAMPLING AREA - 020 *****

Material Category:
MISCELLANEOUS

Location:
MPR/KITCHEN/WASH ROOM

Material Description:
ACOUSTICAL TILE (1X1)

Damage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61519	0	12/16/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

2,613 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

Priority:

Preventative Measures:

Action Election:

Response Action Schedule

Inspector's Comments:

1 X 1 WHITE UNIFORM PATTERN

Start Date

Completion Date

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **031 - ROOSEVELT SCHOOL**
Building #: **001 - MULTIPURPOSE RM/OFFICES**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

***** INSPECTION RESULTS UNIFIED SAMPLING AREA 021 *****

Material Category:
SURFACING MATERIALS

Location:
THROUGHOUT

Material Description:
STUCCO, PLASTER

Damage Category:
ACBM WITH POTENTIAL FOR DAMAGE

Reason for Damage Category:
MATERIAL IN GOOD CONDITION

Potential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
8502	5	12/16/1988	CTL ENVIRONMENTAL	8503	2	12/16/1988	CTL ENVIRONMENTAL

Asbestos: **Y** Friable: **N** ACM Status: **Non-Friable ACBM**

MATERIAL QUANTITIES

3,600 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

O&M MAINTAIN AND MONITOR

Priority:

3

Preventative Measures:

**FOR USE WITH OTHER
ACM**

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

CEILING - LOCATION UNKNOWN

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **031 - ROOSEVELT SCHOOL**
Building #: **001 - MULTIPURPOSE RM/OFFICES**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 022

Material Category:
THERMAL SYSTEM INSULATION

Location:
ON HEATER IN PAPER STORAGE

Material Description:
MJP ON PIPE COVERING

Damage Category:
ACBM WITH POTENTIAL FOR DAMAGE

Reason for Damage Category:
FAIR CONDITION

Potential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
=====	=====	=====	=====	=====	=====	=====	=====
ASSUMED		03/17/2001	HAL GOUNDER				

Asbestos: **Y** Friable: **Y** ACM Status: **Friable Assumed**

MATERIAL QUANTITIES

6 ELBOWS

AND PIPE COVERING

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

O&M MAINTAIN AND MONITOR

Priority:

3

Preventative Measures:

FOR USE W/PIPE INSULATION & MUDDED JOINT FITTINGS


Action Election:

Response Action Schedule


Start Date

Completion Date


Inspector's Comments:



LEGEND



NON-ASBESTOS
VINYL FLOOR TILE



NON-ASBESTOS
CEILING TILES



NON-ASBESTOS
SPRAY / TROWEL
APPLIED MATERIAL



ASBESTOS
CONTAINING
VINYL FLOOR TILE



ASBESTOS
CONTAINING
CEILING TILES



ASBESTOS
CONTAINING
SPRAY / TROWEL
APPLIED MATERIAL

SISC

SAFETY & LOSS CONTROL

INSPECTION
DATE

02/27 - 03/29/2001

DRAWING
NUMBER

031001

AHERA COMPLIANCE PROGRAM

060027-031-001

BAKERSFIELD CITY SCHOOL DISTRICT

ROOSEVELT SCHOOL

MPR / OFFICES

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **031 - ROOSEVELT SCHOOL**
Building #: **002 - CLASSROOMS 5-10**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

***** INSPECTION RESULTS UNIFIED SAMPLING AREA - 001 *****

Material Category:
MISCELLANEOUS

Location:
ON FLOOR UNDER TILE

Material Description:
MASTIC

Damage Category:
ACBM WITH POTENTIAL FOR DAMAGE

Reason for Damage Category:
MATERIAL IN GOOD CONDITION

Potential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
=====	=====	=====	=====	=====	=====	=====	=====
ASSUMED		08/07/1995	JAY OLSEN				

Asbestos: **Y** Friable: **N** ACM Status: **Non-Friable Assumed**

MATERIAL QUANTITIES**MANAGEMENT PLAN RECOMMENDATION**

Recommended Response Action:

O&M MAINTAIN AND MONITOR

Priority:

3

Preventative Measures:

**USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT,
TRANSITE, TILE UNDERLAY & SCRATCH COATS**

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

**MATERIAL SHOULD BE SAMPLED PRIOR TO ABATEMENT TO VERIFY
ASBESTOS CONTENT.**

SISC - AHERA COMPLIANCE PROGRAMCounty: **KERN**Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**Campus #: **031 - ROOSEVELT SCHOOL**Building #: **002 - CLASSROOMS 5-10**Inspection Dates: **02/27/2001 To 03/29/2001**Inspected by: **HAL GOUNDER**Certification#: **3023**State: **CA**Gross Square Ft: **0******* INSPECTION RESULTS UNIFIED SAMPLING AREA - 002 *****Material Category:
MISCELLANEOUSLocation:
ENTIRE BUILDINGMaterial Description:
VINYL FLOOR TILEDamage Category:
ACBM WITH POTENTIAL FOR DAMAGEReason for Damage Category:
MATERIAL IN GOOD CONDITIONPotential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61565	10	12/16/1988	CTL ENVIRONMENTAL				

Asbestos: **Y** Friable: **N** ACM Status: **Non-Friable ACBM****MATERIAL QUANTITIES****5,775 SQ FEET****MANAGEMENT PLAN RECOMMENDATION**

Recommended Response Action:

O&M MAINTAIN AND MONITOR

Priority:

3

Preventative Measures:

**USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT,
TRANSITE, TILE UNDERLAY & SCRATCH COATS**

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

**9 X 9 TAN W/BROWN & WHITE
CARPET & SHEET VINYL OVER TILE.**

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **031 - ROOSEVELT SCHOOL**
Building #: **002 - CLASSROOMS 5-10**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

***** INSPECTION RESULTS UNIFIED SAMPLING AREA - 003 *****

Material Category:
MISCELLANEOUS

Location:
ENTIRE BUILDING

Material Description:
ACOUSTICAL TILE (1X1)

Damage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61598	0	12/16/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

5,775 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

Priority:

Preventative Measures:

Action Election:


Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

1 X 1 WHITE




LEGEND



NON-ASBESTOS
VINYL FLOOR TILE



NON-ASBESTOS
CEILING TILES



NON-ASBESTOS
SPRAY / TROWEL
APPLIED MATERIAL



ASBESTOS
CONTAINING
VINYL FLOOR TILE



ASBESTOS
CONTAINING
CEILING TILES



ASBESTOS
CONTAINING
SPRAY / TROWEL
APPLIED MATERIAL

SISC

SAFETY & LOSS CONTROL

INSPECTION
DATE

02/27 - 03/29/2001

DRAWING
NUMBER

031002

AHERA COMPLIANCE PROGRAM

060027-031-002
BAKERSFIELD CITY SCHOOL DISTRICT
ROOSEVELT SCHOOL
CLASSROOMS 5-10

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
 Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
 Campus #: **031 - ROOSEVELT SCHOOL**
 Building #: **003 - CLASSROOMS 13-17**
 Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
 Certification#: **3023**
 State: **CA**
 Gross Square Ft: **0**

*** INSPECTION RESULTS UNIFIED SAMPLING AREA - 001 ***

Material Category:
MISCELLANEOUS

Location:
CLASSROOMS 15/16/17

Material Description:
VINYL FLOOR TILE

Damage Category:
ACBM WITH POTENTIAL FOR DAMAGE

Reason for Damage Category:
MATERIAL IN GOOD CONDITION

Potential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61530	10	12/16/1988	CTL ENVIRONMENTAL				

Asbestos: **Y** Friable: **N** ACM Status: **Non-Friable ACBM**

MATERIAL QUANTITY

2,880 SQ FEET

ABATED
2021

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

O&M MAINTAIN AND MONITOR

Priority:

3

Preventative Measures:

USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT, TRANSITE, TILE UNDERLAY & SCRATCH COATS

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

9 X 9 TAN W/BROWN & WHITE UNDER CARPET AND LINOLEUM STRIPS AT DOORS AND SINKS.

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
 Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
 Campus #: **031 - ROOSEVELT SCHOOL**
 Building #: **003 - CLASSROOMS 13-17**
 Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
 Certification#: **3023**
 State: **CA**
 Gross Square Ft: **0**

*** INSPECTION RESULTS UNIFIED SAMPLING AREA - 002 ***

Material Category:
MISCELLANEOUS

Location:
ON FLOOR UNDER TILE

Material Description:
MASTIC

Damage Category:
ACBM WITH POTENTIAL FOR DAMAGE

Reason for Damage Category:
MATERIAL IN GOOD CONDITION

Potential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
=====	=====	=====	=====	=====	=====	=====	=====
ASSUMED		08/07/1995	JAY OLSEN				

Asbestos: **Y** Friable: **N** ACM Status: **Non-Friable Assumed**

MATERIAL QUANTITIES

*ABATED
2021*

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

Priority:

Preventative Measures:

O&M MAINTAIN AND MONITOR

3

USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT, TRANSITE, TILE UNDERLAY & SCRATCH COATS

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

MATERIAL SHOULD BE SAMPLED PRIOR TO ABATEMENT TO VERIFY ASBESTOS CONTENT.

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
 Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
 Campus #: **031 - ROOSEVELT SCHOOL**
 Building #: **003 - CLASSROOMS 13-17**
 Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
 Certification#: **3023**
 State: **CA**
 Gross Square Ft: **0**

*** INSPECTION RESULTS UNIFIED SAMPLING AREA - 003 ***

Material Category:
MISCELLANEOUS

Location:
LOUNGE/CUSTODIAN

Material Description:
VINYL FLOOR TILE

Damage Category:
ACBM WITH POTENTIAL FOR DAMAGE

Reason for Damage Category:
MATERIAL IN GOOD CONDITION

Potential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61535	15	12/16/1988	CTL ENVIRONMENTAL				

Asbestos: **Y** Friable: **N** ACM Status: **Non-Friable ACBM**

MATERIAL QUANTITY

405 SQ FEET

ABATED

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

O&M MAINTAIN AND MONITOR

Priority:

3

Preventative Measures:

USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT, TRANSITE, TILE UNDERLAY & SCRATCH COATS

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

9 X 9 PINK W/RED UNDER CARPET.

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **031 - ROOSEVELT SCHOOL**
Building #: **003 - CLASSROOMS 13-17**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

***** INSPECTION RESULTS UNIFIED SAMPLING AREA - 004 *****

Material Category:
MISCELLANEOUS

Location:
CLASSROOMS 13/14

Material Description:
VINYL FLOOR TILE

Damage Category:
ACBM WITH POTENTIAL FOR DAMAGE

Reason for Damage Category:
MATERIAL IN GOOD CONDITION

Potential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61564	10	12/16/1988	CTL ENVIRONMENTAL				

ABATED

Asbestos: **Y** Friable: **N** ACM Status: **Non-Friable ACBM**

MATERIAL QUANTITIES

1,928 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

O&M MAINTAIN AND MONITOR

Priority:

3

Preventative Measures:

**USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT,
TRANSITE, TILE UNDERLAY & SCRATCH COATS**

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

9 X9 WHITE W/RED & BLACK UNDER CARPET.

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
 Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
 Campus #: **031 - ROOSEVELT SCHOOL**
 Building #: **003 - CLASSROOMS 13-17**
 Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
 Certification#: **3023**
 State: **CA**
 Gross Square Ft: **0**

*** INSPECTION RESULTS UNIFIED SAMPLING AREA - 005 ***

Material Category:
MISCELLANEOUS

Location:
ENTIRE BLDG EXCEPT RR/CUSTODIAN

Material Description:
ACOUSTICAL TILE (1X1)

Damage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61570	0	12/16/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

5,138 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

Priority:

Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

1 X 1 WHITE

SISC - AHERA COMPLIANCE PROGRAMCounty: **KERN**Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**Campus #: **031 - ROOSEVELT SCHOOL**Building #: **003 - CLASSROOMS 13-17**Inspection Dates: **02/27/2001 To 03/29/2001**Inspected by: **HAL GOUNDER**Certification#: **3023**State: **CA**Gross Square Ft: **0****INSPECTION RESULTS UNIFIED SAMPLING AREA - 006**Material Category:
SURFACING MATERIALSLocation:
RESTROOMS/CUSTODIANMaterial Description:
HARDWALL/CEILING PLASTERDamage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61591	0	12/14/1988	CTL ENVIRONMENTAL				

Asbestos: **N**Friable: **N/A**ACM Status: **No Suspect Material****MATERIAL QUANTITIES****1,914 SQ FEET****MANAGEMENT PLAN RECOMMENDATION**

Recommended Response Action:

Priority:

Preventative Measures:

Action Election:

Response Action Schedule


Start Date

Completion Date






Inspector's Comments:

SMOOTH

LINOLEUM STRIPS IN ALL ROOMS
 CARPET OVER VFT



LEGEND

	NON-ASBESTOS VINYL FLOOR TILE
	NON-ASBESTOS CEILING TILES
	NON-ASBESTOS SPRAY / TROWEL APPLIED MATERIAL
	ASBESTOS CONTAINING VINYL FLOOR TILE
	ASBESTOS CONTAINING CEILING TILES
	ASBESTOS CONTAINING SPRAY / TROWEL APPLIED MATERIAL

SISC SAFETY & LOSS CONTROL

INSPECTION DATE	DRAWING NUMBER
02/27 - 03/29/2001	031003

AHIERA COMPLIANCE PROGRAM

060027-031-003
 BAKERSFIELD CITY SCHOOL DISTRICT
 ROOSEVELT SCHOOL
 CLASSROOMS 13-17

SISC - AHERA COMPLIANCE PROGRAM

County: KERN
 Project #: 060027 - BAKERSFIELD CITY SCHOOL DISTRICT
 Campus #: 031 - ROOSEVELT SCHOOL
 Building #: 004 - CLASSROOMS 18-22
 Inspection Dates: 02/27/2001 To 03/29/2001

Inspected by: HAL GOUNDER
 Certification#: 3023
 State: CA
 Gross Square Ft: 0

*** INSPECTION RESULTS UNIFIED SAMPLING AREA - 001 ***

Material Category:
 MISCELLANEOUS

Location:
 ON FLOOR UNDER TILE

Material Description:
 MASTIC

Damage Category:
 ACBM WITH POTENTIAL FOR DAMAGE

Reason for Damage Category:
 MATERIAL IN GOOD CONDITION

Potential for Disturbance: SLIGHT

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
=====	=====	=====	=====	=====	=====	=====	=====
ASSUMED		08/07/1995	JAY OLSEN				

ABATED

Asbestos: Y Friable: N ACM Status: Non-Friable Assumed

MATERIAL QUANTITIES

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

O&M MAINTAIN AND MONITOR

Priority:

3

Preventative Measures:

USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT, TRANSITE, TILE UNDERLAY & SCRATCH COATS

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

MATERIAL SHOULD BE SAMPLED PRIOR TO ABATEMENT TO VERIFY ASBESTOS CONTENT.

SISC - AHERA COMPLIANCE PROGRAM

County: KERN
 Project #: 060027 - BAKERSFIELD CITY SCHOOL DISTRICT
 Campus #: 031 - ROOSEVELT SCHOOL
 Building #: 004 - CLASSROOMS 18-22
 Inspection Dates: 02/27/2001 To 03/29/2001

Inspected by: HAL GOUNDER
 Certification#: 3023
 State: CA
 Gross Square Ft: 0

*** INSPECTION RESULTS UNIFIED SAMPLING AREA - 003 ***

Material Category:
 MISCELLANEOUS

Location:
 BALL ROOM AND CLASSROOMS 18-21

Material Description:
 VINYL FLOOR TILE

Damage Category:
 ACBM WITH POTENTIAL FOR DAMAGE

Reason for Damage Category:
 MATERIAL IN GOOD CONDITION

Potential for Disturbance: SLIGHT

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61545	2	12/16/1988	CTL ENVIRONMENTAL				

Asbestos: Y Friable: N ACM Status: Non-Friable ACBM

MATERIAL QUANTITY

140 SQ FEET

ABATED

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

O&M MAINTAIN AND MONITOR

Priority:

3

Preventative Measures:

USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT, TRANSITE, TILE UNDERLAY & SCRATCH COATS

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

9 X 9 WHITE W/GRAY

SISC - AHERA COMPLIANCE PROGRAMCounty: **KERN**Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**Campus #: **031 - ROOSEVELT SCHOOL**Building #: **004 - CLASSROOMS 18-22**Inspection Dates: **02/27/2001 To 03/29/2001**Inspected by: **HAL GOUNDER**Certification#: **3023**State: **CA**Gross Square Ft: **0****INSPECTION RESULTS UNIFIED SAMPLING AREA - 004**Material Category:
MISCELLANEOUSLocation:
BALL ROOM/CLASSROOMSMaterial Description:
ACOUSTICAL TILE (1X1)Damage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61543	0	12/16/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material****MATERIAL QUANTITIES****4,990 SQ FEET****MANAGEMENT PLAN RECOMMENDATION**

Recommended Response Action:

Priority:

Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

1 X 1 WHITE UNIFORM PATTERN

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**

Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**

Campus #: **031 - ROOSEVELT SCHOOL**

Building #: **004 - CLASSROOMS 18-22**

Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**

Certification#: **3023**

State: **CA**

Gross Square Ft: **0**

*** INSPECTION RESULTS UNIFIED SAMPLING AREA - 005 ***

Material Category:
SURFACING MATERIALS

Location:
RESTROOMS/CUSTODIAN

Material Description:
HARDWALL/CEILING PLASTER

Damage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61560	0	12/14/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

1,893 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

Priority:

Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

SMOOTH

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **031 - ROOSEVELT SCHOOL**
Building #: **004 - CLASSROOMS 18-22**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 006

Material Category:
MISCELLANEOUS

Location:
CLASSROOM

Material Description:
VINYL FLOOR TILE

Damage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61562	0	12/14/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

4,850 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

Priority:

Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

1 X 1 GRAY W/WHITE

SISC - AHERA COMPLIANCE PROGRAMCounty: **KERN**Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**Campus #: **031 - ROOSEVELT SCHOOL**Building #: **004 - CLASSROOMS 18-22**Inspection Dates: **02/27/2001 To 03/29/2001**Inspected by: **HAL GOUNDER**Certification#: **3023**State: **CA**Gross Square Ft: **0******* INSPECTION RESULTS UNIFIED SAMPLING AREA - 007 *****

Material Category:

THERMAL SYSTEM INSULATION

Location:

IN ATTIC ABOVE OLD BOILER ROOM

Material Description:

PIPE COVERING

Damage Category:

ACBM WITH POTENTIAL FOR DAMAGE

Reason for Damage Category:

FAIR CONDITIONPotential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
=====	=====	=====	=====	=====	=====	=====	=====
ASSUMED		03/13/2001	HAL GOUNDER				

Asbestos: **Y**Friable: **Y**ACM Status: **Friable Assumed****MATERIAL QUANTITIES****MANAGEMENT PLAN RECOMMENDATION**

Recommended Response Action:

O&M MAINTAIN AND MONITOR

Priority:

3

Preventative Measures:

FOR USE W/PIPE INSULATION & MUDDED JOINT FITTINGS

Action Election:


Response Action Schedule

Start Date


Completion Date

Inspector's Comments:

LINOLEUM STRIPS IN ALL ROOMS
CARPET OVER VFT




LEGEND



NON-ASBESTOS
VINYL FLOOR TILE



NON-ASBESTOS
CEILING TILES



NON-ASBESTOS
SPRAY / TROWEL
APPLIED MATERIAL



ASBESTOS
CONTAINING
VINYL FLOOR TILE



ASBESTOS
CONTAINING
CEILING TILES



ASBESTOS
CONTAINING
SPRAY / TROWEL
APPLIED MATERIAL

SISC

SAFETY & LOSS CONTROL

INSPECTION
DATE
02/27 - 03/29/2001

DRAWING
NUMBER
031004

AHERA
COMPLIANCE PROGRAM

060027-031-004
BAKERSFIELD CITY SCHOOL DISTRICT
ROOSEVELT SCHOOL
CLASSROOMS 18-22

SISC - AHERA COMPLIANCE PROGRAMCounty: **KERN**Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**Campus #: **031 - ROOSEVELT SCHOOL**Building #: **005 - KINDERGARTEN**Inspection Dates: **02/27/2001 To 03/29/2001**Inspected by: **HAL GOUNDER**Certification#: **3023**State: **CA**Gross Square Ft: **0****INSPECTION RESULTS UNIFIED SAMPLING AREA - 001**Material Category:
MISCELLANEOUSLocation:
CLASSROOMS 11/12 / STOREROOMMaterial Description:
ACOUSTICAL TILE (1X1)Damage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61571	0	12/16/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material****MATERIAL QUANTITIES****2,900 SQ FEET****MANAGEMENT PLAN RECOMMENDATION**

Recommended Response Action:

Priority:

Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

1 X 1 WHITE UNIFORM PATTERN

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **031 - ROOSEVELT SCHOOL**
Building #: **005 - KINDERGARTEN**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

***** INSPECTION RESULTS UNIFIED SAMPLING AREA - 003 *****

Material Category:
SURFACING MATERIALS

Location:
STORAGE/MECHANIC/RESTROOMS

Material Description:
HARDWALL/CEILING PLASTER

Damage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61574	0	12/14/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

1,734 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

Priority:

Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

SISC - AHERA COMPLIANCE PROGRAMCounty: **KERN**Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**Campus #: **031 - ROOSEVELT SCHOOL**Building #: **005 - KINDERGARTEN**Inspection Dates: **02/27/2001 To 03/29/2001**Inspected by: **HAL GOUNDER**Certification#: **3023**State: **CA**Gross Square Ft: **0******* INSPECTION RESULTS UNIFIED SAMPLING AREA - 004 *****Material Category:
MISCELLANEOUSLocation:
ON FLOOR UNDER TILEMaterial Description:
MASTICDamage Category:
ACBM WITH POTENTIAL FOR DAMAGEReason for Damage Category:
MATERIAL IN GOOD CONDITIONPotential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
=====	=====	=====	=====	=====	=====	=====	=====
ASSUMED		08/07/1995	JAY OLSEN				

Asbestos: **Y** Friable: **N** ACM Status: **Non-Friable Assumed****MATERIAL QUANTITIES****MANAGEMENT PLAN RECOMMENDATION**

Recommended Response Action:

O&M MAINTAIN AND MONITOR

Priority:

3

Preventative Measures:

**USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT,
TRANSITE, TILE UNDERLAY & SCRATCH COATS**

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

**MATERIAL SHOULD BE SAMPLED PRIOR TO ABATEMENT TO VERIFY
ASBESTOS CONTENT.**

SISC - AHERA COMPLIANCE PROGRAMCounty: **KERN**Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**Campus #: **031 - ROOSEVELT SCHOOL**Building #: **005 - KINDERGARTEN**Inspection Dates: **02/27/2001 To 03/29/2001**Inspected by: **HAL GOUNDER**Certification#: **3023**State: **CA**Gross Square Ft: **0******* INSPECTION RESULTS UNIFIED SAMPLING AREA - 005 *****Material Category:
MISCELLANEOUSLocation:
CLASSROOMS 11/12/STOREROOMSMaterial Description:
VINYL FLOOR TILEDamage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61588	0	12/14/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material****MATERIAL QUANTITIES****2,900 SQ FEET****MANAGEMENT PLAN RECOMMENDATION**

Recommended Response Action:

Priority:

Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

1 X 1 OFF WHITE W/OLIVE

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **031 - ROOSEVELT SCHOOL**
Building #: **005 - KINDERGARTEN**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

***** INSPECTION RESULTS UNIFIED SAMPLING AREA - 006 *****

Material Category:
THERMAL SYSTEM INSULATION

Location:
IN ATTIC ABOVE OLD BOILER ROOM

Material Description:
PIPE COVERING

Damage Category:
ACBM WITH POTENTIAL FOR DAMAGE

Reason for Damage Category:
FAIR CONDITION

Potential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
=====	=====	=====	=====	=====	=====	=====	=====
ASSUMED		03/13/2001	HAL GOUNDER				

Asbestos: **Y** Friable: **Y** ACM Status: **Friable Assumed**

MATERIAL QUANTITIES**MANAGEMENT PLAN RECOMMENDATION**

Recommended Response Action:

O&M MAINTAIN AND MONITOR

Priority:

3

Preventative Measures:

FOR USE W/PIPE INSULATION & MUDDED JOINT FITTINGS

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
 Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
 Campus #: **031 - ROOSEVELT SCHOOL**
 Building #: **005 - KINDERGARTEN**
 Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
 Certification#: **3023**
 State: **CA**
 Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 007

Material Category:
MISCELLANEOUS

Location:
OLD BOILER ROOM

Material Description:
TRANSITE PIPE

Damage Category:
ACBM WITH POTENTIAL FOR DAMAGE

Reason for Damage Category:
FAIR CONDITION

Potential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
=====	=====	=====	=====	=====	=====	=====	=====
ASSUMED		03/13/2001	HAL GOUNDER				

Asbestos: **Y** Friable: **N** ACM Status: **Non-Friable Assumed**

MATERIAL QUANTITIES

8" OD

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

Priority:

Preventative Measures:

O&M MAINTAIN AND MONITOR

3

FOR USE W/PIPE INSULATION & MUDDER JOINT FITTINGS


Action Election:

Response Action Schedule


Start Date

Completion Date


Inspector's Comments:




LEGEND



NON-ASBESTOS
VINYL FLOOR TILE



NON-ASBESTOS
CEILING TILES



NON-ASBESTOS
SPRAY / TROWEL
APPLIED MATERIAL



ASBESTOS
CONTAINING
VINYL FLOOR TILE



ASBESTOS
CONTAINING
CEILING TILES



ASBESTOS
CONTAINING
SPRAY / TROWEL
APPLIED MATERIAL

SISC

SAFETY & LOSS CONTROL

INSPECTION
DATE

02/27 - 03/29/2001

DRAWING
NUMBER

031005

AHERA COMPLIANCE PROGRAM

060027-031-005
BAKERSFIELD CITY SCHOOL DISTRICT
ROOSEVELT SCHOOL
KINDERGARTEN

SISC - AHERA COMPLIANCE PROGRAMCounty: **KERN**Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**Campus #: **031 - ROOSEVELT SCHOOL**Building #: **006 - CLASSROOMS 28-29**Inspection Dates: **02/27/2001 To 03/29/2001**Inspected by: **HAL GOUNDER**Certification#: **3023**State: **CA**Gross Square Ft: **0******* INSPECTION RESULTS UNIFIED SAMPLING AREA - 001 *****

Material Category:

MISCELLANEOUS

Location:

ON FLOOR UNDER TILE

Material Description:

MASTIC

Damage Category:

ACBM WITH POTENTIAL FOR DAMAGE

Reason for Damage Category:

MATERIAL IN GOOD CONDITIONPotential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
=====	=====	=====	=====	=====	=====	=====	=====
ASSUMED		08/07/1995	JAY OLSEN				

Asbestos: **Y**Friable: **N**ACM Status: **Non-Friable Assumed****MATERIAL QUANTITIES****MANAGEMENT PLAN RECOMMENDATION**

Recommended Response Action:

O&M MAINTAIN AND MONITOR

Priority:

3

Preventative Measures:

**USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT,
TRANSITE, TILE UNDERLAY & SCRATCH COATS**

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

**MATERIAL SHOULD BE SAMPLED PRIOR TO ABATEMENT TO VERIFY
ASBESTOS CONTENT.**

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**

Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**

Campus #: **031 - ROOSEVELT SCHOOL**

Building #: **006 - CLASSROOMS 28-29**

Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**

Certification#: **3023**

State: **CA**

Gross Square Ft: **0**

INSPECTION RESULTS UNIFIED SAMPLING AREA - 002

Material Category:
MISCELLANEOUS

Location:
ENTIRE BUILDING

Material Description:
VINYL FLOOR TILE

Damage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61542	0	12/14/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

960 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

Priority:

Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

1 X 1 BEIGE W/RED BROWN

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **031 - ROOSEVELT SCHOOL**
Building #: **006 - CLASSROOMS 28-29**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

***** INSPECTION RESULTS UNIFIED SAMPLING AREA - 003 *****

Material Category:
MISCELLANEOUS

Location:
ENTIRE BUILDING

Material Description:
ACOUSTICAL TILE (1X1)

Damage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61553	0	12/16/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

960 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

Priority:

Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

WHITE

SISC - AHERA COMPLIANCE PROGRAM

County: KERN

Project #: 060027 - BAKERSFIELD CITY SCHOOL DISTRICT

Campus #: 031 - ROOSEVELT SCHOOL

Building #: 006 - CLASSROOMS 28-29

Inspection Dates: 02/27/2001 To 03/29/2001

Inspected by: HAL GOUNDER

Certification#: 3023

State: CA

Gross Square Ft: 0

INSPECTION RESULTS UNIFIED SAMPLING AREA - 004

Material Category:
MISCELLANEOUS

Location:
FURNACE

Material Description:
TRANSITE PANEL

Damage Category:
ACBM WITH POTENTIAL FOR DAMAGE

Reason for Damage Category:
MATERIAL IN GOOD CONDITION

Potential for Disturbance: SLIGHT

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
=====	=====	=====	=====	=====	=====	=====	=====
ASSUMED		12/14/1988	CTL ENVIRONMENTAL				

ABATED

Asbestos: Y Friable: N ACM Status: Non-Friable Assumed

MATERIAL QUANTITIES

8 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

O&M MAINTAIN AND MONITOR

Priority:

3

Preventative Measures:

USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT,
TRANSITE, TILE UNDERLAY & SCRATCH COATS


Action Election:

Response Action Schedule

Start Date

Completion Date


Inspector's Comments:



LEGEND



NON-ASBESTOS
VINYL FLOOR TILE



NON-ASBESTOS
CEILING TILES



NON-ASBESTOS
SPRAY / TROWEL
APPLIED MATERIAL



ASBESTOS
CONTAINING
VINYL FLOOR TILE



ASBESTOS
CONTAINING
CEILING TILES



ASBESTOS
CONTAINING
SPRAY / TROWEL
APPLIED MATERIAL

SISC

SAFETY & LOSS CONTROL

INSPECTION
DATE
02/27 - 03/29/2001

DRAWING
NUMBER
031006

**AHERA
COMPLIANCE PROGRAM**

060027-031-006
BAKERSFIELD CITY SCHOOL DISTRICT
ROOSEVELT SCHOOL
CLASSROOMS 28-29

SISC - AHERA COMPLIANCE PROGRAMCounty: **KERN**Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**Campus #: **031 - ROOSEVELT SCHOOL**Building #: **008 - CLASSROOM 26**Inspection Dates: **02/27/2001 To 03/29/2001**Inspected by: **HAL GOUNDER**Certification#: **3023**State: **CA**Gross Square Ft: **0******* INSPECTION RESULTS UNIFIED SAMPLING AREA - 001 *****Material Category:
MISCELLANEOUS

Location:

Material Description:
NO SUSPECT MATERIALDamage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
=====	=====	=====	=====	=====	=====	=====	=====

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material****MATERIAL QUANTITIES****MANAGEMENT PLAN RECOMMENDATION**

Recommended Response Action:

Priority:

Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date


Inspector's Comments:

NO SUSPECT MATERIAL

(


(

(



NO SUSPECT MATERIAL

LEGEND



NON-ASBESTOS
VINYL FLOOR TILE



NON-ASBESTOS
CEILING TILES



NON-ASBESTOS
SPRAY / TROWEL
APPLIED MATERIAL



ASBESTOS
CONTAINING
VINYL FLOOR TILE



ASBESTOS
CONTAINING
CEILING TILES



ASBESTOS
CONTAINING
SPRAY / TROWEL
APPLIED MATERIAL

SISC

SAFETY & LOSS CONTROL

INSPECTION
DATE
02/27 - 03/29/2001

DRAWING
NUMBER
031008

AHERA
COMPLIANCE PROGRAM

060027-031-008
BAKERSFIELD CITY SCHOOL DISTRICT
ROOSEVELT SCHOOL
CLASSROOM 26

SISC AHERA COMPLIANCE PROGRAMCounty: **KERN**Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**Campus #: **031 - ROOSEVELT SCHOOL**Building #: **009 - CLASSROOMS 23-25**Inspection Dates: **02/27/2001 To 03/29/2001**Inspected by: **HAL GOUNDER**Certification#: **3023**State: **CA**Gross Square Ft: **0****INSPECTION RESULTS UNIFIED SAMPLING AREA - 001**

Material Category:

MISCELLANEOUS

Location:

ON FLOOR UNDER TILE

Material Description:

MASTIC

Damage Category:

ACBM WITH POTENTIAL FOR DAMAGE

Reason for Damage Category:

MATERIAL IN GOOD CONDITIONPotential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
=====	=====	=====	=====	=====	=====	=====	=====
ASSUMED		08/07/1995	JAY OLSEN				

Asbestos: **Y**Friable: **N**ACM Status: **Non-Friable Assumed****MATERIAL QUANTITIES****MANAGEMENT PLAN RECOMMENDATION**

Recommended Response Action:

O&M MAINTAIN AND MONITOR

Priority:

3

Preventative Measures:

**USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT,
TRANSITE, TILE UNDERLAY & SCRATCH COATS**

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

**MATERIAL SHOULD BE SAMPLED PRIOR TO ABATEMENT TO VERIFY
ASBESTOS CONTENT.**

SISC - AHERA COMPLIANCE PROGRAMCounty: **KERN**Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**Campus #: **031 - ROOSEVELT SCHOOL**Building #: **009 - CLASSROOMS 23-25**Inspection Dates: **02/27/2001 To 03/29/2001**Inspected by: **HAL GOUNDER**Certification#: **3023**State: **CA**Gross Square Ft: **0******* INSPECTION RESULTS UNIFIED SAMPLING AREA - 002 *****Material Category:
MISCELLANEOUSLocation:
CLASSROOMS 23-25Material Description:
VINYL FLOOR TILEDamage Category:
ACBM WITH POTENTIAL FOR DAMAGEReason for Damage Category:
MATERIAL IN GOOD CONDITIONPotential for Disturbance: **SLIGHT**

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61559	10	12/16/1988	CTL ENVIRONMENTAL				

Asbestos: **Y** Friable: **N** ACM Status: **Non-Friable ACBM****MATERIAL QUANTITIES****1,000 SQ FEET****MANAGEMENT PLAN RECOMMENDATION**

Recommended Response Action:

O&M MAINTAIN AND MONITOR

Priority:

3

Preventative Measures:

**USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT,
TRANSITE, TILE UNDERLAY & SCRATCH COATS**

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

**9 X 9 TAN W/WHITE & BROWN
CARPET OVER TILE.**

SISC - AHERA COMPLIANCE PROGRAMCounty: **KERN**Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**Campus #: **031 - ROOSEVELT SCHOOL**Building #: **009 - CLASSROOMS 23-25**Inspection Dates: **02/27/2001 To 03/29/2001**Inspected by: **HAL GOUNDER**Certification#: **3023**State: **CA**Gross Square Ft: **0******* INSPECTION RESULTS UNIFIED SAMPLING AREA - 003 *****Material Category:
MISCELLANEOUSLocation:
CLASSROOM 24Material Description:
VINYL FLOOR TILEDamage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61569	0	12/14/1988	CTL ENVIRONMENTAL				

Asbestos: **N**Friable: **N/A**ACM Status: **No Suspect Material****MATERIAL QUANTITIES****1,000 SQ FEET****MANAGEMENT PLAN RECOMMENDATION**

Recommended Response Action:

Priority:

Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

**1 X 1 BEIGE W/WHITE & BROWN OVER OLD ASBESTOS CONTAINING
FLOOR TILE.**

SISC - AHERA COMPLIANCE PROGRAMCounty: **KERN**Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**Campus #: **031 - ROOSEVELT SCHOOL**Building #: **009 - CLASSROOMS 23-25**Inspection Dates: **02/27/2001 To 03/29/2001**Inspected by: **HAL GOUNDER**Certification#: **3023**State: **CA**Gross Square Ft: **0******* INSPECTION RESULTS UNIFIED SAMPLING AREA - 004 *****Material Category:
MISCELLANEOUSLocation:
ENTIRE BUILDINGMaterial Description:
ACOUSTICAL TILE (1X1)Damage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61578	0	12/16/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material****MATERIAL QUANTITIES****3,000 SQ FEET****MANAGEMENT PLAN RECOMMENDATION**

Recommended Response Action:

Priority:

Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

1 X 1 WHITE UNIFORM PATTERN

SISC - AHERA COMPLIANCE PROGRAM

County: KERN
 Project #: 060027 - BAKERSFIELD CITY SCHOOL DISTRICT
 Campus #: 031 - ROOSEVELT SCHOOL
 Building #: 009 - CLASSROOMS 23-25
 Inspection Dates: 02/27/2001 To 03/29/2001

Inspected by: HAL GOUNDER
 Certification#: 3023
 State: CA
 Gross Square Ft: 0

*** INSPECTION RESULTS UNIFIED SAMPLING AREA - 005 ***

Material Category: MISCELLANEOUS
 Location: ON EASEL BOARDS IN ROOMS 23-25
 Material Description: LINOLEUM

Damage Category: ACBM WITH POTENTIAL FOR DAMAGE
 Reason for Damage Category: POOR CONDITION
 Potential for Disturbance: HIGH

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
=====	=====	=====	=====	=====	=====	=====	=====

ASSUMED 03/13/2001 HAL GOUNDER

*NEGATIVE
 See Doc.
 in Front of
 Book*

Asbestos: Y Friable: N ACM Status: Non-Friable Assumed

MATERIAL QUANTITIES

240 SQ FT

MANAGEMENT PLAN RECOMMENDATION


Recommended Response Action: REMOVE
 Priority: 1
 Preventative Measures: USED W/MISC. & CEMENTITIOUS MATERIAL INCL. VAFT, TRANSITE, TILE UNDERLAY & SCRATCH COATS

Action Election:

Response Action Schedule

Start Date Completion Date


Inspector's Comments:



EASEL LINOLEUM ASSUMED

*NOTE: CARPET OVER TILE

LEGEND



NON-ASBESTOS
VINYL FLOOR TILE



NON-ASBESTOS
CEILING TILES



NON-ASBESTOS
SPRAY / TROWEL
APPLIED MATERIAL



ASBESTOS
CONTAINING
VINYL FLOOR TILE



ASBESTOS
CONTAINING
CEILING TILES



ASBESTOS
CONTAINING
SPRAY / TROWEL
APPLIED MATERIAL

SISC

SAFETY & LOSS CONTROL

INSPECTION
DATE
02/27 - 03/29/2001

DRAWING
NUMBER
031009

AHERA COMPLIANCE PROGRAM

060027-031-009
BAKERSFIELD CITY SCHOOL DISTRICT
ROOSEVELT SCHOOL
CLASSROOMS 23-25

SISC - AHERA COMPLIANCE PROGRAMCounty: **KERN**Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**Campus #: **031 - ROOSEVELT SCHOOL**Building #: **010 - RSP**Inspection Dates: **02/27/2001 To 03/29/2001**Inspected by: **HAL GOUNDER**Certification#: **3023**State: **CA**Gross Square Ft: **0******* INSPECTION RESULTS UNIFIED SAMPLING AREA - 001 *****Material Category:
MISCELLANEOUSLocation:
ENTIRE BUILDINGMaterial Description:
ACOUSTICAL TILE (1X1)Damage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61557	0	12/16/1988	CTL ENVIRONMENTAL				

Asbestos: **N**Friable: **N/A**ACM Status: **No Suspect Material****MATERIAL QUANTITIES****560 SQ FEET****MANAGEMENT PLAN RECOMMENDATION**

Recommended Response Action:

Priority:

Preventative Measures:


Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:




BS 12
61557

LEGEND



NON-ASBESTOS
VINYL FLOOR TILE



NON-ASBESTOS
CEILING TILES



NON-ASBESTOS
SPRAY / TROWEL
APPLIED MATERIAL



ASBESTOS
CONTAINING
VINYL FLOOR TILE



ASBESTOS
CONTAINING
CEILING TILES



ASBESTOS
CONTAINING
SPRAY / TROWEL
APPLIED MATERIAL

SISC

SAFETY & LOSS CONTROL

INSPECTION
DATE

02/27 - 03/29/2001

DRAWING
NUMBER

031010

AHERA COMPLIANCE PROGRAM

060027-031-010
BAKERSFIELD CITY SCHOOL DISTRICT
ROOSEVELT SCHOOL
RSP

SISG - AHERA COMPLIANCE PROGRAMCounty: **KERN**Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**Inspected by: **HAL GOUNDER**Campus #: **031 - ROOSEVELT SCHOOL**Certification#: **3023**Building #: **011 - ENTIRE CAMPUS**State: **CA**Inspection Dates: **02/27/2001 To 03/29/2001**Gross Square Ft: **0****INSPECTION RESULTS UNIFIED SAMPLING AREA - 002**Material Category:
SURFACING MATERIALSLocation:
ENTIRE BUILDINGMaterial Description:
STUCCO, PLASTERDamage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61541	0	12/16/1988	CTL ENVIRONMENTAL	61554	0	12/16/1988	CTL ENVIRONMENTAL
61536	0	12/16/1988	CTL ENVIRONMENTAL	61582	0	12/16/1988	CTL ENVIRONMENTAL

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material****MATERIAL QUANTITIES****99,138 SQ FEET****MANAGEMENT PLAN RECOMMENDATION**

Recommended Response Action:

Priority:

Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **031 - ROOSEVELT SCHOOL**
Building #: **011 - ENTIRE CAMPUS**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

***** INSPECTION RESULTS UNIFIED SAMPLING AREA - 003 *****

Material Category:
SURFACING MATERIALS

Location:
STUCCO CEILING

Material Description:
STUCCO, PLASTER

Damage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
61537	0	12/16/1988	CTL ENVIRONMENTAL	61555	0	12/16/1988	CTL ENVIRONMENTAL
61561	0	12/16/1988	CTL ENVIRONMENTAL	61547	0	12/16/1988	CTL ENVIRONMENTAL
61556	0	12/16/1988	CTL ENVIRONMENTAL				

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES

12,078 SQ FEET

MANAGEMENT PLAN RECOMMENDATION

Recommended Response Action:

Priority:

Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date

Inspector's Comments:

SISC - AHERA COMPLIANCE PROGRAM

County: **KERN**
Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**
Campus #: **031 - ROOSEVELT SCHOOL**
Building #: **014 - ROOM 35**
Inspection Dates: **02/27/2001 To 03/29/2001**

Inspected by: **HAL GOUNDER**
Certification#: **3023**
State: **CA**
Gross Square Ft: **0**

***** INSPECTION RESULTS UNIFIED SAMPLING AREA - 001 *****

Material Category:
MISCELLANEOUS

Location:

Material Description:
NO SUSPECT MATERIAL

Damage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
=====	=====	=====	=====	=====	=====	=====	=====

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material**

MATERIAL QUANTITIES**MANAGEMENT PLAN RECOMMENDATION**

Recommended Response Action:

Priority:

Preventative Measures:

Action Election:


Response Action Schedule

Start Date

Completion Date


Inspector's Comments:

RELOCATABLE BUILDING SERIAL NUMBER: 97-330-102-034A&B




NO SUSPECT MATERIAL


LEGEND



NON-ASBESTOS
VINYL FLOOR TILE



NON-ASBESTOS
CEILING TILES



NON-ASBESTOS
SPRAY / TROWEL
APPLIED MATERIAL



ASBESTOS
CONTAINING
VINYL FLOOR TILE



ASBESTOS
CONTAINING
CEILING TILES



ASBESTOS
CONTAINING
SPRAY / TROWEL
APPLIED MATERIAL

SISC

SAFETY & LOSS CONTROL

INSPECTION
DATE

02/27 - 03/29/2001

DRAWING
NUMBER

031014

AHERA
COMPLIANCE PROGRAM

060027-031-014
BAKERSFIELD CITY SCHOOL DISTRICT
ROOSEVELT SCHOOL
ROOM 35

SISC - AHERA COMPLIANCE PROGRAMCounty: **KERN**Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**Campus #: **031 - ROOSEVELT SCHOOL**Building #: **015 - ROOM 34**Inspection Dates: **02/27/2001 To 03/29/2001**Inspected by: **HAL GOUNDER**Certification#: **3023**State: **CA**Gross Square Ft: **0****INSPECTION RESULTS UNIFIED SAMPLING AREA - 001**Material Category:
MISCELLANEOUS

Location:

Material Description:
NO SUSPECT MATERIALDamage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
=====	=====	=====	=====	=====	=====	=====	=====

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material****MATERIAL QUANTITIES****MANAGEMENT PLAN RECOMMENDATION**

Recommended Response Action:

Priority:

Preventative Measures:


Action Election:

Response Action Schedule

Start Date


Completion Date

Inspector's Comments:




NO SUSPECT MATERIAL


LEGEND



NON-ASBESTOS
VINYL FLOOR TILE



NON-ASBESTOS
CEILING TILES



NON-ASBESTOS
SPRAY / TROWEL
APPLIED MATERIAL



ASBESTOS
CONTAINING
VINYL FLOOR TILE



ASBESTOS
CONTAINING
CEILING TILES



ASBESTOS
CONTAINING
SPRAY / TROWEL
APPLIED MATERIAL

SISC

SAFETY & LOSS CONTROL

INSPECTION
DATE

02/27 - 03/29/2001

DRAWING
NUMBER

031015

AHERA
COMPLIANCE PROGRAM

060027-031-015
BAKERSFIELD CITY SCHOOL DISTRICT
ROOSEVELT SCHOOL
ROOM 34

SISC - AHERA COMPLIANCE PROGRAMCounty: **KERN**Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**Campus #: **031 - ROOSEVELT SCHOOL**Building #: **016 - ROOM 33**Inspection Dates: **02/27/2001 To 03/29/2001**Inspected by: **HAL GOUNDER**Certification#: **3023**State: **CA**Gross Square Ft: **0****INSPECTION RESULTS UNIFIED SAMPLING AREA - 001**Material Category:
MISCELLANEOUS

Location:

Material Description:
NO SUSPECT MATERIALDamage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
=====	=====	=====	=====	=====	=====	=====	=====

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material****MATERIAL QUANTITIES****MANAGEMENT PLAN RECOMMENDATION**

Recommended Response Action:

Priority:

Preventative Measures:

Action Election:

Response Action Schedule

Start Date


Completion Date

Inspector's Comments:

(

(

(



NO SUSPECT MATERIAL

LEGEND



NON-ASBESTOS
VINYL FLOOR TILE



NON-ASBESTOS
CEILING TILES



NON-ASBESTOS
SPRAY / TROWEL
APPLIED MATERIAL



ASBESTOS
CONTAINING
VINYL FLOOR TILE



ASBESTOS
CONTAINING
CEILING TILES



ASBESTOS
CONTAINING
SPRAY / TROWEL
APPLIED MATERIAL

SISC

SAFETY & LOSS CONTROL

INSPECTION
DATE

02/27 - 03/29/2001

DRAWING
NUMBER

031016

AHERA
COMPLIANCE PROGRAM

060027-031-016

BAKERSFIELD CITY SCHOOL DISTRICT
ROOSEVELT SCHOOL

ROOM 33

SISC - AHERA COMPLIANCE PROGRAMCounty: **KERN**Project #: **060027 - BAKERSFIELD CITY SCHOOL DISTRICT**Campus #: **031 - ROOSEVELT SCHOOL**Building #: **017 - ROOM 36**Inspection Dates: **02/27/2001 To 03/29/2001**Inspected by: **HAL GOUNDER**Certification#: **3023**State: **CA**Gross Square Ft: **960******* INSPECTION RESULTS UNIFIED SAMPLING AREA - 001 *****Material Category:
MISCELLANEOUSLocation:
PRE-KMaterial Description:
NO SUSPECT MATERIALDamage Category:
N/A

Reason for Damage Category:

Potential for Disturbance:

Sample#	% Asb	Date	Inspector	Sample#	% Asb	Date	Inspector
=====	=====	=====	=====	=====	=====	=====	=====

Asbestos: **N** Friable: **N/A** ACM Status: **No Suspect Material****MATERIAL QUANTITIES****MANAGEMENT PLAN RECOMMENDATION**

Recommended Response Action:

Priority:

Preventative Measures:

Action Election:

Response Action Schedule

Start Date

Completion Date


Inspector's Comments:

RELOCATABLE BUILDING SERIAL NUMBER: 97-330-102-033A&B

(


(

(




NO SUSPECT MATERIAL

LEGEND



NON-ASBESTOS
VINYL FLOOR TILE



NON-ASBESTOS
CEILING TILES



NON-ASBESTOS
SPRAY / TROWEL
APPLIED MATERIAL



ASBESTOS
CONTAINING
VINYL FLOOR TILE



ASBESTOS
CONTAINING
CEILING TILES



ASBESTOS
CONTAINING
SPRAY / TROWEL
APPLIED MATERIAL

SISC

SAFETY & LOSS CONTROL

INSPECTION
DATE

02/27 - 03/29/2001

DRAWING
NUMBER

031017

AHERA
COMPLIANCE PROGRAM

060027-031-017
BAKERSFIELD CITY SCHOOL DISTRICT
ROOSEVELT SCHOOL
ROOM 36