BAKERSFIELD CITY SCHOOL DISTRICT

David West Director Department of Stores and Purchasing westd@bcsd.com EDUCATION CENTER, 1300 BAKER STREET BAKERSFIELD, CALIFORNIA 93305-4326 (661) 631-4712 FAX: (661) 861-9907



Addendum No. One (2) To BCSD BID #23-12-03, HVAC ELECTRICAL EQUIPMENT BID

Bid Date: Wednesday, January 24, 2024 @ 11:00 A.M. Bid Date Revised: Wednesday, January 31, 2024 @ 11:00 A.M.



Issued by:

Department of Stores and Purchasing David West, Director Bakersfield City School District January 25, 2024

Clarifications

- 1. The District is adding an additional school site to the bid, Roosevelt Elementary School. Please see updated drawings and new bid form under "Active Bid": https://www.bcsd.com/Page/435
- 2. On the new Bid Form, Line Item #28 for Roosevelt Elementary School, "Distribution Board (DP) 800A" can either be provided as a switchboard or a panel board.
- 3. Pioneer Single Line Diagram, drawing Sheet E-000, has been removed and replaced with revised drawing Sheet E-000.

Questions/Answers for Mt. Vernon, Pioneer, Horace Mann & Fremont

4. **Question:** Please provide the fault current (AIC) rating for all panels.

Answer: Panel schedules show 10KAIC for panels and breakers.

5. Question: Is series rating allowed?

Answer: Series rating is permitted. Switchboard should be braced for 30KA. Main should be 30KAIC.

Questions/Answers for Roosevelt

6. Question: Please provide the fault current (AIC) rating for all panels.

Answer: The main switchboard rating is noted on the single line diagram

7. **Question:** Is series rating allowed?

Answer: Series rated fault current rating for panelboards and distribution boards is acceptable. All equipment shall be of same manufacturer.

TO BE INCLUDED WITH BID:

I (we) acknowledge receipt of the following addenda to the specifications, all of the provisions and requirement of which have been taken into consideration on the preparation of the foregoing bid:

Addendun	n No. 2 (Initials)	 	
Company:			
Ву:			
Title:			
Address:			
-			
Telephone	::		