

# Bakersfield City School District

# Maintenance, Operations and Facilities Department

1501 Feliz Drive Bakersfield, California 93307 Office (661) 631-5883 Fax (661) 834-9986

Michael Hamlin, Director hamlinm@bcsd.com Leonard Zasoski, Assistant Director zasoskil@bcsd.com Daniel Wastaferro, Assistant Director wastaferrod@bcsd.com Jason Sitton, Assistant Director sittoni@bcsd.com

### September 1, 2023

- To: Interested C-10 Contractors
- Re: Fremont ES (10) Temp Classrooms Electrical, Fire Alarm & Communications (Project #22213.TR-26)

### Bid Addendum #2

#### **Clarifications:**

1. Refer to Work Scope Summary, BP-01 Electrical, Fire Alarm & Communications. **ADD** the following work scope note #25. *Provide and allowance of* **\$25,000.00** *for classroom intercom speakers and associated work not indicated on the drawings, labor to pull District provided fiber to the closest IDF Cabinet, labor to terminate fiber, and for any unforeseen items. This allowance shall be listed in the Schedule of Values and shall be tracked on a Time and Material basis. Profit and overhead on top of this Time and Material work will not be allowed. This allowance amount is to be used as directed by the District and is not to be used to fulfill obligations under this contract. All costs used against this allowance must be agreed to by the District before work is started. All unused portions of this allowance shall be credited back to the owner in the form of a deductive change order at 100% of the remaining value. This allowance shall be included in the base bid.* 

#### Pre-Bid RFIs:

#### Please see the Revised Pre-Bid RFI Response below.

1. Is the low voltage cabling (excluding fire alarm) to be owner furnished and installed?

Response: Bakersfield City School District -9/1/23 – District will provide (1) IDF Cabinet for the (10) temp classrooms, 8 CAT6 (Wall Locations) and 2 CAT6A (1 ceiling location for WAP) per room, data jacks, plates, WAPs, and misc. communications materials. Contractor to provide and install sleeves through classrooms, rough in pathways and boxes, labor to install IDF Cabinets labor, electrical dedicated circuit for IDF, labor to pull cabling and terminate for a planned (10) cables per classroom. Exact location of IDF cabinet and data outlets to be determined with District.

## Please date, sign and return this form via email to Cindi Canfield at canfieldc@bcsd.com

Date Print Name

Signature

Print Company Name

Sincerely,

Daniel Wastaferro Assistant Director II Maintenance, Operations and Facilities Bakersfield City School District