



FLEWELLING & MOODY  
architects for education

HEADQUARTERS OFFICE:  
1525 Main Street, Suite 100  
Berkeley, CA 94702  
Tel: 415.863.4444  
Fax: 415.863.4447  
Email: fmo@flemo.com

ANTIOPE VALLEY OFFICE:  
1000 Main Street, Suite 100  
Antiope, CA 94509  
Tel: 925.762.1100  
Fax: 925.762.1101  
Email: fmo@flemo.com



IDENTIFICATION STAMP  
DIV OF THE STATE ARCHITECT  
APPROX 11.2.8.17  
DATE: 11.2.8.17

Drawn by: AC  
Checked by: PH  
Date: 11-14-2009

AWARDSFIELD CITY SCHOOL DISTRICT  
MODERNIZATION PROJECT AT  
EVERGREEN ELEMENTARY SCHOOL  
2600 ROSE WARE DRIVE  
BERKELEY, CA 94704

PANEL SCHEDULES

Job No. 1884300  
Date: 1-14-2009  
E-0.6

PANEL "H1" BUS: 400A  
SERVICE: 120/200V 3Ø 4W  
SQUARE D NODD PANELBOARD IPAC  
MAIN BRK: 300A  
LOC.: SEE PLAN  
MFG.: FLUSH  
REMARKS: ROOM 103 HVAC, ROOM 104 HVAC, ROOM 105 HVAC, ROOM 106 HVAC, ROOM 107 HVAC, ROOM 108 HVAC, ROOM 109 HVAC, TRANSFORMER 1.1

PANEL "H1" BUS: 400A  
SERVICE: 120/200V 3Ø 4W  
SQUARE D NODD PANELBOARD IPAC  
MAIN BRK: 300A  
LOC.: SEE PLAN  
MFG.: FLUSH  
REMARKS: ROOM 103 SOUTH, ROOM 104 SOUTH, ROOM 105 SOUTH, ROOM 106 SOUTH, ROOM 107 SOUTH, ROOM 108 SOUTH, ROOM 109 SOUTH, TRANSFORMER 1.1

PANEL "H2" BUS: 400A  
SERVICE: 277/480V 3Ø 4W  
SQUARE D NODD PANELBOARD IPAC  
MAIN BRK: 400A  
LOC.: SEE PLAN  
MFG.: FLUSH  
REMARKS: EXTERIOR, EXTERIOR, EXTERIOR, TRANSFORMER 1.2

PANEL "H3" BUS: 400A  
SERVICE: 277/480V 3Ø 4W  
SQUARE D NODD PANELBOARD IPAC  
MAIN BRK: 400A  
LOC.: SEE PLAN  
MFG.: FLUSH  
REMARKS: ROOM 110 HVAC, ROOM 111 HVAC, ROOM 112 HVAC, ROOM 113 HVAC, ROOM 114 HVAC, ROOM 115 HVAC, TRANSFORMER 1.3

PANEL "H1" BUS: 400A  
SERVICE: 120/200V 3Ø 4W  
SQUARE D NODD PANELBOARD IPAC  
MAIN BRK: 300A  
LOC.: SEE PLAN  
MFG.: FLUSH  
REMARKS: ROOM 103, ROOM 104, ROOM 105, ROOM 106, ROOM 107, ROOM 108, ROOM 109, TRANSFORMER 1.1

PANEL "H1" BUS: 400A  
SERVICE: 120/200V 3Ø 4W  
SQUARE D NODD PANELBOARD IPAC  
MAIN BRK: 300A  
LOC.: SEE PLAN  
MFG.: FLUSH  
REMARKS: ROOM 103 SOUTH, ROOM 104 SOUTH, ROOM 105 SOUTH, ROOM 106 SOUTH, ROOM 107 SOUTH, ROOM 108 SOUTH, ROOM 109 SOUTH, TRANSFORMER 1.1

PANEL "H2" BUS: 400A  
SERVICE: 277/480V 3Ø 4W  
SQUARE D NODD PANELBOARD IPAC  
MAIN BRK: 400A  
LOC.: SEE PLAN  
MFG.: FLUSH  
REMARKS: EXTERIOR, EXTERIOR, EXTERIOR, TRANSFORMER 1.2

PANEL "H2A" BUS: 225A  
SERVICE: 277/480V 3Ø 4W  
SQUARE D NODD PANELBOARD IPAC  
MAIN BRK: 200A  
LOC.: SEE PLAN  
MFG.: FLUSH  
REMARKS: ROOM 107A, ROOM 108A, ROOM 109A, TRANSFORMER 1.2A

PANEL "H1" BUS: 400A  
SERVICE: 120/200V 3Ø 4W  
SQUARE D NODD PANELBOARD IPAC  
MAIN BRK: 300A  
LOC.: SEE PLAN  
MFG.: FLUSH  
REMARKS: ROOM 103, ROOM 104, ROOM 105, ROOM 106, ROOM 107, ROOM 108, ROOM 109, TRANSFORMER 1.1

PANEL "H1" BUS: 400A  
SERVICE: 120/200V 3Ø 4W  
SQUARE D NODD PANELBOARD IPAC  
MAIN BRK: 300A  
LOC.: SEE PLAN  
MFG.: FLUSH  
REMARKS: ROOM 103 SOUTH, ROOM 104 SOUTH, ROOM 105 SOUTH, ROOM 106 SOUTH, ROOM 107 SOUTH, ROOM 108 SOUTH, ROOM 109 SOUTH, TRANSFORMER 1.1

PANEL "H2" BUS: 400A  
SERVICE: 277/480V 3Ø 4W  
SQUARE D NODD PANELBOARD IPAC  
MAIN BRK: 400A  
LOC.: SEE PLAN  
MFG.: FLUSH  
REMARKS: EXTERIOR, EXTERIOR, EXTERIOR, TRANSFORMER 1.2

PANEL "H2A" BUS: 225A  
SERVICE: 277/480V 3Ø 4W  
SQUARE D NODD PANELBOARD IPAC  
MAIN BRK: 200A  
LOC.: SEE PLAN  
MFG.: FLUSH  
REMARKS: ROOM 107A, ROOM 108A, ROOM 109A, TRANSFORMER 1.2A