



Bakersfield

5500 ming, overnue, suite 450, bakersfield, ca 93309
601.356.4300
for: 661.856.4311


San Jose
300
408.624.0341
for: 408.624.0341

San Luis Obispo
4113 bond street, suite 3-b
san luis obispo, ca 93401
for: 805.545.9594




Oakland
300 frank square plaza, suite 300
510.891.6070
for: 510.891.0574

Principal Architects
446 W. Fairbrook Ave., Suite 106
Fresno, California 93711
(559) 452-4490 / (559) 452-4494 fax
James W. Gordon, Electrical Engineer
E.E. #5101



WENSTRA ENGINEERING
446 W. Fairbrook Ave., Suite 106
Fresno, California 93711
(559) 452-4490 / (559) 452-4494 fax
James W. Gordon, Electrical Engineer
E.E. #5101



MODERNIZATION FOR
COLONEL HOWARD NICHOLS
SCHOOL
3401 RENEGADE AVE.
BAKERSFIELD, CA 93306
BAKERSFIELD CITY
SCHOOL DISTRICT

**BUILDING 300
POWER / SIGNAL
FLOOR PLAN**

Version Date: 02-127
Job No.: 06/24/03
date: 06/24/03
drawn by: T.A.
chkd by: D.G.
© copyright 2003

Version Name:
2.31B

KEYNOTES

NOTE: KEYNOTES IN THIS LIST MAY NOT NECESSARILY OCCUR ON THIS SHEET.

- 1 INSTALL WIREMOLD # 5400 WITH OUTLETS AT 30" O.C. COORDINATE MFG. HEIGHT WITH ARCHITECT'S ELEVATIONS.
- 2 REPLACE EXISTING EXTERIOR DOWNLIGHT. USE RETROFIT KIT FUTURE TYPE "C".
- 3 REPLACE EXISTING WALL BRACKET FIXTURE. USE FIXTURE TYPE "C".
- 4 REPLACE EXISTING FIXTURES. USE FIXTURES TYPE "C".
- 5 DISCONNECT AND REMOVE EXISTING 2x4 SURFACE METAL SIDED FIXTURES. REMOVE (3) HOME RUN AS APPLICABLE.
- 6 REPLACE EXISTING FIXTURE WITH NEW FIXTURE TYPE "C". EXISTING FIXTURE TO REMAIN.
- 7 EXISTING 2x4 SURFACE METAL SIDED FIXTURES WITH (2) 40W T-8 LAMPS. REPLACE LAMPS WITH (2) T8 LAMPS. ELECTRONIC BALLAST. REPLACE LENS WITH KSH K12.125 ACRYLIC LENS.
- 8 DISCONNECT AND REMOVE EXISTING FIXTURES.
- 9 WIREMOLD # 5400 RISER UP TO CEILING.
- 10 REPLACE (E) PANEL "C" NEW PANEL SHALL HAVE (4) 20/1 BREAKERS TOOK BUS USER SQUARE TOP NOSPOT (E) OR EQUAL. RECONNECT (E) CIRCUITS AND FEEDER.
- 11

