


TO POWER POLE LOCATED IN FT. KENNEDY OF MAIN SWITCHBOARD

NOTE: CONDUIT RIGID ON FLOOR OR OVERHEAD. 100 FT. PORTION OF MAIN SWICH. VENTILY EXACT LOCATION.

NOTE: REFER TO SHEET E-100 FOR TYPE USE. NEOPRENE JACKET MUST BE USED IN SPACES OF CONDUIT.

NOTE: FURNITURE SHALL BE ALL FURNITURE NOT MOUNTING ON CONDUIT OR BE SUSPENDED 1/8" OR BE ON INCONVERTIBLE BACKING.

NOTE: SEE TYPICAL PANEL PLAN FOR EXACT LOCATION OF OUTLETS.



SCALE 1/8" = 1'-0"

ELECTRICAL SYMBOLS

- CEILING OUTLET
- INDICATES FIXTURE TYPE
- BRACKET OUTLET
- RECESSED CEILING OUTLET
- EXIT LIGHT
- SPOT LIGHT
- YARD OR HOOD LIGHT
- DUPLEX COAK OUTLET
- FLOOR OUTLET - WATER TIGHT
- SPECIAL PURPOSE OUTLET
- MOTOR OUTLET - 1Ø - 3Ø
- MASTER CLOCK - SECONDARY CLOCK
- BELL
- HORN - SINGLE - DOUBLE
- BUZZER
- BREAK GLASS STATION
- PUBLIC TELEPHONE OUTLET
- LOCAL SWITCHES
- 3-WAY
- 4-WAY
- WITH PILOT
- MOTOR SWITCHER
- DISCONNECT SWITCH
- LIGHTING PANEL
- POWER PANEL
- SIGNAL CABINET
- JUNCTION BOX (WITH SQUARE TOP - LARGER THAN 4" X 4" X 2")
- HOME RUN - PER DEVICES
- CIRCUIT NUMBER & PANEL
- 3/4" CONDUIT RUN CONCEALED IN WALL OR CEILING. CROSS MARKS INDICATE NUMBER OF 1/2" WIRES. OTHER SIZE CONDUIT & WIRES SO MARKED.
- 3/4" CONDUIT RUN UNDERGROUND ON FLOOR BELOW. MARKED AS ABOVE.

NOTE: ALL UNDERGROUND SERVICE FEEDER CONDUITS SHALL BE TYPE USE STEEL. CONDUIT UNDER GROUND MAY BE RINO STEEL OR TYPE USE STEEL. CONDUIT UNDER GROUND SHALL BE TYPE USE STEEL. ALL UNDERGROUND SERVICE FEEDER CONDUITS SHALL BE TYPE USE STEEL.

DIVISION OF ARCHITECTURE

STATE OF CALIFORNIA - DEPARTMENT OF PUBLIC WORKS
DIVISION OF ARCHITECTURE
18096 APPROVED DEC 22 1958
APPROVED BY: *M. W. Sullivan*
REGISTERED ARCHITECT

BOARD OF EDUCATION

Paul R. Thompson
11/14/58

ELECTRICAL

KEY PLAN
MILLER DRIVE SCHOOL

WHITNEY BIGGAR ARCHITECT
MEMBER AMERICAN INSTITUTE OF ARCHITECTS
3601 STOCKDALE HIGHWAY
BAKERSFIELD, CALIFORNIA
29285 REGISTRATION C-11128

PROJECT No. 18
DRAWN BY:
CHECKED BY:
DATE 11/24/58
SHEET F-1
OF 73