

**ADDENDUM NO. 1
PROJECT MANUAL**

**PROJECT: 5566
August 31, 2023**

**WAYSIDE ELEMENTARY SCHOOL
5 TEMPORARY CLASSROOMS
BACKERSFIELD CITY SCHOOL DISTRICT**

DSA APP# 03-123013



This Addendum and Addendum drawings form a part of the Contract Documents. It modifies the original Project Manual and Drawings. Bidders are required to acknowledge receipt of this Addendum in the space provided in the Bid Form. Failure to acknowledge receipt of each addendum may subject bidder to disqualification.

DRAWINGS

ELECTRICAL

1-01 Additive alternate Bid #1 The contractor shall purchase all the electrical equipment only identified with a delta 'EB' in the attached Equipment Bid Package dated 2/17/23, DSA App. #03-122531, noted as EXHIBIT - 1 and comprised of the following sheets:

E1.00 SITE ELECTRICAL PLAN
E1.01 ENLARGED SITE ELECTRICAL PLAN
E2.11 NEW POWER PLANS – BUILDINGS D, E, & CHILLER YARD
E4.00 ONE LINE DIAGRAM - DEMO
E4.01 ONE LINE DIAGRAM
E4.02 PANELS SCHEDULES

1-02 SHEET E1.00: Route 2-inch conduit from chiller yard to the 17 x 30 pullbox such that it doesn't conflict with future HVAC replacement electrical distribution conduits – see reference drawing 5526 sheet E1.01 DSA #03-122531. Conduit run and pullbox should move to the east to avoid these. Coordinate work with future HVAC Replacement project work areas.

END ADDENDUM NO. 1