

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7120-0410:0165

Page 1 of 1

CATEGORY: 7120 -- ANNUNCIATORS

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Tony Lujan (714) 670-3248 Fax (714) 522-2268
Email: tlujan@hochiki.com

DESIGN: Model *FN-LCD-N Network LCD Annunciator and **Model FN-LCD-S Serial LCD Annunciator. Connects to the control panel via the RS-485 network interface. Employs four Form C relays that are unsupervised. **Up to 16 FN-LCD-S Serial LCD Annunciators can be connected to one control panel. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating, and UL label.

APPROVAL: Listed as annunciator panel for use with listee's separately listed compatible Model FireNet 4127 fire alarm control unit (CSFM Listing No. 7165-0410:159). Refer to listee's Installation Instruction Manual for details.

NOTE:

*Recert 4-12-2007 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2018**

Listing Expires **June 30, 2019**

Authorized By: **DAVID CASTILLO**, Program Coordinator
Fire Engineering Division