

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

LISTING No. 7165-0410:0180

Page 1 of 1

CATEGORY: 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268  
Contact: Tony Lujan (714) 670-3248 Fax (714) 522-2268  
Email: tlujan@hochiki.com

DESIGN: Models FIRENET PLUS 1127 Series. Analog Addressable Fire Alarm System. May be followed by suffixes -R or -C which represents the color of the panel enclosure, -R for red, -C for charcoal. Non-coded, automatic, manual, local, remote station, central station is with (DACT), waterflow and sprinkler supervisory service. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

FPN-1127-R; Loop Not Expandable, Red  
FPN-1127-C; Loop Not Expandable, Charcoal  
FPN-1127D-R; Loop W/Integrated Dialer, Not Expandable, Red  
FPN-1127D-C; Loop W/Integrated Dialer, Not Expandable, Charcoal  
FPN-1127E-R; Loop Expandable, Red  
FPN-1127E-C; Loop Expandable, Charcoal  
FPN-1127DE-R; Loop W/Integrated Dialer, Expandable, Red  
FPN-1127DE-C; Loop W/Integrated Dialer, Expandable, Charcoal  
FPN-1127-SLC; Loop Expansion Module\*

RATING: 120V, 50 / 60Hz, 2.1A, and 240V, 50 / 60Hz, 1.1A

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating, and UL label.

APPROVAL: Listed as fire alarm control units for use with listed compatible indicating and initiating devices. Also suitable for high rise applications.

These control units generate a distinctive temporal pattern (Temporal Pattern Fire Alarm Evacuation) for total evacuation in accordance with NFPA 72, 2002 Edition. This control unit meets the requirements of UL Standard 864, 9th Edition.

NOTE: 1. For **Fire Alarm Verification Feature (delay of fire alarm signal)**, the maximum Retard/Reset/Restart period shall not exceed 30 seconds.

XLF: 7165-1714:0115

\*Rev. 11/26/14 jp



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2018**

Listing Expires **June 30, 2019**

Authorized By: **DAVID CASTILLO**, Program Coordinator  
Fire Engineering Division