

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7270-0410:0203

Page 1 of 1

**CATEGORY:** 7270 -- HEAT DETECTOR

**LISTEE:** Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268  
Contact: Tony Lujan (714) 670-3248 Fax (714) 522-2268  
Email: tlujan@hochiki.com

**DESIGN:** Model ATJ-EA Analog Addressable Combination 15°F Rate of Rise / 135-194°F Fixed Temperature Heat Detector for use with base Models HSB-NSA-6 or YBN-NSA-4. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 17.0 - 40.7 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model designation, electrical/temperature rating and UL label.

**APPROVAL:** Listed as heat detector for use with separately listed compatible fire alarm control units. Refer to manufacturer's Installation Manual for details.

08-19-13 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2018**

Listing Expires **June 30, 2019**

Authorized By: **DAVID CASTILLO**, Program Coordinator  
Fire Engineering Division