

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 6911-0410:0176 Page 1 of 1

**CATEGORY:** 6911 -- VOICE COMMUNICATION SYSTEMS CONTROL UNITS

**LISTEE:** Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268  
Contact: Tony Lujan (714) 670-3248 Fax (714) 522-2268  
Email: tlujan@hochiki.com

**DESIGN:** Models EVAX 25, -25E, -50, -50E, -100, -100E, -150, -150E, -200, -200E audio adjunct system. These units are intended to be used in conjunction with a listed electrically compatible fire alarm control unit to provide voice communication, paging, evacuation tone signals, and voice alarm signals with voice override. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** Input: 24-32 VAC/DC, Standby: 24 VDC, 7 Ah Battery

**INSTALLATION:** In accordance with listee's printed installation instructions, wiring diagram, applicable codes and ordinances and in a manner which is acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as a voice/tone communication/evacuation/relocation/audio adjunct system for use with separately listed electrically compatible fire alarm speakers and control units. Supervision is dependent upon the fire alarm control panel. Refer to the control panel's listing and installation instructions for proper configurations. Suitable for high rise applications when used in conjunction with separately listed fire alarm control units. Refer to listee's Installation Instruction Manual for details.

**XLF:** 6912-1446:0100

8-28-2008 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2018**

Listing Expires **June 30, 2019**

Authorized By: **DAVID CASTILLO**, Program Coordinator  
Fire Engineering Division