



- ### KEY NOTES
- TS 2" x 2" x 14ga
 - TS 1 1/2" x 1 1/2" x 14ga (Ty = 38 KSI)
 - TS 1 1/4" x 1 1/4" x 14ga (Ty = 38 KSI)
 - TS 1" x 1" x 16ga WHITECHAIN GUARD
 - 2 x 8 PT SILL PLATE
 - 2 x 2 HAULER W/16d @ 12" OC
 - 2 x 4 HW HEADER BY DISTRICT
 - 6" x 10ga CONTINUOUS PLATE W/ #14 @ 2" TEK SCREWS @ 8" OC INTO WOOD OR FOUNDATION BLOCKS OR #14 @ 2" TEK SCREWS INTO METAL W/ 9" OC
 - 2" x 4" x 12ga BASE PLATE W/2-1/4" x 1" LAGS
 - 6" x 10" x 12ga BASE PLATE @ RAMP TOE
 - LOWER LANDING BY DISTRICT
 - SHORING: PLYWOOD TO MATCH BUILDING SIDING, PLACE ALL EDGES AT LEAST W/2" @ 8" OC EDGES AND 1" @ 8" FIELD. AT EDGE CONNECTION TO F.S. USE #14 x 2" TEK SCREWS @ 9" OC
 - 12ga METAL DECK: NON-SLIP SURFACE. DESIGN COEFFICIENT OF FRICTION GREATER THAN EX. MAINTAINABLE FOR 1 YR EXISTING BUILDING.
 - CAULKING
 - 28 ga FLASHING
 - 3/8" dia x 2" LONG HD W/NUT & WASHERS
 - RAVE BY DISTRICT
 - RAMP BY MODTECH
 - FLUSH TRANSITION
 - 3" MINIMUM BUILDING GENERATION
 - PROVIDE DRAINAGE FOR WATER FROM DOWNSPOUT FOR THIS CONNECTION. BY DISTRICT
 - FOR LANDING DETAILS AND RAMP ATTACHMENT SEE 12/R1.3
 - PASTEN POSTS W/ 3/8" x THRU BOLT. TYPICAL
 - 6" MINIMUM STRIPS MAX 1" FROM EVERY STAIR nosing. USE CONTRASTING COLOR
 - TS 2 1/2" x 1 1/2" x 8ga ASTM A500 GRADE A

NO.	REVISIONS

Vertical Engineer's Seal
Mechanical Engineer's Seal
Structural Engineer's Seal
Architect's Seal

IDENTIFICATION STAMP
DIV. OF THE STATE ARCHITECT
OFFICE OF REGULATION SERVICES

PC 275

JAN 21 1997
REVISED

MODTECH INC.
2830 BARRETT AVENUE
PERRIS, CALIF. 92572
PH (909) 943-4014
FAX (909) 940-0427

Job Number: PC 275

© MODTECH, INC. 1997

drawn by: [Signature]
checked by: [Signature]
approved by: [Signature]

7/21/94

RAMP/STAIR DETAILS R2.0