

· CLASSROOM UNIT C ·

NOTE! MOUNTING HEIGHT OF TYPE 1 FIXTURES IN CLASSROOMS 8'-0"



· CLASSROOM UNIT D ·

NORTH

· LIGHTING FLOOR PLANS ·

SCALE 1/8"=1'-0"

PANEL "C" SCHEDULE

CIR. NO.	NO. OF OUT.	AMPS	WATTS	AMPS	BREAKER
1	2		1800		60 A.T.P.
2					
3			1800		
4					
5	1		1800		
6					
7			1800		
8					
9					
10	1		1800		
11					
12			1800		
13					
14					
15	1		1800		
16	3		800		
17	2		1800		
18	6				750
19	4		800		
20	5				
21	4		450		
22	4				800
23	4		800		
24	4				
25	4		800		
26	5				600
27	4		800		
28	6				
29	5*		450		
30	2				500
31	2		300		
32	2		180		
33	4 1/2				800
34	2		800		
35					
36			800		
37					
38					800
39			555		
40					
41	1 1/2 HP		555		15 A.S.P.
42	1 1/2 HP		555		15 A.S.P.
43					
44			555		
TOTAL WATTS & AMPS			13600	180	11595

TOTAL: 58 BRKRS @ 208 V 3 Φ 4 W. 106 A 100 A. BUSSING

PANEL - 120/208 V 3 Φ 4 W.



KEY PLAN

BAKERSFIELD CITY SCHOOL DISTRICT
OFFICE OF SUPERINTENDENT
APPROVED BY:
BOARD ORDER NO. 394
RESOLUTION NO.
BOOK 11 PAGE 165
DATE 12-3-53
BOARD SECRETARY
BY

FOSTER K. SAMPSON
ELECTRICAL ENGINEER
816 WEST FIFTH ST. LOS ANGELES
Foster K. Sampson
CERT. REG. NO. 349

STATE DIVISION OF ARCHITECTURE
STATE OF CALIFORNIA — DEPARTMENT OF PUBLIC WORKS
DIVISION OF ARCHITECTURE
APPLICATION NO. 11352 APPROVED DEC 2 - 1953
By Harry W. Wade

ARCHITECT'S
DATE 10-8-53

WRIGHT METCALF & PARSONS
ARCHITECTS A.I.A.
2501 F STREET • PHONE 4-9416 • P.O. BOX 3344
BAKERSFIELD, CALIFORNIA

KERN COUNTY SUPT. OF SCHOOLS
APPROVED:
DATE:

BAKERSFIELD CITY SCHOOL DISTRICT
BOARD OF EDUCATION
APPROVED:
DATE:

DATE: 10-8-53
DRAWN BY: RS
CHECKED BY: A.C.W.

LIGHTING FLOOR PLANS. — UNITS "C & D"
JOHN C. FREMONT SCHOOL
FOR THE
BAKERSFIELD CITY SCHOOL DISTRICT
TEXAS STREET, BAKERSFIELD, KERN COUNTY, CALIFORNIA

JOB NO. 289
SHEET NO. E4