



- KEYNOTE** GBC 1998
- 1 MAIN RUNNERS & 4'-0" O.C. MAX. WITH HANGER WIRES SPACED @ 4'-0" O.C. MAX.
 - 2 MAIN RUNNER, AR-STRONGS - T301 HEAVY DUTY
 - 3 CROSS RUNNER, AR-STRONGS - 2L 1526 HEAVY DUTY
 - 4 HALL RUNNER, AR-STRONGS T800 D
 - 5 TYPICAL HANGER WIRE TO BE 12 GA. STEEL WIRE ATTACHED TO STRUCTURE ABOVE AND TO GRID WITH (A) TIGHT TURNS WITHIN 1/2" - SEE DETAIL 4
 - 6 TYPICAL SPLAY WIRE TO BE 12 GA. STEEL WIRE ATTACHED TO STRUCTURE ABOVE AND TO GRID WITH (A) TIGHT TURNS WITHIN 1/2" - SEE DETAIL 4
 - 7 AT END OF ROWS OF RUNNERS, A HANGER WIRE SHALL BE ATTACHED WITHIN 2" OF ANY WALL OR JOIST OR 1/4 LENGTH OF END TEE WHICHEVER IS LEAST
 - 8 VERTICAL WIRES MORE THAN 16" OUT OF PLUMB SHALL HAVE COUNTERBALANCE WIRES INSTALLED.
 - 9 RUNNERS MAY BE ATTACHED TO WALL HOLDINGS AT (C) ADJOINING WALLS. AT OTHER WALLS NO ATTACHMENT. WHERE THERE IS NO ATTACHMENT THERE SHALL BE A 1/2" CLEARANCE BETWEEN END RUNNER AND FACE OF WALL.
 - 10 CEILING AREAS EVERY 144 SQ. FT. OR MORE SHALL HAVE SPLAY WIRES INSTALLED AS INDICATED ON CEILING PLAN. SPLAY WIRES SHALL BE TAUT BUT SHALL NOT DISTORT GRID.
 - 11 ELECTRICIAN SHALL PROVIDE (C) SLACK HANGER WIRES AT OPPOSITE CORNERS OF ALL LIGHT FIXTURES. WIRES SHALL BE ATTACHED TO STRUCTURE ABOVE PER NOTE 5. LIGHT FIXTURES SHALL BE ATTACHED TO CEILING GRID WITH (C) NO SHEET METAL SCREWS.
 - 12 DUCTWORK, IF REQUIRED, SHALL BE RIGIDLY ATTACHED TO STRUCTURE ABOVE AT INTERVALS NOT TO EXCEED 4' AND SHALL NOT BE CLOSER THAN 6" TO ANY WIRE.
 - 13 CEILING REGISTERS, WHEN INDICATED ON PLANS, SHALL BE ATTACHED TO STRUCTURE ABOVE PER NOTE 5.
 - 14 CONT. WALL - 70° ANGLE WITH POP RIVET TO EACH END.
 - 15 1/8" CONTINUOUS HALL ANGLE.
 - 16 6d NAIL @ 16" O.C. INTO BLOCK OR STUD.
 - 17 JIF-S SCREEN MODEL 8-1 (DSA-PA-080) FOR ATTACHMENT OF WIRES TO FURLINS.
 - 18 ROOF JOIST - SEE SHEET 54.0 OR 54.1
 - 19 MODLINE ABOVE
 - 20 CLOSE OFF CROSS TEE - INSERT ONE END OF CROSS TEE INTO MAIN RUNNER WITH SATONET. CUT OPPOSITE END TO FIT. IF LESS THAN 24", INSERT MIN. 20 GA. MIL. STRAP THRU MAIN RUNNER, SECURE TO CROSS TEE W/ (C) NO TEK SCREWS AT EACH END.
 - 21 VERTICAL BRACE - 1/2" STEEL CONDUIT AT SPLAY WIRE LOCATIONS. DRILL (C) 1/8" HOLE THRU CONDUIT @ TOP & (C) @ BOTTOM. ATTACH CONDUIT TO JOIST ABOVE W/ (C) NO TEK SCREWS WITHIN 2" OF CROSS RUNNER.

D. REVISED

IDENTIFICATION STAMP
DIV. OF THE STATE ARCHITECT
OFFICE OF REGULATION SERVICES

04 - 101055

D.S.A.

FORUM 1

STRUCT. ENGINEER

ARCHITECT

CHANGE ORDER

ADDED JIF-S SCREEN

CHECKED BY:

1833 Highway 44, Branch, CA 95924
Phone (916) 788-2317
Fax (916) 788-2327

URORA MODULAR INDUSTRIES

REFLECTED CEILING PLAN (24x40)

IDENTIFICATION STAMP
DIV. OF THE STATE ARCHITECT

A 03 117375
AC / FLS / SS / BY
Date JUN 27 2016

A5.0