



- KEYNOTE** **CBC 1998**
- 1 MAIN RUNNERS @ 4'-0" O.C. MAX. WITH HANGER WIRES SPACED @ 4'-0" O.C. MAX.
  - 2 MAIN RUNNER: ARMSTRONGS - 7301 HEAVY DUTY
  - 3 CROSS RUNNER: ARMSTRONGS - XL 7320 HEAVY DUTY
  - 4 HALL RUNNER: ARMSTRONGS 1800 D
  - 5 TYPICAL HANGER WIRE TO BE 12 GA. STEEL WIRE ATTACHED TO STRUCTURE ABOVE AND TO GRID WITH (3) TIGHT TURNS WITHIN 1/2" - SEE DETAIL 4
  - 6 TYPICAL SPLAY WIRE TO BE 12 GA. STEEL WIRE ATTACHED TO STRUCTURE ABOVE AND TO GRID WITH (4) TIGHT TURNS WITHIN 1/2" - SEE DETAIL 4
  - 7 AT END OF ROWS OF RUNNERS, A HANGER WIRE SHALL BE ATTACHED WITHIN 8" (OF ANY WALL OR SOFFIT) OR 1/4 LENGTH OF END TEE WHICHEVER IS LEAST
  - 8 VERTICAL WIRES MORE THAN 1/6 OUT OF PLUMB SHALL HAVE COUNTERBALANCE WIRES INSTALLED.
  - 9 RUNNERS MAY BE ATTACHED TO WALL HOLDING AT (2) ADJOINING WALLS. AT OTHER WALLS NO ATTACHMENT. WHERE THERE IS NO ATTACHMENT THERE SHALL BE A 1/2" CLEARANCE BETWEEN END RUNNER AND FACE OF WALL.
  - 10 CEILING AREAS EVERY 144 SQ. FT. OR MORE SHALL HAVE SPLAY WIRES INSTALLED AS INDICATED ON CEILING PLAN. SPLAY WIRES SHALL BE TAUT BUT SHALL NOT DISTORT GRID.
  - 11 ELECTRICIAN SHALL PROVIDE (2) SLACK HANGER WIRES AT OPPOSITE CORNERS OF ALL LIGHT FIXTURES. WIRES SHALL BE ATTACHED TO STRUCTURE ABOVE PER NOTE 5. LIGHT FIXTURES SHALL BE ATTACHED TO CEILING GRID WITH (2) #8 SHEET METAL SCREWS.
  - 12 DUCTWORK, IF REQUIRED, SHALL BE RIGIDLY ATTACHED TO STRUCTURE ABOVE AT INTERVALS NOT TO EXCEED 4' AND SHALL NOT BE CLOSER THAN 6" TO ANY WIRE.
  - 13 CEILING REGISTERS, WHEN INDICATED ON PLANS, SHALL BE ATTACHED TO STRUCTURE ABOVE PER NOTE 5.
  - 14 CONT. WALL 7/8" ANGLE WITH POP RIVET TO EACH MEMBER.
  - 15 7/8" CONTINUOUS WALL ANGLE.
  - 16 6d NAIL @ 16" O.C. INTO BLOCK OR STUD.
  - 17 JIF-E SCREEN MODEL JS-1 (DSA-PA-026) FOR ATTACHMENT OF WIRES TO FURLING.
  - 18 ROOF JOIST - SEE SHEET 54.0 OR 54.1
  - 19 MODLINE ABOVE
  - 20 CLOSE OFF CROSS TEE - INSERT ONE END OF CROSS TEE INTO MAIN RUNNER WITH BAYONET. CUT OPPOSITE END TO FIT (IF LESS THAN 24"), INSERT MIN. 20 GA. MTL. STRAP THRU MAIN RUNNER, SECURE TO CROSS TEE W/ (2) #8 TEK SCREWS AT EACH END.
  - 21 VERTICAL BRACE - 1/2" STEEL CONDUIT AT SPLAY WIRE LOCATIONS. DRILL (2) 1/8" HOLE THRU CONDUIT @ TOP & (1) @ BOTTOM. ATTACH CONDUIT TO JOIST ABOVE W/ (2) #8 TEK SCREWS, WITHIN 2" OF CROSS RUNNER.

**D. REVISED**  
IDENTIFICATION STAMP  
DIV. OF THE STATE ARCHITECT  
OFFICE OF REGULATION SERVICES  
04-101055  
DATE APR 03 2007

**D.S.A.**  
PORTION OF  
PROFESSIONAL SEAL  
NO. 3602  
STRUCT. ENGINEER  
LICENSE # 9308-9-30-2006

**ARCHITECT**  
CHANGE ORDER  
A ADDED JIF-E SCREEN  
ALTERNATE

**CHECKED BY**

18333 Rompage Ave. Riverside, CA 92504  
Tel: (951) 789-0288  
Fax: (951) 789-0283

**TURORA-MODULAR INDUSTRIES**

**REFLECTED CEILING PLAN (24x40)**

IDENTIFICATION STAMP  
DIV. OF THE STATE ARCHITECT  
A 03-117375  
Date JUL 27 2016

IDENTIFICATION STAMP  
DIV. OF THE STATE ARCHITECT  
04-115204  
Date APR 11 2016

JUDGE F. SHAW  
PROFESSIONAL SEAL  
NO. 31717  
STATE OF CALIFORNIA

**ASO**