



- KEYNOTE** CBC 1098
- 1 MAIN RUNNERS @ 4'-0" O.C. MAX. WITH HANGER WIRES SPACED @ 4'-0" O.C. MAX.
 - 2 MAIN RUNNER, ARMSTRONG - 1501 HEAVY DUTY
 - 3 CROSS RUNNER, ARMSTRONG - XL 1526 HEAVY DUTY
 - 4 HALL RUNNER, ARMSTRONG 7800 D
 - 5 TYPICAL HANGER WIRE TO BE 12 G. STEEL WIRE ATTACHED TO STRUCTURE ABOVE AND TO GRID WITH (A) TIGHT TURNS WITHIN 1/2" - SEE DETAIL 4
 - 6 TYPICAL SPLAY WIRE TO BE 12 G. STEEL WIRE ATTACHED TO STRUCTURE ABOVE AND TO GRID WITH (A) TIGHT TURNS WITHIN 1/2" - SEE DETAIL 4
 - 7 AT END OF ROWS OF RUNNERS, A HANGER WIRE SHALL BE ATTACHED WITHIN 6" OF ANY WALL OR SOFFIT OR 1/4 LENGTH OF END TEE WHICHEVER IS LEAST
 - 8 VERTICAL WIRES MORE THAN 1/6 OUT OF PLUMB SHALL HAVE COUNTERBALANCE WIRES INSTALLED.
 - 9 RUNNERS MAY BE ATTACHED TO WALL HOLDING AT (2) ADJOINING WALLS, AT OTHER WALLS NO ATTACHMENT; WHERE THERE IS NO ATTACHMENT THERE SHALL BE A 1/2" CLEARANCE BETWEEN END RUNNER AND FACE OF WALL.
 - 10 CEILING AREAS EVERY 144 SQ. FT. OR MORE SHALL HAVE SPLAY WIRES INSTALLED AS INDICATED ON CEILING PLAN. SPLAY WIRES SHALL BE TAUT BUT SHALL NOT DISTORT GRID.
 - 11 ELECTRICIAN SHALL PROVIDE (2) SLACK HANGER WIRES AT OPPOSITE CORNERS OF ALL LIGHT FIXTURES. WIRES SHALL BE ATTACHED TO STRUCTURE ABOVE PER NOTE 5. LIGHT FIXTURES SHALL BE ATTACHED TO CEILING GRID WITH (2) #8 SHEET METAL SCREWS.
 - 12 DUCTWORK, IF REQUIRED, SHALL BE RIGIDLY ATTACHED TO STRUCTURE ABOVE AT INTERVALS NOT TO EXCEED 4' AND SHALL NOT BE CLOSER THAN 6" TO ANY WIRE.
 - 13 CEILING REGISTERS, WHEN INDICATED ON PLANS, SHALL BE ATTACHED TO STRUCTURE ABOVE PER NOTE 5.
 - 14 CORNICE WALL - 78° ANGLE WITH POP RIVET TO EACH FACE.
 - 15 1/8" CONTINUOUS WALL ANGLE.
 - 16 6d NAIL @ 16" O.C. INTO BLOCK OR STUD.
 - 17 S-F-S SCREW MODEL S-1 (DSA-PA-026) FOR ATTACHMENT OF WIRES TO PURLINS
 - 18 ROOF JOIST - SEE SHEET 54.0 OR 54.1
 - 19 MODLINE ABOVE
 - 20 CLOSE OFF CROSS TEE - INSERT ONE END OF CROSS TEE INTO MAIN RUNNER WITH BAYONET CUT OPPOSITE END TO FIT (IF LESS THAN 24") INSERT MIN. 20 G. MET. STRAP THRU MAIN RUNNER, SECURE TO CROSS TEE W/ (2) #8 TEK SCREWS AT EACH END.
 - 21 VERTICAL BRACE - 1/2" STEEL CONDUIT AT SPLAY WIRE LOCATIONS, DRILL (2) 1/8" HOLE THRU CONDUIT @ TOP & (2) @ BOTTOM, TIE TO JOIST ABOVE W/ (2) #8 TEK SCREWS WITHIN 2" OF CROSS RUNNER.

REVISED

IDENTIFICATION STAMP
DIV. OF THE STATE ARCHITECT
OFFICE OF REGULATION SERVICES

04 - 101055

DATE: MAY 03 2016

D.S.A.

PORTION 1
IDENTIFICATION STAMP

NO. 3802

STRUCT. ENGINEER

ARCHITECT

CHANGE ORDER
ADDED JIF-E SCREEN
ALTERNATE

CHECKED BY:

1853 Kuykendall Ave., Brentwood, CA 92004
Tel: (805) 778-0218
Fax: (805) 778-0219

TURORA-MODULAR INDUSTRIES

REFLECTED CEILING PLAN (24x40)

IDENTIFICATION STAMP
DIV. OF THE STATE ARCHITECT

APPD3 116978

AC: FLS
Date: MAY 03 2016

AJ.O

SHEET