



KEY NOTES

- TS 2" x 2" x 14ga
- TS 1 1/2" x 1 1/2" x 14ga (Fy = 36 KSI)
- TS 1 1/4" x 1 1/4" x 14ga (Fy = 36 KSI)
- TS 1" x 1" x 16ga WHEELCHAIR GUIDE
- 2 x 8 FT SILL PLATE
- 2 x 2 HALER W/104 @ 12" OC
- 2 x PW HEADER BY DISTRICT
- 6" x 10ga CONTINUOUS PLATE W/1/4" x 2" TEK SCREWS @ 9" OC INTO WOOD OR TOLERATION BLOCKS OR #14 @ 5" TEK SCREWS INTO METAL W 9" OC
- 2" x 4" x 12ga BASE PLATE W/2-1/4" x 1" LAGS
- 6" x 10" x 12ga BASE PLATE @ RAMP TOE
- LOWER LANDING BY DISTRICT
- EXISTING BUILDING: FINISHING FLOOR TO MATCH BUILDING EDGE BLOCK. ALL EDGES, ATTACH W/4" @ 9" OC EDGES AND 1" OC FIELD. AT EDGE CONNECTION TO U.S. USE #14 x 5" TEK SCREWS @ 9" OC
- 12ga METAL DECK: NON-SLIP SURFACE. DESIGN COEFFICIENT OF FRICTION GREATER THAN 0.8. MAINTAINABLE FOR 1 YR EXISTING BUILDING.
- CALLING
- 26 ga FLASHING
- 3/8" dia x 2" LONG MB W/NUT & WASHERS
- PAVE BY DISTRICT.
- RAMP BY MODTECH
- FLUSH TRANSITION
- 3" MINIMUM BUILDING SEVERATION
- PROVIDE DRAINAGE FOR WATER FROM DOWNSPOUT FOR THE CONNECTION. BY DISTRICT
- FOR LANDING DETAILS AND RAMP ATTACHMENT SEE 12/RT.8
- PASTER POSTS W/ 3/8" x THRU BOLT. TYPICAL
- 3" MINIMUM STUDS MAX 1" FROM EVERY STAIR nosing. USE CONTRASTING COLOR.
- TS 2 1/2" x 1 1/2" x 8ga ASTM A500 GRADE A

REVISIONS

1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		
16		
17		
18		
19		
20		
21		
22		
23		
24		
25		
26		
27		
28		
29		
30		
31		
32		
33		
34		
35		
36		

Electrical Engineer's Seal
 Mechanical Engineer's Seal
 Structural Engineer's Seal
 Architect's Seal

IDENTIFICATION STAMP
 DIV. OF THE STATE ARCHITECT
 OFFICE OF REGULATION SERVICES
 PC 275
 DATE: JUN 21 1997
 REVISED

MODTECH INC.
 2830 BARRETT AVENUE
 PERRIS, CALIF. 92572
 PH (909) 943-4014
 FAX (909) 940-0427

Job Number: PC 275
 © MODTECH, INC. 1997
 Drawn By: FLM
 Checked By: JLM
 Date: 11/94

RAMP/STAIR DETAILS R2.0