



KEY NOTES

- 1 MAIN RUNNERS • 4'-0" W/12GA. HANGER WIRES • END OF EACH RUNNER.
- 2 NOT USED
- 3 NOT USED
- 4 PROVIDE 2-12GA. SLACK WIRES TO HOUSING OF ALL LIGHT FIXTURES AT DIAGONAL CORNERS. WIRES SHALL BE ATTACHED TO STRUCTURE OF LIGHT FIXTURES: 2' X 4' RECESSED, ATTACH FIXTURE TO GRID W/1-#8 SHEET METAL SCREW AT EACH CORNER.
- 5 NOT USED
- 6 CEILING AREAS SHALL HAVE 4-WAY SPLAYS PER DETAIL 1 ON SHEET A7.1 IN LOCATIONS INDICATED ON DRAWING WIRES TAUT BUT NOT TO DISTORT GRID.

T-BAR PART NUMBERS

	APPROXIMATE PA-DIM	APPROXIMATE W/12 GA	W/12 GA
RUNNER	7301	200	DS 26
4" CROSS	7342	1210	DX 422
2" CROSS	7328	1226	DX 216
WALL ANGLE	7800	1420-01	M-7

- 8 REGISTERS SHALL BE POSITIVELY ATTACHED W/4-10GA SHEET METAL SCREWS. (TYP. 1- • EA. CORNER)
- 9 CEILING PANELS: 2 X 4 LAY-IN PANELS. ASTM FLAME SPREAD CLASS 1 (0-25). FLAME SPREAD SMOKE DEVELOPMENT DENSITY LESS THAN 450 (TYP.)

NOTES

- 1. AT THE END OF ROWS OF RUNNERS A 12GA. HANGER WIRE SHALL BE ATTACHED WITHIN 8" OF WALL OR SOFFIT.
- 2. VERTICAL WIRES MORE THAN 1-IN-8 OUT OF PLUMB SHALL HAVE COUNTERBRACING WIRES
- 3. RUNNERS MAY BE ATTACHED TO WALLS OR MOLD AT 2-ADJACENT WALLS. OTHER WALLS NO ATTACHMENT. CLEARANCE OF 1/2" BETWEEN END OF RUNNERS AND FACE OF WALL.
- 4. DUCTWORK SHALL BE RIGIDLY ATTACHED TO BUILDING AND SHALL NOT BE CLOSER THAN 6" TO HANGER WIRES.

LEGEND

- T & T BAR CEILING
- 2' X 4' ELEC. FIXTURE RECESSED
- SUPPLY AIR DIFFUSER
- SPLAY WIRE
- INDICATES FIXED SIDE (SEE DETAIL 7/A7.1)
- INDICATES FREE SIDE (SEE DETAIL 6/A7.1)

IDENTIFICATION STAMP
 DIV. OF THE STATE ARCHITECT
 OFFICE OF REGULATION SERVICES
 DATE JAN 07 1999

REFLECTED CEILING PLAN

24' X 40'

SCALE 1/4"=1'-0"

REVISED

REVISIONS

Electrical Engineer's Seal Mechanical Engineer's Seal Structural Engineer's Seal Architect's Seal Division of the State Architect

PC-200

MODTECH INC.
 2830 BARRETT AVENUE
 PERRIS, CALIF. 92572
 PH (909) 943-4014
 FAX (909) 940-0427

PROJECT NUMBER 2986

© MODTECH, INC. 1997

APP#3 117168

AC / FLS / SS / TN

REFLECTED CEILING PLAN

drawn by 4012-088
 checked by 05 JAN 99
 project no. 2986

A7.0