



SHEET NOTES

- EXISTING FACP 'X', SMOKE DETECTOR, TELEPHONE SWITCH, TELECENTER, AND MDF
- DISCONNECT ELECTRICAL SYSTEMS FROM EXISTING PORTABLE. PULL CONDUCTORS BACK TO SOURCE. INSTALL PULL ROPE AND CAP CONDUITS AT GRADE LEVEL.

GENERAL NOTES

- PROVIDE (3) 1-1/2" C FLEXIBLE CONDUIT NIPPLES BETWEEN SUCCESSIVE PORTABLES TO FACILITATE CABLE INSTALLATION.
- RUN ONE 1/2" COAXIAL CABLE FROM BOOKROOM TO EACH NEW IDF.
- CONTRACTOR MAY USE EXISTING MECHANICAL CHASE TO ROUTE CONDUITS FROM BOOKROOM TO PORTABLES IF THE CHASE HAS ROOM. REFER TO CIVIL PLANS FOR LOCATION.

Ownership of Documents
This document, the ideas and designs incorporated herein, as an instrument of Professional Service is the property of Integrated Designs by SOMAM, Inc. and is not to be used, in whole or in part for any other project without written authorization. © COPYRIGHT 2010

integrated designs by SOMAM, Inc.
ARCHITECTURE - ENGINEERING - INTERIOR DESIGN - CONSTRUCTION MANAGEMENT
6011 N. Fresno, Suite 130 - Fresno, California 93710
Phone (559) 438-0881 Fax (559) 438-0887 E-Mail: design@somam.com
www.integrateddesigns.com

Rev. No.	Date	Description

ELECTRICAL DEMOLITION SITE PLAN

**PIONEER DRIVE ELEMENTARY SCHOOL
5 PERMANENT MODULAR CLASSROOMS**
BAKERSFIELD CITY SCHOOL DISTRICT
4404 PIONEER DRIVE, BAKERSFIELD, CA 93306

Project Name & Address:
Project No.:
Project Date:

Issue Date:
Date:
Designer:
DR:
PC:

DSA Identification Stamp:
FILE #: 15-6
IDENTIFICATION STAMP
DIV. OF THE STATE ARCHITECT
OFFICE OF REGULATION SERVICES
08-113549
AC: [Signature]
DATE: 9-2-2010
TRACKING #: -

Stamp(s):

Job No.: **3862**

Sheet No.: **E2.1**

Release:

BORRELLI AND ASSOCIATES, INC.
CONSULTING ELECTRICAL ENGINEERS
1200 N. EIGHTH AVENUE
FRESNO, CALIFORNIA 93710
PH: 559-253-4158 FAX: 559-253-4334
8449 18127
HTTP://WWW.BORRELLIENGINEERING.COM
E-MAIL: ADMIN@BORRELLIENGINEERING.COM

ELECTRICAL SITE PLAN
SCALE: 1"=30'-0"