

MATERIALS AND WORKMANSHIP

ALL CONTRACTORS SHALL CERTIFY THAT NO ASBESTOS-CONTAINING BUILDING MATERIALS WHICH EXCEED STATE AND FEDERAL MANDATED SAFE ASBESTOS LEVELS HAVE BEEN USED IN THE CONSTRUCTION OF RELOCATABLE FACILITIES.

ALL WORKMEN SHALL BE SKILLED AND QUALIFIED FOR THE WORK WHICH THEY PERFORM. ALL MATERIALS USED, UNLESS OTHERWISE SPECIFIED, SHALL BE NEW AND OF THE TYPES AND GRADES SPECIFIED. THE CONTRACTOR SHALL, IF REQUESTED, FURNISH EVIDENCE SATISFACTORY TO THE ARCHITECT THAT SUCH IS THE CASE.

CONTRACTOR'S CREWS ASSIGNED TO ANY WORK PERFORMED UNDER THIS CONTRACT SHALL INCLUDE ONE COMPETENT AND FULLY EXPERIENCED PERSON DESIGNATED AS THE RESPONSIBLE PERSON IN CHARGE. SUCH PERSON MUST BE IDENTIFIED BY NAME TO THE DISTRICT IN ADVANCE OF ANY WORK. UPON REQUEST, THE CONTRACTOR SHALL PROMPTLY FURNISH TO THE DISTRICT INFORMATION RELATING TO THIS EMPLOYEE'S EXPERIENCE.

WORKMANSHIP SHALL BE EQUAL OR BETTER IN QUALITY TO THAT REQUIRED BY THE CONSTRUCTION TRADES FOR A FINISHED PRODUCT. A QUALITY CONTROL SUPERVISOR, DESIGNATED BY THE MANUFACTURER, SHALL REVIEW ALL WORK IN PROGRESS AND SHALL REVIEW THE FINISHED BUILDING PRIOR TO FINAL INSPECTION TO ASSURE IT IS COMPLETE AND CORRECT. THE QUALITY CONTROL SUPERVISOR SHALL HAVE THE AUTHORITY TO HAVE MATERIALS REPLACED AND WORK REDONE IN ORDER TO CORRECT FAULTY MATERIALS OR WORKMANSHIP.

GENERAL DESIGN REQUIREMENTS:

UP TO (12) APPROXIMATELY 12' x 40' MODULES DESIGNED SO THAT TWO MODULES MAY BE JOINED TOGETHER TO FORM A COMPLETE STRUCTURE TO MAINTAIN A POSITIVE ALIGNMENT OF FLOORS, WALLS, AND ROOF AND TO PERMIT SIMPLE NON-DESTRUCTIVE DETACHMENT FOR FUTURE RELOCATION.

EACH MODULE SHALL BE PERMANENTLY IDENTIFIED WITH AN IMPRINTED (STAMPED NOT ENGRAVED) METAL IDENTIFICATION TAG 3"x1" -1/2" MINIMUM SIZE WITH THE FOLLOWING INFORMATION:

1. MANUFACTURER'S NAME AND BUILDING SERIAL NUMBER.
2. DESIGN WIND LOAD / EXPOSURE
3. DESIGN ROOF LIVE LOAD
4. DESIGN FLOOR LIVE LOAD
5. D.S.A. APPLICATION NUMBER.

2-TAGS PER MODULE ONE ON EXTERIOR AND ONE ON MODULE BEAM AT FRONT OF BUILDING ABOVE CEILING.

EACH MODULE SHALL BE CAPABLE OF RESISTING ALL VERTICAL AND LATERAL LOADS DURING TRANSPORTATION AND RELOCATION. (NORMAL INDUSTRY PRACTICE FOR BRACING MODULES DURING TRANSPORTATION AND RELOCATIONS IS ACCEPTABLE.) WHEN MODULES ARE ASSEMBLED JOINTS SHALL BE SEALED WITH REMOVABLE CLOSING STRIPS OR OTHER METHOD TO PRESENT A FINISHED APPEARANCE AND BE PERMANENTLY WATERPROOF.

EACH MODULE SHALL BE SUFFICIENTLY RIGID TO BE JACKED UP AT THE FRONT AND BACK CORNERS FOR RELOCATION WITHOUT DAMAGE OR THE MODULE SHALL HAVE LIFT LUGS AT FRONT AND BACK LOCATED AS REQUIRED SO THAT THE MODULE MAY BE JACKED UP FOR RELOCATION IN ONE PIECE WITHOUT ADDITIONAL SUPPORTS OF ANY TYPE. EVIDENCE OF EXCESSIVE BOWING DURING THE INSTALLATION OF THE MODULES WHICH, IN THE OPINION OF THE AGENCY ARCHITECT OR STRUCTURAL ENGINEER, CAUSES EXCESSIVE WORKING AT ANY JOINT OR COMPROMISES THE STRUCTURAL INTEGRITY OF THE MODULE SHALL BE SUFFICIENT REASON FOR REJECTION OF THE MODULE.

FINISH AND BASE MATERIALS AT EACH MODULE SHALL TERMINATE AT INTERIOR MODULE JOINTS IN A MANNER TO JOIN FLUSH AND TIGHT WITH SAME MATERIAL IN ADJACENT MODULE SO THE MODULE MAY BE RELOCATED WITH MINIMUM CUTTING AND PATCHING.

MARKERBOARD SPECIFICATIONS

MARKERBOARDS SHALL BE 24 ga. PORCELAIN STEEL FACING SHEET SUITABLE TO ACCEPT DRY ERASE FLET MARKERS. THE FACING SHEET SHALL BE LAMINATED TO PARTICLE BOARD SUBSTRATE WITH A MINIMUM DENSITY OF 45#/cu. ft. THE PANEL SHALL HAVE A FOIL BACKING. THE PANELS SHALL HAVE EXTRUDED ALUMINUM MOLDING AND CHALKRAIL WITH A MINIMUM OF 2-1/8" PROJECTION FROM THE FACE OF PANEL. THREE MAP HOOKS WITH CLIPS PER PANEL SHALL BE PROVIDED. ONE FLAG HOLDER, 1/2" SIZE, SHALL BE PROVIDED FOR EACH CLASSROOM. EACH CLASSROOM SHALL HAVE 2 EACH 4 X 8 PANELS INSTALLED SIDE BY SIDE TO MAKE A 4 X 16 PANEL. CENTERED ON THE LONG WALLS. REFERENCE BRANDS: CHATFIELD-CLARKE Co, Inc. SERIES 500 OR NELSON ADAMS Co. NACO SERIES 60.

NOTE:

| | |
|-------------------------|-------------------------|
| WALL FINISH MATERIAL | PIPE INSULATION |
| FLAME SPREAD MAX = 200 | FLAME SPREAD MAX = 25 |
| SMOKE DENSITY MAX = 450 | SMOKE DENSITY MAX = 450 |
| BUILDING INSULATION | DUCT INSULATION |
| FLAME SPREAD MAX = 25 | FLAME SPREAD MAX = 25 |
| SMOKE DENSITY MAX = 450 | SMOKE DENSITY MAX = 50 |

INTERIOR

1. FLOOR: CARPETS - CLASSROOM SHALL BE CARPETED AS INDICATED ON FLOOR PLAN WITH DIRECT GLUE DOWN TYPE PER STATE OF CALIFORNIA SPECIFICATION 7220-XXX-01, GROUP 1, TYPE A, CLASS 26. COLOR WILL BE SELECTED BY ARCHITECT AFTER AWARD OF BID. THE CARPET DENSITY SHALL BE 4600 MINIMUM. PILE YARN SHALL BE BRANDED NYLON. NO CROSS SEAMS SHALL BE ALLOWED. PILE HEIGHT 1/2" MAX
2. BASE: RESILIENT COVE BASE - BEST QUALITY, MOULDED RUBBER, 1/8" THICK, 4" HIGH, MOULDED TOP SET COVE: PROVIDE PREFORMED BASE FOR SQUARE EXTERNAL CORNERS AND PREFORMED END STOPS WHERE BASE DOES NOT ABUT. SOLID COLOR AS MANUFACTURED BY "JOHNSONITE CO.", FLEXCO, OR EQUAL. APPLY COVE TO COMPLETE PERIMETER OF CLASSROOM.
3. INTERIOR WALLS SHALL BE VINYL COVERED TACKBOARD(U.O.N.) APPLIED IN ONE CONTINUOUS LENGTH FROM FLOOR TO CEILING. THE TACKBOARD SHALL BE INDUSTRIAL INSULATION BOARD MANUFACTURED SPECIFICALLY AS A SUBSTITUTE FOR VINYL COVERED WALL PANELS. THE BOARD SHALL BE ASPHALT FREE, SHALL HAVE AN IRONED-ON COATING AND SHALL HAVE A MINIMUM DENSITY OF 18 LBS. PER FT. THE VINYL COATING SHALL BE MADE OF VIRGIN VINYL CALENDERED BASE COLOR, WEIGHING A MINIMUM OF 8 OZ. PER SQUARE YARD. THE COATING BACKING SHALL BE SHEETING OR NON-WOVEN FABRIC. THE VINYL COATING SHALL BE MECHANICALLY LAMINATED, WITH THE LONG EDGES WRAPPED, TO THE TACKBOARD. TACKBOARD SHALL BE APPLIED OVER 1/2" SHEETROCK OR PLYWOOD SHEATHING. THE VINYL WALL COVERED PANEL SHALL HAVE A CLASS III FLAME SPREAD RATING. THE PANEL SHALL BE APPROVED FOR CLASSROOM USE BY THE CALIFORNIA STATE FIRE MARSHAL. REFERENCE BRAND: VINYL COVERED TACKBOARD AS MANUFACTURED BY CHATFIELD-CLARKE OR COMPARABLE. CARE SHALL BE TAKEN IN MOUNTING THE TACKBOARD SO THAT THE TEXTURE OF ALL PANELS WILL HAVE THE SAME ORIENTATION AND COLOR MATCH.
4. CEILING: SUSPEND T-BAR SYSTEM, SEE SHEET M2 FOR DETAILS ETC. MATERIALS AND INSTALLATION PER CCR 2501.A.5 AND IR 25-2 INCLUSIVE AS APPLICABLE TO CLASSROOMS.

DOORS & WINDOWS

EXTERIOR DOORS: METAL DOORS - 3'-0"x7'-0" HOLLOW METAL DOOR CONSTRUCTION OF 1 SHEET OF 18 GA. GRADE II STEEL ASSEMBLED PER CS242 MIN AND REINFORCED WITH 20 GA. MIN. FILL DOOR SPACES WITH MINERAL WOOL OR OTHER INSULATION. (REINFORCE BOTH FACES FOR CLOSURE) PROVIDE FLUSH TOP ON DOORS. HARDWARE REINFORCEMENT SHALL BE 10 GA. MIN FOR HINGES, DOOR FRAME SHALL BE 16 GA. PRESSED STEEL FRAME ASTM A366 & CS242. HARDWARE REINFORCEMENT SHALL BE 10 GA. PLATE. FRAMES SHALL BE DESIGNED WITH INTEGRAL STOP AND TRIM. PROVIDE (3) ANCHORS PER JAMB PLUS ADJUSTABLE FLOOR ANCHOR.

EXTERIOR WINDOWS: PROVIDE ANODIZED ALUMINUM FRAME 5/8" MINIMUM DUAL PANE WINDOW UNITS, AS SHOWN ON FLOOR PLANS. THE 5/8" DIMENSION IS THE MINIMUM THICKNESS FOR THE DUAL GLAZED WINDOW PANEL CONSISTING OF TWO LIGHTS OF GLASS AND THE AIR SPACE. GLAZING MATERIAL SHALL BE:

EXTERIOR LITE - 3/16" MINIMUM TEMPERED GLASS OR LAMINATED AS - 1 GLASS OF SOLAR GRAY GLARE REDUCING TYPE WITH A LIGHT TRANSMISSION FACTOR OF 45% MAXIMUM.

INTERIOR LITE - 1/8" MINIMUM CLEAR TEMPERED.

MINIMUM AIR SPACE SHALL BE 1/4".

SPACE - BENT OR SEALED CORNER ALUMINUM WITH DESICCANT FILL SEALER - BUTYL PRIMARY SEAL AND POLYSULFIDE OF SILICONE SECONDARY SEAL.

CERTIFICATION - ALL GLAZING TO BE CERTIFIED IN ACCORDANCE WITH ASTM E-773, E-774.

HEADER HEIGHT SHALL BE THE SAME AS THE DOOR. ALL OPERABLE GLASS SHALL HAVE ALUMINUM SCREENS. WINDOWS SHALL NOT BE MOUNTED TO THE EXTERIOR PLYWOOD SURFACE. ALL WINDOWS SHALL MEET THE AIAA GS101-88 VOLUNTARY SPEC. FOR ALUMINUM PRIME WINDOWS AND SLIDING GLASS (ANSI), COMMERCIAL GRADE.

HARDWARE

1. EXTERIOR DOOR
 - A) HINGES: HAGER 4-1/2X4-1/2 BUTTS, BB1279 US260, 1-1/2 PAIR EACH DOOR WITH SET SCREW IN BARREL AND BALL BEARING DESIGN, OR APPROVED EQUAL.
 - B) EXTERIOR LOCKSET: SCHLAGE N070P CORBIN OR YALE OR EQUIVALENT. ALUM. FINISH. OR PANIC BARS/PULL HANDLE PANIC BAR TYPE VON DUPRIN 22L (PULL ON EXT.) OR CORBIN OR YALE OR EQUIVALENT. ALUM. FINISH. PANIC BARS ARE ONLY REQUIRED WHERE THE OCCUPANT LOAD IS 50 OR MORE.
 - C) CLOSER: NORTON 8500DA OR 8500BF SERIES, LCN 1460 DEL SERIES OR EQUAL. MAXIMUM 5 LBS FOR EXTERIOR AND INTERIOR DOORS. THE MAXIMUM EFFORT FOR FIRE DOORS MAY BE INCREASED TO THE MAXIMUM ALLOWED BY THE APPROPRIATE ADMINISTRATIVE AUTHORITY, NOT TO EXCEED 15 LBS. THE SWEEP PERIOD FROM AN OPEN POSITION OF 70 DEGREES SHALL BE AT LEAST 3 SECONDS TO MOVE TO A POINT 3 INCHES FROM THE LATCH, MEASURED TO THE LEADING EDGE OF THE DOOR.
 - D) WEATHERSTRIPPING: ALL EXTERIOR DOORS SHALL BE WEATHERSTRIPPED WITH PEMKO 299D, ULTRA WS007, AT DOOR JAMBS AND HEAD OR EQUAL.
 - E) THRESHOLD: THRESHOLD SHALL BE PEMKO 271 AV 5" ALUMINUM WITH PEMKO 216 AV ULTRA TH042 DOOR BOTTOM.
 - F) DOORSTOP: QUALITY #44, OR EQUAL.
 - D) INTERIOR LOCKSET: SCHLAGE LEVER HANDLE LOCKSET, AS FOLLOWS:

| | |
|-----------------|---------------------------------|
| STUDENT TOILETS | S10A PASSAGE LATCH OR EQUAL |
| OFFICES | S70D CLASSROOM LOCKSET OR EQUAL |
| CUSTODIAL | S80A LOCKSET OR EQUAL |
| PUBLIC TOILETS | S40A PRIVACY LATCHSET OR EQUAL |

FIRE EXTINGUISHER

1. EACH PORTABLE CLASSROOM SHALL BE EQUIPPED WITH PRESSURE TYPE FIRE EXTINGUISHERS WITH 2A10BC UL RATING. TO BE MOUNTED ON THE INTERIOR WALL OF THE BUILDING NEAR THE DOORWAY(S) AT A MAXIMUM HEIGHT OF 4 FEET TO THE MOUNTING BRACKET AND THE BOTTOM OF FE MOUNTED 27" AFF. FIRE EXTINGUISHERS SHALL BE TOTALLY CHARGED AND HAVE A DIAL INDICATING THE STATE OF CHARGE.

ACCESSIBILITY STANDARDS

2007 CALIFORNIA BUILDING CODE (PART 2, TITLE 24, CCR) SEC. 1103B.1 BUILDING ACCESSIBILITY, GENERAL.

THE 2007 CBC REQUIRES THAT BUILDINGS EXCEEDING 10,000 SQUARE FEET ON ANY FLOOR MUST HAVE AN ACCESSIBLE MEANS OF VERTICAL ACCESS VIA RAMP, ELEVATOR, OR LIFT WITHIN 200 FEET OF TRAVEL OF EACH STAIR AND EACH STAIR AND EACH ESCALATOR. TABLE 1115B-1 SUGGESTED DIMENSIONS FOR CHILDREN'S USE.

THE 2007 CBC REQUIRES A 27" MINIMUM DIMENSION FOR LAVATORY/SINK KNEE CLEARANCE, WHICH IS THE DISTANCE FROM THE FINISH FLOOR TO THE UNDERSIDE OF THE LAVATORY/SINK.

SECTION 1115B.3.1 ACCESSIBLE WATER CLOSET COMPARTMENT. THE 2007 CBC REQUIRES AN ACCESSIBLE TOILET STALL TO HAVE A MINIMUM WIDTH OF 60" AND SHALL BE EQUIPPED WITH A DOOR THAT HAS AN AUTOMATIC-CLOSING DEVICE AND SHALL HAVE A CLEAR, UNOBSTRUCTED OPENING WIDTH OF 32 INCHES WHEN LOCATED AT THE END AND 34 INCHES WHEN LOCATED AT THE SIDE WITH THE DOOR POSITIONED AT AN ANGLE OF 90 DEGREES FROM ITS CLOSED POSITION. THE INSIDE AND OUTSIDE OF THE COMPARTMENT DOOR SHALL BE EQUIPPED WITH A LOOP OR U-SHAPED HANDLE IMMEDIATELY BELOW THE LATCH. THE LATCH SHALL BE FLIP-OVER STYLE, SLIDING OR OTHER HARDWARE NOT REQUIRING THE USER TO GRASP OR TWIST. EXCEPT FOR DOOR-OPENING WIDTHS AND DOOR SWINGS, A CLEAR, UNOBSTRUCTED ACCESS OF NOT LESS THAN 44 INCHES SHALL BE PROVIDED TO THE WATER CLOSET COMPARTMENTS DESIGNED FOR USE BY PERSONS WITH DISABILITIES.

SECTION 1115B.4.4.4. WATER CONTROLS THE 2007 CBC REQUIRES THAT THE FORCE TO OPERATE A WATER CONTROL (VALVE) FOR AN ACCESSIBLE SHOWER SHALL NOT EXCEED 5LBS. MAXIMUM FORCE (PULL).

SECTION 1117B.5 SIGNS AND IDENTIFICATION (ALSO REFER TO SECTIONS 1115B.6, 1116B, 1007.6.5 1007.7, 1008.1.8.6, 1011.3, 1020.1.5 & 1020.1.6.1-5)

THE 2007 CBC MAKES SEVERAL GENERAL DESIGN CHANGES AND CLARIFICATIONS TO SIGNAGE.

*ALL GROUND FLOOR EXIT DOOR SHALL HAVE TACTILE EXIT SIGNAGE.

*AT STAIRS, EACH FLOOR SHALL RECEIVE TACTILE "STAIR LEVEL" SIGNAGE IN ADDITION TO SPECIAL TACTILE AT THE EXIT DISCHARGE LEVEL.

*EACH EXIT DOOR THAT LEADS TO A GRADE LEVEL EXIT BY MEANS OF A STAIRWAY SHALL HAVE TACTILE EXIT SIGNAGE.

*EACH EXIT ACCESS DOOR TO A CORRIDOR OR HALLWAY THAT IS REQUIRED TO HAVE A VISUAL EXIT SIGN SHALL BE IDENTIFIED BY TACTILE EXIT SIGNAGE.

SECTION 1129B ACCESSIBLE PARKING REQUIRED.

THE 2007 CBC REQUIRES THE WORDS "NO PARKING", IN 12" HEIGHT WHITE LETTERS, TO BE PAINTED ON THE PAVEMENT WITHIN ALL PARKING SPACE ACCESS AISLES. VAN PARKING ACCESS AISLES SHALL BE PLACED ON THE PASSENGER SIDE OF THE VEHICLE. RAMPS MAY NOT ENCRoACH INTO ANY REQUIRED ACCESS AISLE. PARKING SPACE ACCESS AISLES SHALL NOT EXCEED 2% SLOPE IN ANY DIRECTION.

*EXISTING SITES: AT EXISTING SITES, ANY RAMP WHICH EXCEEDS A 2% SLOPE ACCESS AISLES FOR ACCESSIBLE PARKING SPACES PER CBCS SECTION 1129B, MAY REQUIRED REMOVAL AND REDESIGN PER THE PATH OF TRAVEL (POT) PROVISIONS OF CBCS SECTION 1134B, IN ORDER TO APPROVE THE BUILDING PLACEMENT.

SECTION 1133B.2.5 CLOSER EFFORT TO OPERATE DOORS. THE 2007 CBC REQUIRES THAT THE EFFORT TO OPEN AN EXTERIOR DOOR SHALL NOT EXCEED 5 POUNDS (PULL).

THE 2007 CBC REQUIRES THAT THE SWEEP PERIOD OF ACCESSIBLE DOORS SHALL BE 3 SECONDS MAXIMUM, BASED ON AN OPEN DOOR POSITION OF 70 DEGREES (FROM CLOSED), TO A DOOR POSITION OF 3" FROM THE LATCH.

SECTIONS 1133B.2.4.5 & 1133B.2.5.3 RECESSED DOORS. THE 2007 CBC REQUIRES THAT DOORS RECESSED 8" OR MORE SHALL HAVE STRIKE EDGE CLEARANCES IN ACCORDANCE WITH FIGURE 11B-33 (A).

SECTION 1133B.4.2.4 HANDRAIL ORIENTATION. THE 2007 CBC SPECIFIES THAT AT LEAST ONE HANDRAIL SHALL BE PARALLEL TO THE DIRECTION OF THE STAIR RUN, AND PERPENDICULAR TO THE EDGE OF THE STAIR NOSING.

SECTION 1133B.5.2 RAMP WIDTH: MINIMUM 48" CLEAR AT OCCUPANT LOAD 300 OR LESS, 60" CLEAR AT OCCUPANT LOAD MORE THAN 300. RADIUS MINIMUM OF 0.125"

THE 2007 CBC REQUIRES THAT SIGN EDGES LESS THAN 80" ABOVE THE FINISHED FLOOR MUST CONTAIN ROUNDED OR EASED RADIUS MINIMUM OF 0.125"

THE PROJECT PLANS OR SPECIFICATIONS SHALL INDICATE THE REQUIREMENT THAT THE MANUFACTURER SHALL PROVIDE A WRITTEN FIVE-YEAR PRODUCT WARRANTY, IN ACCORDANCE WITH THE BULLETIN.

LIGHT GAUGE METAL STUDS

1. ALL GALVANIZED STUDS AND JOISTS SHALL BE FORMED FROM STEEL THAT CORRESPONDS TO THE MINIMUM REQUIREMENTS OF THE 2001 AISI/COS/ANSI.
2. ALL GALVANIZED STUDS, JOISTS, TRACK, BRIDGING AND ACCESSORIES SHALL BE FORMED FROM STEEL HAVING A GALVANIZED COATING MEETING THE REQUIREMENTS OF ASTM A 653
3. GALVANIZED FRAMING PRODUCTS SHALL BE COATED IN ACCORDANCE WITH REQUIREMENTS OF ASTM A 653. PRODUCTS WILL BE FURNISHED WITH A G-60 OR EQUIVALENT COATING IF SPECIFIED AND ORDERED TO BE IN CONFORMANCE WITH ASTM C-955 OTHERWISE, G-40 OR EQUIVALENT COATING WILL BE PROVIDED.

METAL FLOOR DECK

1. SECTION PROPERTIES SHALL BE DERIVED IN ACCORDANCE WITH AISI " SPECIFICATION FOR DESIGN OF COLD-FORMED STEEL STRUCTURAL MEMBERS, LATEST EDITION."
2. METAL DECKING IS TO BE ATTACHED TO THE STRUCTURAL FRAME IN CONFORMANCE WITH AWS D1.1 AND D1.3 "SPECIFICATION FOR WELDING SHEET STEEL IN STRUCTURES."
3. ASTM REFERENCE NUMBERS: A) ASTM A653, STEEL SHEET, ZINC-COATED (GALVANIZED) OR ZINC-IRON ALLOY-COATED (GALVANNEALED) BY THE HOT-DIP PROCESS STRUCTURAL (PHYSICAL) QUALITY.
4. STEEL DECK INSTITUTE (SDI)-METAL FLOOR DECK PROFILES SHALL BE IN CONFORMANCE WITH SDI STANDARDS.
5. METAL FLOOR DECK TO BE ASC STEEL DECK
 1. B-36, 18 GAUGE
 - 1 1/2" DEEP X 36" WIDE
 2. N-24, 18 GAUGE
 - 3" DEEP X 24" WIDE
6. DECK UNITS ARE TO BE FABRICATED FROM SHEET STEEL CONFORMING TO ASTM A653, Fy=38 KSI WITH A GALVANIZED COATING, G-60 OR G-90.

| REVISIONS | | |
|-----------|------|-------------|
| NO | DATE | DESCRIPTION |
| | | |
| | | |
| | | |
| | | |

DATE: 01/20/09

SCALE: NOTED

DRAWN BY: RL

SERIAL NO.:

CUSTOMER:

2:12 PITCHED ROOF 24' x 40' THRU 120' x 40' RELOCATABLE CLASSROOMS

GENERAL NOTES



APPROVALS:

IDENTIFICATION STAMP DIV. OF THE STATE ARCHITECT OFFICE OF REGULATION SERVICES

PC 02-109895

AC FLS TH SS CC

DATE: 3/23/2009

PROJECT No. N2-C

THESE DRAWINGS AND SPECIFICATIONS ARE THE PROPERTY OF AMERICAN MODULAR SYSTEMS, INC. AND ARE NOT TO BE REPRODUCED, CHANGED OR COPIED IN ANY FORM OR MANNER, NOR ARE THEY TO BE ASSIGNED TO ANY THIRD PARTY WITHOUT THE WRITTEN AUTHORIZATION OF AMERICAN MODULAR SYSTEMS, INC.