



GENERAL NOTES

MAIN RUNNERS AT 4'-0" ON CENTER WITH 12GA HANGER WIRES AT TOP OF EACH RUNNER.

AT END OF ROWS OF RUNNERS A 12GA HANGER WIRE SHALL BE ATTACHED WITHIN 6" OF WALL, OR 1/4 LENGTH OF END RUN.

VERTICAL WIRES MORE THAN 1 IN 6 OUT OF PLUMB SHALL HAVE CORNER BRACING WIRES.

PROVIDE 2-12GA SLACK WIRES TO HOLDING OF ALL LIGHT FIXTURES AT PRINCIPAL CORNERS. WIRES SHALL BE ANCHORED TO STRUCTURE. ATTACH WIRES TO LIGHT FIXTURES WITH #8 SHEET METAL SCREW AT EACH CORNER.

RUNNERS MAY BE ATTACHED TO WALLS AT ONLY TWO ADJACENT WALLS. ALL OTHER CONDITIONS MUST PROVIDE A CLEARANCE OF 1/2" BETWEEN END OF RUNNERS AND FACE OF WALL.

CEILING AREAS SHALL HAVE 4-WAY SPIRES AT LOCATIONS INDICATED. WIRES TO BE 5/16" BUT NO PORTION OF GRID.

ALL FINISHES SHALL COMPLY WITH CFC CHAPTERS 5, 6, 7, 8, AND 10.

ELECTRICAL SHALL BE NORMALLY ATTACHED TO BUILDING AND SHALL NOT BE CLOSER THAN 6" TO HANGER WIRES.

RECELERS SHALL BE NORMALLY ATTACHED WITH 4-10GA SHEET METAL SCREWS TO GRID.

CEILING PANELS, 2'-4" LxM-IN PANELS, ASH PLANE SPREAD CLASS I (CO-25), PLANE SPREAD SMOKE DEVELOPMENT RATED LESS THAN 450.

MAIN RUNNERS, AMERICAN M. 8000/150, SH 8020/160, OR EQUAL.

CROSS RUNNERS, AMERICAN M. 8000/150, SH 8020/160, OR EQUAL.

WALL ANCHORS, PSY 8000/ 890L, CPT 8000/ 890L, OR EQUAL.

APPREVIATIONS

AT	ABOVE FINISH FLOOR
AL OR ALUM	ALUMINUM
AL	ALUMINUM CONNECTION
CON	CONNECTION
GA	GAUGE
HM	HOLLOW METAL
HW	HANGER
MIN	MINIMUM
NO.	NUMBER
NR	NOT REVERSED
OVNG	OVERLAPPING
PS	PSYCHO
SMS	SHEET METAL SCREW

LEGEND

	TANK CEILING
	CROSS RUNNER
	INDICATED FREE SIDE
	INDICATED FREE SIDE
	PLAY WIRE - 4 WAY
	2"x4" RECESSED LIGHT FIXTURE
	SUPPLY AIR DIFFUSER

APPROVALS

IDENTIFICATION STAMP
DIV. OF THE STATE ARCHITECT
OFFICE OF REGULATION SERVICES

03-118272

AC: FLS / SS CL

DATE: NOV - 8 2017

TRACKING #: 63321-292

STATE OF CALIFORNIA
Department of General Services

JUL 22 1997

Division of the State Architect
Regulation Services Section

DATE: APR 20, 1997

REV. #2: JUN 30, 1997

DRAWING SCALE: AS SHOWN

PROJECT NUMBER: 97-05

SHEET: A4

5 OF 21

NORMAN A. GEIGER
AIA, CSI, CDT, ICBO
P.O. BOX 41064
Sacramento, CA 95841
(916) 332-2463 FAX
(916) 332-2463 PHONE

GRAFICS ARCHITECTURAL SERVICES

GEIGER

REGISTERED ARCHITECT
STATE OF CALIFORNIA
C-23816
10-20-97
RESIDUAL
SITE

PACESSETTER INDUSTRIES, INC.
P.O. BOX 1151, ANDREWS, CA 95833 (916) 321-1000

24X40 RELOCATABLE BUILDING

REVISIONS

REFLECTED CEILING PLAN
GENERAL NOTES
LEGEND
DETAILS