



- DEMOLITION SITE ELECTRICAL PLAN NOTES**
- 1 REMOVE EXISTING CONDUCTORS FROM RELOCATED BUILDING PANELS AND CONDUITS BACK TO EXISTING CONCRETE PULL BOX.
 - 2 EXISTING CONCRETE PULL BOX TO REMAIN (N-36 PULL BOX.)
 - 3 DISCONNECT EXISTING FEEDER CONDUCTORS AND REMOVE FROM PANEL TO EXISTING CONCRETE PULL BOX. BACKBOARD AND PANELS TO REMAIN.
 - 4 AFTER PG&E HAS DISCONNECTED SERVICE AND REMOVED EXISTING METER, PROVIDE A BLANK METER SOCKET COVER.
 - 5 REMOVE EXISTING OVERHEAD CABLING FROM T4 TO T3 AND T4 TO ROOM 19. CUT CABLES AT T4 AND T3 AND REMOVE ANY RISER. CUT CABLES AT ROOM 19 AND WEATHER PROOF THE CABLE ENDS.
 - 6 REMOVE EXISTING ABOVE GROUND 12 X 12 X 4 NEMA 3R J-BOXES AND UNISTRUT SUPPORTS COMPLETELY. INSTALL (N) N-9 CONCRETE PULL BOXES OVER (E) CONDUITS. SET BOXES FLUSH TO EXISTING GRADE (TYPICAL).
 - 7 REMOVE EXISTING OVERHEAD SERVICE CONDUCTORS FROM T-3 BACK TO ROOM 19. REMOVE AT RISER ON ROOM 19 AND WEATHER PROOF THE CONDUCTOR ENDS. REMOVE RISER FROM PANEL ON T-3.
 - 8 REMOVE EXISTING RISER SUPPORTS AND EXTERIOR FLOOD LIGHTS.
 - 9 EXISTING BUILDING TO REMAIN UNTIL NEW BUILDINGS ARE COMPLETED.

DEMOLITION SITE ELECTRICAL PLAN

SCALE: 1"=30'-0"

JMPE/JOB#:04082/DATE:01-14-10 AG

Ownership of Documents
This document, the ideas and designs incorporated herein, as an instrument of Professional Service is the property of Integrated Designs by SOMAM Inc. and is not to be used, in whole or in part for any other project without written authorization. © COPYRIGHT 2009

integrated designs by SOMAM, Inc.
ARCHITECTURE • ENGINEERING • INTERIOR DESIGN • CONSTRUCTION MANAGEMENT
6011 N. Fresno, Suite 130 - Fresno, California 93710
Phone (559) 436-0881 Fax (559) 436-0887 E-Mail: design@somam.com
www.integrateddesigns.com

Revision	Rev. Date	Rev. Description
1	10/15/09	ADENDUM 1
2	01/22/10	CHANGE ORDER

Sheet Title: **DEMOLITION SITE ELECTRICAL PLAN**
Project Name & Address: **MUNSEY ELEMENTARY SCHOOL 10 NEW PORTABLE CLASSROOMS**
BAKERSFIELD CITY SCHOOL DISTRICT
3801 BRAVE AVE. BAKERSFIELD, CA 93309

Issue Date: 05/02/06
Date: 05/02/06
Designer: DR. CUM
DRAFTER: CUM
PC: CUM

DSA Identification Stamp:
IDENTIFICATION STAMP
DIV. OF THE STATE ARCHITECT
03-112985
AC FLS SS
DATE 2/10/10

Stamp(s):
JMPE
ELECTRICAL ENGINEERING
LIGHTING DESIGN
CA REGISTRATION NO. E13083
04082
5050 MING AVENUE,
SUITE 101
BAKERSFIELD, CA 93309
(805) 881-7801
FAX (805) 881-7813
email: madmosey@jimppe.net
www.jimppe.net
CURTIS E. MCNALLY
REGISTERED PROFESSIONAL ELECTRICAL ENGINEER
STATE OF CALIFORNIA

Job No.: **3832**
Sheet No.: **X6-E-1**
Release: **CURTIS MCNALLY**