

GENERAL NOTES AND SPECIFICATIONS

SECTION 1A GENERAL REQUIREMENTS

- 1. GENERAL. THE REQUIREMENTS OF THE GENERAL CONDITIONS OF THE AGREEMENT AND THIS GENERAL REQUIREMENT APPLY TO THE SEVERAL TRADE SECTIONS WITH THE SAME FORCE AS THOUGH FULLY REPEATED IN EACH TRADE SECTION.
2. NAME BRANDS ARE INDICATED TO ESTABLISH A STANDARD OF QUALITY. ITEMS OF EQUAL OR BETTER QUALITY MAY BE SUBSTITUTED FOR THE LISTED BRAND NAMED PRODUCTS WITH THE WRITTEN APPROVAL OF D.S.A. AND THE ARCHITECT.
3. ALL WORK SHALL COMPLY WITH THE REQUIREMENTS OF TITLES 19 AND 24 CALIFORNIA CODE OF REGULATIONS 2007 C.B.C. NO CHANGES SHALL BE MADE FROM D.S.A. APPROVED DRAWINGS OR SPECIFICATIONS WITHOUT PRIOR WRITTEN APPROVAL OF D.S.A. AND THE ARCHITECT.
4. THE WORK CONSISTS OF MANUFACTURING OFF-SITE IN A PLANT AND INSTALLING ON-SITE/MODULAR RELOCATABLE BUILDINGS AS DEFINED HEREIN AND SHOWN AND DETAILED ON DRAWINGS.
5. ALL REQUIREMENTS OF TITLES 24 OF THE STATE OF CALIFORNIA CODE OF REGULATIONS RELATING TO INSPECTIONS AND VERIFIED REPORTS SHALL BE COMPLIED WITH AND SHALL INCLUDE:
6. GENERAL RESPONSIBLE CHARGE OF FIELD ADMINISTRATION BY THE ARCHITECT OF RECORD
7. INSPECTION IN-PLANT DURING THE COURSE OF CONSTRUCTION BY AN INSPECTOR APPROVED BY THE DIVISION OF THE STATE ARCHITECT AND THE DISTRICT ARCHITECT. THE INSPECTOR SHALL BE RESPONSIBLE FOR AND APPROVED TO INSPECT THE GENERAL CONSTRUCTION WELDING, MECHANICAL, AND ELECTRICAL WORK. COST OF THESE INSPECTIONS SHALL BE BORNE BY THE SCHOOL DISTRICTS.
8. ON-SITE INSPECTION OF THE BUILDING INSTALLATION, ELECTRICAL AND UTILITY INSTALLATION OR CONNECTIONS BY AN INSPECTOR APPROVED BY THE DIVISION OF THE STATE ARCHITECT AND THE DISTRICT ARCHITECT AND THE DISTRICT ARCHITECT AND RETURNED BY THE SCHOOL DISTRICT.
9. OTHER SPECIAL TESTS OR INSPECTIONS AS MAY BE APPROVED BY D.S.A.
10. APPROVED BY D.S.A.
11. CHANGE ORDERS SHALL BE SIGNED BY THE OWNER & ARCHITECT & APPROVED BY D.S.A.
12. THE TESTING LAB SHALL BE IN THE EMPLOY OF THE OWNER. DIMENSIONS AND DETAILS VERIFY ALL WORK CONDITIONS, AND DISCREPANCIES TO THE DESIGNER/OWNER IMMEDIATELY BEFORE COMMENCING WORK.
13. EACH CONTRACTOR TO ALL GOVERNMENTAL CODES WHETHER OR NOT SO STATED ON THE DRAWINGS.
14. ALL MATERIALS AND WORKMANSHIP TO CONFORM TO THE LATEST REQUIREMENTS OF THE GOVERNING BUILDING CODES IN EFFECT AT TIME OF USA APPLICATION.
15. ALL MANUFACTURED ARTICLES, MATERIALS AND EQUIPMENT SHALL BE APPLIED, INSTALLED, CONNECTED AND ERECTED PER MANUFACTURER'S DIRECTIONS AND INSTRUCTIONS.
16. SHOP DRAWINGS MAY BE REQUIRED. IF SO, THEY WILL BE ACCURATELY DRAWN TO A LARGE ENOUGH SCALE TO SHOW ALL PERTINENT FEATURES OF THE ITEM AND ITS CONNECTION TO RELATED WORK.
17. THE MANUFACTURER OF BUILDING IS TO PLACE TWO PERMANENT METAL IDENTIFICATION LABELS ON EACH MODULE MECHANICALLY ATTACHED TO THE FRAME SEE GENERAL DESIGN REQUIREMENTS. THIS PAGE
18. FOR PROJECTS MANUFACTURED OFF-SITE, THE PLANT INSPECTOR IS TO PROVIDE THE MANUFACTURER'S IDENTIFICATION LABEL NUMBER OF EACH MODULE ON THE VERIFIED REPORT
19. AND D.S.A. APP. NUMBER.
20. ALL TESTS AND INSPECTIONS REQUIRED BY D.S.A. SHALL BE COMPLIED WITH. ALL TESTS REQ. BY FIRE AND LIFE SAFETY REGULATIONS SHALL BE BY A NATIONALLY RECOGNIZED TESTING LABORATORY.
21. ASSUMED ALLOWABLE SOIL BEARING: 1000 PSF FOR WOOD FOUNDATIONS, 1500 P.S.F. FOR CONCRETE FOUNDATIONS EMBEDDED 12" MIN. BELOW GRADE.
22. FOOTINGS SHALL BE LOCATED ON UNDISTURBED FIRM NATURAL SOIL. APPROVED COMPACTED FILL OR ON AN APPROVED PAVED SURFACE.
23. THE FOUNDATION SYSTEM PRESENTED HEREIN COMPLIES WITH INTERPRETATION OF REGULATIONS, I.R. 16-1, ISSUED BY DIVISION OF THE STATE ARCHITECT FOR TEMPORARY BUILDINGS. THIS FOUNDATION SYSTEM IS NON-CONVENTIONAL AND THE STRUCTURAL ENGINEER TAKES NO RESPONSIBILITY FOR ITS CONSTRUCTION OR LONGEVITY.
24. WORK NOT INCLUDED:
A. ALL ON-SITE OR OFF-SITE UTILITIES AND THE CONNECTION OF THEM TO THE BUILDING UNLESS INDICATED ON THE DRAWINGS.
B. ALL LEVELING, GRADING OR OTHER SITE PREPARATION EXCEPT CONCRETE OR WOOD LEVELING STRIPS WHERE REQUIRED, UNLESS OTHERWISE INDICATED ON THE DRAWINGS.
C. FIRE ALARM SYSTEM, PROGRAM BELL, PUBLIC ADDRESS SYSTEM/INTERCOM SYSTEM, TELEPHONE SYSTEM UNLESS OTHERWISE INDICATED ON THE DRAWINGS, OR MODIFIED BY CHANGE ORDER.
D. WHEELS AND HITCH SHALL REMAIN THE PROPERTY OF THE CONTRACTOR.
E. THE SCHOOL DISTRICT SHALL PROVIDE ACCESS TO THE SITE FOR THE INSTALLATION OF BUILDINGS. REMOVAL OF TREES SHRUBS, FENCING, SPRINKLERS ETC. NECESSARY FOR THE MOVE-IN OF BUILDINGS SHALL BE THE RESPONSIBILITY OF THE SCHOOL DISTRICT.

SECTION 5 STEEL

- A. GENERAL - ALL WORK SHALL CONFORM TO THE REQUIREMENTS OF AISC STANDARD SPECIFICATIONS, TITLE 24 OF CALIFORNIA CODE OF REGULATIONS AND THE AMERICAN IRON AND STEEL INSTITUTE SPECIFICATIONS FOR DESIGN OF STEEL STRUCTURAL MEMBERS. A COPY OF TITLE 24 SHALL BE KEPT AT THE JOB SITE AT ALL TIMES.
B. WELDING - ALL WELDING DONE BY SHIELDED ELECTRIC-ARC OR FLOW CONEDED-ARC PROCESS COMPLYING WITH REQUIREMENTS OF THE STRUCTURAL WELDING CODE OF THE AMERICAN WELDING SOCIETY. WELDING DONE BY OPERATORS QUALIFIED BY TESTS ACCEPTABLE TO THE DIVISION OF THE STATE ARCHITECT. WELDING INSPECTION PER TITLE 24, PART 2, COR. SECTION 1704A.3.1 ALL WELDS USED IN PRIMARY MEMBERS AND CONNECTIONS IN THE LATERAL FORCE-RESISTING SYSTEMS SHALL BE MADE WITH A FILLER METAL THAT HAS A MINIMUM CHARPY V-NOTCH TOLERANCE OF 20FT-LETS AT ZERO DUCTILITY F, AS DETERMINED BY AWS CLASSIFICATION OR MANUFACTURER'S SPECIFICATIONS.
1. STRUCTURAL STEEL SHALL CONFORM TO A.S.T.M. A-36
2. PIPE COLUMNS SHALL CONFORM TO A.S.T.M. A-53
3. WITH SULFUR CONTENT NOT EXCEEDING 0.05%.
4. STEEL TUBING SHALL CONFORM TO A.S.T.M. A-500 GRADE B OR A.S.T.M. A579 GRADE 50 FOR GAUGE TUBING-TYP. U.N.O.
5. STRUCTURAL WELDS ARE DESIGNED FOR FULL ALLOWABLE STRESS UNLESS OTHERWISE NOTED.
6. ERECTION - STRUCTURAL STEEL, ERECTED TRUE/STRAIGHT, PLUMB AND TO ITS DESIGNATED LOCATIONS. FIELD DRAWINGS SHALL BE CORDING PLATED OR GALVANIZED.
7. BOLTS FOR STRUCTURAL STEEL JOINTS SHALL CONFORM TO A.S.T.M. A-307 UNLESS OTHERWISE NOTED. ALL BOLTS FOR MACHINES AND CARTRIDGE BOLTS THROUGH STEEL TO BE DRILLED, OR TORCH PLOT HOLES AND REAM NIP 1/16" TO BOLT SIZE. NELSON STUDS (WELDED TO STEEL) MAY BE SUBSTITUTED FOR BOLTS SAME LENGTH AND DIAMETER.
8. HANDRAILS - FABRICATED, AS DETAILED, WELDS GROUND SMOOTH.
9. EXPOSED STEEL COATED WITH ONE SHOP COAT OF RED OXIDE PRIMER.
10. NON-EXPOSED STEEL COATED WITH ONE SHOP COAT OF RED OXIDE PRIMER.
11. ALL SURFACES THOROUGHLY CLEANED BY EFFECTIVE MEANS PRIOR TO APPLICATION OF SHOP COATS.
12. TESTS
13. PROVIDE MILL CERTIFICATES OR TEST ALL STEEL MEMBERS PER 1-24 PART 2, COR SECTION 2212A.1
SECTION 6A CARPENTRY
1. SCOPE OF WORK
2. CONTRACTOR SHALL PROVIDE ALL LABOR, MATERIALS AND SERVICES TO INSTALL CARPENTRY.
3. MATERIALS
4. LUMBER GRADE MARKED IN ACCORDANCE WITH "STANDARD GRADING AND DRESSING RULE NO. 17" OF WEST COAST LUMBER INSPECTION BUREAU OR "GRADING RULES FOR LUMBER" OF WESTERN WOOD PRODUCTS ASSOCIATION OR W.C.L.B. BLYWOOD GRADE MARKED IN ACCORDANCE WITH AMERICAN FLOOR WOOD ASSOCIATION.
5. EACH SHEET SHALL BEAT THE STAMP OF A.P.A. PITTSBURGH TESTS, OR T.E.C.O.
6. JOISTS, PLATES, STUDS-DOUGLAS FIR S4S #2 UNK.O.
7. NOTER: M&R 1650 E.T.S. MAY BE SUBSTITUTED FOR #2 GRADE IF IT MEETS THE STRUCTURAL REQUIREMENTS FOR FLOOR AND ROOF MEMBERS.
8. H.F. HEADERS, POSTS AND TIMBERS-DOUGLAS FIR S4S #1
9. BLOOMING - DOUG FIR #3 OR HEH FIR #3 OR STD. & BET.
10. SILLS AND LUMBER & SHIM PLUGS IN CONTACT WITH CONCRETE/MASONRY OR EARTH, DOUG FIR #2 PRESSURE TREATED IN ACCORDANCE WITH CGC 2304.11.2 EACH PIECE SHALL BEAR AMPB STAMP. AMPA STANDARD U1 & T1 GROUND CONTACT/D.#2 ABOVE GROUND.
11. MOISTURE BARRIER - KRAFT WATERPROOF BUILDING PAPER, OR 15 LB. FELT, PER 2007 CGC 17-1.1 FOR KRAFT, 32-1 FOR FELT. STUDS - S4S DOUG FIR #2, OR #2 HEH FIR, MAXIMUM MOISTURE CONTENT OF 19% AT TIME OF INSTALLATION.
12. FASTENERS - NAILS SHALL BE CORROSION RESISTANT PER C.B.C. 2304.9.1.1 COMMON NAILS FOR EXT. SIDING & FNDN. ONLY. DOOR/TRIM TRIM - 2X RESAWN SELECT D.F., H.F., OR CEDAR.
13. FRAMING CONNECTORS SHALL BE FROM SIMPSON CATALOG LATEST ED.
14. FIRE BLOCS SHALL CONFORM TO CGC SECTION 717
15. ALL NAILS SHALL BE COMMON NAILS UNLESS OTHERWISE NOTED.
16. FOUNDATION LUMBER: ALL CUT ENDS AND HOLES IN PRESSURE TREATED LUMBER SHALL BE TREATED WITH "CUPRINOX".
17. WORKMANSHIP
18. FRAMING - SECURELY NAIL/ED BRIDGED AND BLOCKED TO FORM RIGID STRUCTURE. WORK CUT, FITTED AND ASSEMBLED LEVEL PLUMB AND TRUE TO LINE. TRIM IN AS LONG LENGTHS AS POSSIBLE WITH ALL STRANDING TRIM IN ONE PIECE. TRIM SEALED AT ALL JOINTS.
19. EXTERIOR WALLS - FACTORY FABRICATED. CAULKING PROVIDED BETWEEN PERIMETER OF WALL AND STRUCTURAL MEMBERS PROVIDING WEATHER-PROOF AND WATER-TIGHT SEAL. NECESSARY CLOSERS, STAYS, AND FLASHINGS PLACED AT TOP AND BASE SUPPORT OF PANELS AND AROUND OPENINGS.
20. NAILS INTO P.T. LUMBER TO BE HOT DIPPED GALVANIZED.

- E. MACHINE APPLIED FINISHING
1. USE OF MACHINE FINISHING IS SUBJECT TO A SATISFACTORY JOBSITE DEMONSTRATION FOR EACH PRODUCT AND THE APPROVAL BY THE PROJECT ARCHITECT OR STRUCTURAL ENGINEER AND THE DIVISION OF THE STATE ARCHITECT. THE APPROVAL IS SUBJECT TO CONTINUED SATISFACTORY PERFORMANCE.
2. MACHINE FINISHING WILL NOT BE APPROVED IN 5/8" PLYWOOD. IF NAILHEADS PENETRATE THE OUTER PLY MORE THAN WOULD BE NORMAL FOR A HAND HAMMER OR IF MINIMUM ALLOWABLE EDGE DISTANCES ARE NOT MAINTAINED THE PERFORMANCE WILL BE DEEMED UNSATISFACTORY.
3. MOSTURE BARRIER - APPLIED TO STUDS WEATHER-BOARD FASHION. HORIZONTAL JOINTS LAPPED MIN 6" INCLUDING BUILDING CORNERS. SHEATHING APPLIED OVER MOISTURE BARRIER. TRIM OR SEALED AT ALL EDGES. SEALANT PAINTED TO MATCH TRIM OR UNLESS TRANSPARENT TYPE.
SECTION 7B SHEET METAL
1. SCOPE OF WORK
2. CONTRACTOR SHALL PROVIDE ALL LABOR, MATERIALS AND SERVICES TO INSTALL INDICATED SHEET METAL.
3. MATERIALS
4. SHEET METAL - STEEL SHEETS HOT DIP GALVANIZED WITH 1.25 A526. MINIMUM 26 GA. UNLESS OTHERWISE NOTED ON THE DRAWINGS.
5. SOLDER - OF STD. GRADE "X" OF EQUAL PARTS/BRAND LEAD AND TIN ASTM B32.
6. CUTTERS - 26 GA. G-90 GALV. STEEL.
7. DOWNSPOUTS: 2"x3" CONVOLUTIONED 30 GA. G-90 GALV. STEEL. GUTTER ENDCAPS: 26 GA. G-90 GALV. STEEL. GUTTER CLIPS: 18 GA. G-90 GALV. STEEL.
8. WORKMANSHIP
9. SHEET METAL ACCURATELY FORMED TO DIMENSIONS AND SHAPES DETAILED WITH TRUE STRAIGHT LINES, CORNERS AND ANGLES. FLASHING INSTALLED IN LONGEST LENGTHS POSSIBLE. EXTERIOR WORK INSTALLED AND INSULATED SO THAT IT COMPLETELY PROVIDES FOR EXPANSION AND CONTRACTION IN THE COMPLETED WORK AND FINISHES WATER AND WEATHER TIGHT. ALUMINUM SHALL BE SEPARATED FROM FERROUS METAL BY POLYETHYLENE TAPE OR FLOOD COAT OF ASPHALTIC PAINT.
SECTION 7C METAL ROOFING
1. SCOPE OF WORK
2. CONTRACTOR SHALL PROVIDE ALL LABOR, MATERIALS AND SERVICES TO INSTALL METAL ROOFING. TEST RESULTS SHOWING THE ROOFING SYSTEM WILL WITHSTAND THE UPLIFT OF A 85 MPH WIND SHALL BE SUBMITTED WITH THE PLANS AND SPECIFICATIONS.
3. MATERIALS
4. ROOFING - 1 1/4" INCH STANDING SEAM MIN 26-GAUGE G-90 GALV. INTERLOCKING (UNPENETRATED) SHEET ST. PANELS (90).
5. ALTERNATE: ROOFING - 3 INCH STANDING SEAM MIN 26-GAUGE G-90 GALV. INTERLOCKING (UNPENETRATED) SHEET ST. PANELS (90).
6. ROOFING: CLASS B FIRE RATING
SECTION 7J SEALANT
1. SCOPE OF WORK
2. CONTRACTOR SHALL PROVIDE ALL LABOR, MATERIAL AND SERVICES TO SEAL BUILDINGS.
3. MATERIALS
4. VULKAN SEALANT: POLYURETHANE, MANUFACTURED BY MAMECO INTERNATIONAL FOR ROOFS. "GEOTEK" SILICONIZED CAULK, GE DUPOINT, ENGLESTAL OR DAP FOR ALL OTHER APPLICATIONS, OR EQUAL.
5. WORKMANSHIP
6. SEALANT APPLIED TO DRY CLEAN SURFACES, WHEREVER INDICATED ON DETAILS AND AS NEEDED TO MAKE BUILDING WATER/TIGHT IN ACCORDANCE WITH MANUFACTURER'S SPECIFICATIONS.
SECTION 8 CONCRETE
1. CONCRETE CONSTRUCTION SHALL CONFORM TO ACI 318-05
2. THE MINIMUM 28 DAY STRENGTH AND TYPE OF CONCRETE SHALL BE A FOLLOWS:
3. SLABS ON GROUND & FOUNDATIONS 2500 PSI (150 PCF) OR (150 PCF) CONCRETE OVER METAL DECK
4. REINFORCING SHALL CONFORM TO ASTM A618--GRADE 40 UN.
5. CONCRETE COVERAGE SHALL BE AS FOLLOWS, UN ON DRAWINGS: CONCRETE EXPOSED DIRECTLY AGAINST GROUND (EXCEPT SLABS) 3" SLABS (ON GROUND)..... POSITION IN CENTER OF SLAB 2"
6. ALL BARS SHALL HAVE A CLASS B MINIMUM SPECIE LAP UN.
SECTION 8A EXTERIOR PLASTER
1. LATHING AND PLASTERING MATERIALS AND ACCESSORIES SHALL BE MARKED BY THE MANUFACTURER'S DESIGNATION TO INDICATE COMPLIANCE WITH THE APPROPRIATE STANDARDS REFERENCED IN THIS SECTION AND STORED IN SUCH A MANNER TO PROTECT THEM FROM THE WEATHER. PER 2507.1
2. LATHING AND PLASTERING MATERIALS SHALL CONFORM TO THE STANDARDS LISTED IN TABLE 2507.2 AND CHAPTER 35 AND, WHERE REQUIRED FOR FIRE PROTECTION, SHALL ALSO CONFORM TO THE PROVISIONS OF CHAPTER 7. PER 2507.2
3. Gypsum board and gypsum plaster construction shall be of the materials listed in tables 2506.2 and 2506.3 and shall comply with the standards listed in tables 2508.1 and 2511.1, and chapter 35
4. PER 2508.1 PROVIDE 2 LAYERS OF GRADE D PAPER PER CGC SECTION 2510.6
5. 2510.6 WATER-RESISTIVE BARRIERS WATER-RESISTIVE BARRIERS SHALL BE INSTALLED AS INCLUDE A WATER-RESISTIVE VAPOR-PERMEABLE BARRIER WITH A PERFORMANCE AT LEAST EQUIVALENT TO TWO LAYERS OF GRADE D PAPER.
6. EXCEPTION: WHERE THE WATER-RESISTIVE BARRIER THAT IS APPLIED OVER WOOD-BASED GYPSUM BOARD OR PAPER RESISTANCE EQUAL TO OR GREATER THAN THAT 60-MINUTE EVALUATION TO TWO LAYERS OF GRADE D PAPER OR DAMAGE SPACE.
SECTION 9B HOLLOW METAL DOORS AND FRAMES
1. GENERAL NOTES
2. PLASTERING WITH CEMENT PLASTER SHALL NOT BE LESS THAN THREE COATS WHEN APPLIED OVER METAL LATH OR WIRE FABRIC LATH AND SHALL NOT BE LESS THAN TWO COATS WHEN APPLIED OVER MASONRY CONCRETE OR GYPSUM BACKING AS SPECIFIED IN SECTION 2510.5
3. THE FIRST COAT SHALL BE APPLIED WITH SUFFICIENT MATERIAL AND PRESSURE TO FILL SOLIDLY ALL OPENINGS. IN THE LATH, THE SURFACE SHALL BE SCORED HORIZONTALLY SUFFICIENTLY ROUGH TO PROVIDE ADEQUATE BOND TO RECEIVE THE SECOND COAT.
4. THE SECOND COAT SHALL BE BROUGHT OUT TO PROPER THICKNESS, RODED AND FLOATED SUFFICIENTLY ROUGH TO PROVIDE ADEQUATE BOND TO THE FINISH COAT. THE SECOND COAT SHALL HAVE NO VARIATION GREATER THAN 1/4 INCH (6.4 mm) IN ANY DIRECTION UNDER 5-FOOT STRAIGHT EDGE. THE FINISH COATS SHALL BE APPLIED OVER BASE COATS THAT HAVE BEEN IN PLACE FOR THE TIME PERIODS SET FORTH IN ASTM C 928 THE THIRD OR FINISH COAT SHALL BE APPLIED WITH SUFFICIENT MATERIAL AND PRESSURE TO BOND TO AND TO COVER THE BROWN COAT AND SHALL BE OF SUFFICIENT THICKNESS TO CONCEAL THE BROWN COAT.
5. SCOPE OF WORK
6. CONTRACTOR SHALL PROVIDE ALL LABOR, MATERIALS AND SERVICES TO INSTALL HOLLOW METAL DOORS AND FRAMES.
7. MATERIALS
8. DOORS - INSULATED TYPE L FULL FLUSH, MANUFACTURED BY AMWELD MANUFACTURING COMPANY, 1/8 GA. 1 3/4" THICK PER CGS242 W/REINFORCE FOR HARBOR-BOOTH FACES FOR CLOSER.
9. SOUND DEADEN INTERIOR ROLLED, 2" THICK, CGS242 MIN.3 FRAMES PER JAMB & ADJUSTABLE FLOOR ANCHOR EACH JAMB REINFORCES FOR JAMB. PROVIDE STRIKE BOX PROVIDE SOUND DEADENING: 1/8" UNDERCAPPING OR INSULATING FILL.
10. WORKMANSHIP
11. ALL WORK FABRICATED IN SHOP TO REQUIRED PROFILES BY FORMING AND WELDING WITH ARRESSES AND EDGES STRAIGHT, SHARP FIT FABRICATED ACCURATELY WITH SQUARE CORNERS, HANGLINE JOINTS AND SURFACES FREE FROM WARP, WAVE, BUCKLE, OR OTHER DEFECTS AFTER FABRICATION/DOORS AND FRAMES CLEANED THOROUGHLY-ALL WELDS GROUND SMOOTH AND GIVEN PRIME COAT.
SECTION 9E PAINTING
1. SCOPE OF WORK
2. CONTRACTOR SHALL PROVIDE ALL LABOR, MATERIALS AND SERVICES TO PAINT BUILDING. ALL EXPOSED SURFACES OF BUILDING AND RAMPS SHALL BE PAINTED EXCEPT ALUMINUM WINDOW FRAMES, THRESHOLDS, AND ROOFING.
3. MATERIALS
4. FOR EXTERIOR WOOD:
5. REF-BRAND DUNN EDWARDS KELLY MOORE SHERWIN WILLIAMS SINGLAR PRIMER 43-4 1710 B50WZ6 15N
6. FINISH 10-XX 1700-XXX B54WZ10Z G22-1XX
7. WORKMANSHIP
8. ALL EXPOSED SURFACES SHALL BE PAINTED EXCEPT ALUMINUM WINDOW FRAMES AND THRESHOLDS. MATERIAL SHALL BE OF THE GRADE SPECIFIED OR EQUAL.
9. EXTERIOR - WOOD SIDING, TRIM AND SKIRTING FLAT OR SEMI-GLOSS LATEX - APPLY ONE COAT OF PRIME AND AT LEAST ONE FINISH COAT. PRIME COAT SHALL BE BRUSHED ON OR SPRAYED AND BACK BRUSHED INTO ALL GROOVES IN THE SIDING. IF NECESSARY, IN THE OPINION OF THE INSPECTOR, AN EXTRA COAT SHALL BE APPLIED TO ALL GROOVES SO THAT THE FINISH COAT WILL HAVE A UNIFORM APPEARANCE. ALLOW PRIME COAT TO DRY ACCORDING TO MANUFACTURER'S RECOMMENDATION. PRIME AND FINISH COATS SHALL BE COMPATIBLE AND MANUFACTURED BY THE SAME COMPANY.
10. INTERIOR TRIM - TRIM NOT PRECATED SHALL BE PAINTED WITH TWO COATS OF SEMI-GLOSS LATEX OVER PRIMER.
11. INTERIOR HARDWOOD CABINETS - TWO COATS LOW LUSTER POLYURETHANE FINISH. APPLY FIRST COAT THINNED WITH ONE QUART MINERAL SPIRITS PER GALLON. APPLY SECOND COAT AS RECOMMENDED BY MANUFACTURER.
12. METAL - ALL METAL SURFACES SHALL BE PAINTED WITH TWO COATS OF ALVO FINISH COAT OVER ZINC CHROMATE OR EQUAL RUST INHIBITING PRIMER.
13. RAMP - ONE COAT OF FERROX NON-SLIP (0.8 MIN. C.O.F.) SURFACING AS MANUFACTURED BY AMERICAN ABRASIVE METALS OR COMPARABLE. ALL PAINTS OF THE TYPE INDICATED SHALL BE LISTED ON THE STATE OF CALIFORNIA QUALIFIED PRODUCTS LIST FOR MAINTENANCE STATES 8010-910-98A DATED JULY 1989. OR EQUAL.
14. SUBMIT ONE SET COLOR SAMPLES TO ARCHITECT FOR EACH PRODUCT TO ASSIST IN SELECTION.
SECTION 13F SITE ASSEMBLY
1. SCOPE OF WORK
2. CONTRACTOR SHALL PROVIDE ALL LABOR, MATERIALS AND SERVICES TO PREPARE THE BUILDING ELEMENTS, TRANSPORT THEM FROM THE PLANT TO THE SITE AND TO COMPLETE THE ASSEMBLY AT THE SITE.
3. THE CONDITION OF THE SITE, SUCH AS DRAINAGE AND SOIL BEARING CAPACITY, SHALL BE THE RESPONSIBILITY OF THE SCHOOL DISTRICT. UNLESS SPECIFICALLY CALLED FOR IN THE CONTRACT, STAYS, RAMPS, OR HANDRAILS SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR ASSEMBLY OF ELEMENTS
4. IN A LOCATION ON THE SITE AS DETERMINED BY THE SCHOOL DISTRICT, APPROVED BY (05A) THE CONTRACTOR SHALL PLACE WOOD LEVELING STRIPS OR OTHER SUITABLE SUPPORTS AS DETAILED ON THE DRAWINGS.
5. THE ELEMENTS SHALL BE BROUGHT TO THE SITE ON WHEEL ASSEMBLY AND TRANSPORTED TO THE PREPARED SITE. GREAT CARE SHALL BE TAKEN TO AVOID DAMAGE TO THE ELEMENTS BY RACKING OR BUMPING EACH OTHER.
6. CONNECTION OF THE ELEMENTS TOGETHER SHALL BE DONE ACCORDING TO INSTRUCTION ON THE DRAWINGS. FLASHINGS, TRIM AND OTHER LOOSE ITEMS SHALL BE INSTALLED PER DETAILS ON THE DRAWINGS.

SECTION 15A AIR CONDITIONING

- 1. SCOPE OF WORK (SEE SHEET M3 FOR HVAC SPEC. AND NOTES)
2. CONTRACTOR SHALL PROVIDE ALL LABOR, MATERIALS AND SERVICES TO INSTALL THE AIR CONDITIONING SYSTEM AS SHOWN ON THE DRAWINGS AND SPECIFICATIONS, INCLUDING A/C UNITS AND ACCESSORIES, REMOVE THERMOSTATS, GRILLS AND POWER WIRING COMPLETE TO LOAD CENTER. CONTRACTOR SHALL INSTRUCT OWNER'S OPERATORS ON OPERATION AND MAINTENANCE OF A/C SYSTEM.
3. EQUIPMENT
4. SEE NOTE ON FLOOR PLAN FOR SIZE AND TYPE.
5. WORKMANSHIP
6. UNITS SHALL BE INSTALLED COMPLETE AND OPERATING WITH ALL ACCESSORIES IN ACCORDANCE WITH THE MANUFACTURER'S INSTRUCTIONS.
SECTION 16A ELECTRICAL
1. SCOPE OF WORK
2. CONTRACTOR SHALL PROVIDE ALL LABOR, MATERIALS AND SERVICES FOR ELECTRICAL INSTALLATION COMPLIABLE WITH ASSOCIATED EQUIPMENT AND FIXTURES. IN OPERATING CONDITION READY FOR USE. THE WORK INCLUDES: LIGHT AND POWER SYSTEMS LIGHTING FIXTURES COMPLETE WITH LAMPS, CONNECTIONS AND DISCONNECTS TO A/C EQUIPMENT.
3. PROVIDE CONDUIT WITH PULL STRINGS AND JUNCTION BOXES FOR AUTOMATIC DETECTION FIRE ALARM SYSTEM AND NOTIFICATION PER NFPA 72
4. MATERIALS
5. ALL NEW CONDUIT WITH REQUIREMENTS OF CALIFORNIA ELECTRIC CODE AND NATIONAL FIRE PROTECTION ASSOCIATION
6. ELECTRICAL METALLIC TUBING - COPULING AND FLEX CONDUIT GALVANIZED OR SHEARBRIDZED. EXTERIOR FLEX- GALV. STEEL W/ FACTORY APPLIED P.V.C. JACKET.
7. PANELBOARDS - FLUSH MOUNTED.
8. CONDUCTORS - COPPER/INSULATED FOR 600 VOLTS, TYPE THIN FOR SIZES #12 TO #6, TYPE THW FOR LARGER SIZES. MINIMUM SIZE- #14.
9. RECEPTACLES - AS NOTED, +18" A.F.F. MIN.
10. CLOCK RECEPTACLE - AS NOTED.
11. SWITCHES - AS NOTED, +48" A.F.F. MAX.
12. LIGHTING FIXTURES - AS NOTED ON THE DRAWINGS.
13. WORKMANSHIP
14. MATERIALS AND EQUIPMENT INSTALLED IN A SEQUENCE/NEAT WORKMANLIKE MANNER IN ACCORDANCE WITH CODE REQUIREMENTS.
15. PANELBOARD CARDS FILLED OUT. CONDUIT AND CABLE INSTALLED IN WALL AND CEILING SPACES. WORK PIERCING WATERPROOFED AREAS FLASHED AND SEALED TO A WATER/TIGHT CONDITION.
16. BUILDING CONDUIT/WIRING FROM FACE OF BLDG TO SITE TERMINATION BY SITE CONTRACTOR(M.I.C.)(FLEXIBLE CONDUIT S-BEND SEALTIE)
SECTION 16B INSPECTION
1. INSPECTION OF PREPARATED BUILDINGS IS DIVIDED INTO TWO SEPARATE FUNCTIONS.
2. ON-SITE INSPECTION.
3. IN-PLANT INSPECTION.
4. THE CONTRACTOR SHALL ALLOW UP TO SEVEN (7) DAYS FROM THE DATE OF PLAN APPROVAL TO OBTAIN AN IN-PLANT INSPECTOR APPROVED BY D.S.A.
5. IN-PLANT INSPECTION AND MATERIAL TESTING SHALL BE CONDUCTED UNDER THE SUPERVISION OF THE DISTRICT ARCHITECT. THE CONTRACTOR SHALL NOTIFY THE DISTRICT ARCHITECT, D.S.A. AND THE DESIGNATED INSPECTOR/INSPECTION AGENCY AT LEAST 48 HOURS PRIOR TO COMMENCING WORK. THE MANUFACTURER SHALL PROVIDE THE INSPECTOR WITH FULL ACCESS TO ALL PLANT OPERATIONS INVOLVING WORK UNDER THIS CONTRACT AND SHALL ADVISE THE INSPECTOR IN ADVANCE OF THE TIME AND PLACE WHEN OPERATIONS THAT THE INSPECTOR WANTS TO OBSERVE TAKE PLACE. BEFORE THE BUILDING IS REMOVED FROM THE PLANT FOR DELIVERY TO THE STORAGE YARD OR FROM THE STORAGE FACILITY TO THE SITE THE INSPECTOR SHALL ISSUE A WRITTEN RELEASE WHICH SHALL BE IN THE FORM OF A VERIFIED REPORT (FORM SSS-6). A COPY OF THE RELEASE SHALL BE SUBMITTED TO THE DISTRICT ARCHITECT AND THE DISTRICT ARCHITECT SHALL FORWARD THE REPORT TO STORAGE OR TO THE SITE. THE INSPECTOR SHALL FOLD TO STORAGE OR TO THE SITE.


- SECTION 15B COORDINATION OF WORK
1. IF SHALL BE THE CONTRACTOR'S RESPONSIBILITY TO MAKE ALL NECESSARY ARRANGEMENTS WITH THE SCHOOL DISTRICT AUTHORIZED REPRESENTATIVE FOR ACCESS TO GROUNDS AND REMOVAL OF EQUIPMENT IF NECESSARY.
2. THIS CONTACT SHALL BE MADE AT LEAST 48 HOURS PRIOR TO DELIVERY OF AN MODULE.
3. ON-SITE INSPECTION SHALL BE DONE BY THE SITE INSPECTOR. ALL WORK WHICH THE MANUFACTURER OR HIS SUBCONTRACTORS PERFORM AT THE SITE SHALL BE SUBJECT TO THE INSPECTION OF THE SITE INSPECTOR. THE MANUFACTURER WILL FURNISH THE SITE INSPECTOR WITH SUCH INFORMATION AS MAY BE NECESSARY TO KEEP HIM FULLY INFORMED AS TO PROGRESS OF WORK AND DATES WHEN SITE WORK WILL OCCUR. THE CONTRACTOR SHALL NOTIFY THE INSPECTION AGENCY AT LEAST 48 HOURS PRIOR TO COMMENCING WORK.
4. THE CONTRACTOR SHALL VERIFY THAT THE DISTRICT'S SITE IS READY TO RECEIVE THE CLASSROOM(S) PRIOR TO THE DELIVERY OF ANY CLASSROOM(S) BY VISITING EACH SITE (THIS MAY BE DONE BY THE INSPECTOR).

Table with 2 columns: NO. and DATE. Header: REVISIONS. Description: NO. DATE DESCRIPTION

Table with 2 columns: DATE and SERIAL NO. Header: DATE: 12/20/04. Description: SCALE: NOTED. DRAWN BY: RL. SERIAL NO.:

CUSTOMER: 2:12 PITCHED ROOF 24' x 40' GENERAL NOTES RELOCATABLE BUILDINGS

AMERICAN MODULAR SYSTEMS INC. 787 Speckle Ave, Valencia, CA 91356 (209)825-1921 Fax (209)825-7018 americanmodular.com



IDENTIFICATION STAMP DIV OF THE STATE ARCHITECT APR03 11 28 8 5 AC: WLS: ZC SS: ZSC DATE: 3-24-2012 IDENTIFICATION STAMP DIV OF THE STATE ARCHITECT OFFICE OF REGULATION SERVICES APR03 11 28 8 5 AC: FLS: SS: DATE: PROJECT NO. N1