


ORDIZ MELBY

ARCHITECTS, INC.

5500 MING AVENUE SUITE 280
BAKERSFIELD, CALIFORNIA 93309
TELEPHONE (861) 832-5258
FACSIMILE (861) 832-4291



Danny E. Ordiz
DANNY E. ORDIZ, AIA
ARCHITECT C-14,728
WILLIAM J. MELBY, AIA
ARCHITECT C-16,835

IDENTIFICATION STAMP
DIV. OF THE STATE ARCHITECT
APPROX 116318
ACQ/FLS/SS/EX
DATE 051215

9 RELOCATABLE CLASSROOM BUILDINGS FOR:

CURRAN MIDDLE SCHOOL
1116 LYMRIC WAY
BAKERSFIELD, CA 93309
FOR:

BAKERSFIELD CITY
SCHOOL DISTRICT
1300 BAKER STREET
BAKERSFIELD, CA 93305

MARK	DATE	DESCRIPTION

JOB NUMBER:
1508.00
CAD DRAWING FILE:
1508 NINE New Portables - CD16.pl
DRAWN BY:
AC
CHECKED BY:
KT
CHECK AND VERIFY ALL DIMENSIONS BEFORE
PROCEEDING WITH THE WORK.
REPORT DISCREPANCIES TO THE ARCHITECT.
THE DRAWINGS, IDEAS, AND DESIGNS
REPRESENTED ON THIS SHEET ARE THE
PROPERTY OF THE ARCHITECT.
COPYRIGHT
ORDIZ-MELBY ARCHITECTS, INC. 2010

SHEET TITLE PARTIAL SITE DATA/COMM. PLAN

SHEET IDENTIFICATION NUMBER
E-3
SHEET OF

JMPE
ELECTRICAL ENGINEERING
LIGHTING DESIGN
CA REGISTRATION NO. E13083
14346
5500 MING AVENUE,
SUITE 280
BAKERSFIELD, CA 93309
(805) 832-7951
FAX (805) 832-7913
email: maloney@jmpe.net
www.jmpe.net



(E) ENTRANCE SIGNAGE PER
A# 03-107003[1]

BUILDING 'B'
A#10168 / 03-107003[1]

BUILDING 'A'
A#10168 / 03-107003[1]

(E) STUDENT
RESTROOMS
A# 03-107003[1]

BUILDING 'C'
A#10168 / 03-107003[1]

(E) HI-LO
DRINKING
FOUNTAIN

BUILDING 'D'
A#10168 / 03-107003[1]

(E) STAFF
UNISEX R.R.
A# 03-107003[1]

BUILDING 'E'
A#10168 / 03-107003[1]

(E) STUDENT
RESTROOMS
A# 03-107003[1]

BUILDING 'F'
A#10168 / 03-107003[1]

BUILDING 'G'
#10168 / 03-107003[1]

R-1.A
A#17766
03-107003[1]

R-1.B
A#17766
03-107003[1]

R-1.C
A#17766
03-107003[1]

R-1.D
A#17766
03-107003[1]

(N) IDF
(2) 2" C. W/ () CAT5E (2) 369 CABLES

R-2.A
R-2.B
R-2.C
R-2.D

R-3.A
R-3.B
R-3.C
R-3.D

(E) PANEL "R-26"

(N) 2" C. W/ () CAT5E
(N) 2" C. W/ () CAT5E

(N) IDF
(2) 2" C. W/ () CAT5E (2) 369 CABLES

R-2.A
R-2.B
R-2.C
R-2.D

R-3.A
R-3.B
R-3.C
R-3.D

(E) PANEL "R-26"

ASSUMED PROPERTY LINE

(E) CONCRETE

NEW FIRE
HYDRANT

SEE DETAIL @ SHEET E-0.1

2" C./SLEEVE TYPICAL
AREA 3

PARTIAL SITE DATA/COMM. PLAN

SCALE: 1"=30'-0"



JMPE/JOB#14346/DATE:11-13-14 AC