

KEY NOTES ROOF OVERHANG HVAC UNIT (HV) 2 MODLINE (M) 3 FINISH FLOORING (FIN) 5 INTERIOR FINISH (FIN) 6 ELECTRICAL PANEL EL 7 NOT USED FIRE EXTINGUISHER - 5 POUNDS DRY CHEMICAL WITH 2A - 10BC UL RATING ON WALL MTD BRACKET, HANDLE AT 48" AFF 8 RAMP/LANDING RAMP SIGNAGE PROVIDED AND INSTALLED BY DISTRICT PRIOR TO OCCUPANCY. 5/A5.01 WATER POC 12 SEWER POC NOTES 1. PLACE (2) PERMANENT METAL IDENTIFICATION LABELS ON EACH MODULE (1) LABEL AT REAR EXTERIOR AND (1) LABEL ABOVE CEILING LINE AT INTERIOR FRAME. LABELS WILL BE MECHANICALLY FASTENED AND SHOW THE DSA APPLICATION NUMBER, MANUFACTURERS NAME AND SERIAL NUMBER, DESIGN LIVE LOAD FOR ROOF AND FLOOR FRAMING, WIND SPEED AND EXPOSURE CATEGORY. INSULATION MATERIALS INSTALLED WITHIN FLOOR/CEILING ASSEMBLIES, ROOF-CEILING ASSEMBLIES, WALLS, CRAWL SPACES OR ATTICS SHALL HAVE A FLAME SPREAD RATING NOT TO EXCEED 25 AND A SMOKE DENSITY NOT TO EXCEED 450. EXCEPTIONS: (1) FOAM PLASTIC INSULATION SHALL COMPLY WITH SECTION 2602 (2) WHEN MATERIALS ARE INSTALLED IN CONCEALED SPACES OF TYPES III, IV, AND V CONSTRUCTION, THE FLAME SPREAD AND SMOKE-DEVELOPED LIMITATIONS DO NOT APPLY TO FACINGS IF THE FACING IS INSTALLED IN SUBSTANTIAL CONTACT WITH THE UNEXPOSED SURFACE OF THE CEILING, FLOOR OR WALL FINISH (CBC SECTION 707.3) (3) CELLULOSE LOOSE FILL INSULATION SHALL COMPLY WITH CPSC 16 CFR PARTS 1209 AND 1404 INTERIOR SIDE WALLS MAY BE LOCATED ON EITHER SIDE OF MODLINE 4. DISTRICT TO PROVIDE OCCUPANT LOAD SIGN PRIOR TO OCCUPANCY. 1153, 4161, 420 FICATION STAMP STATE ARCHITECT 03 $(24' \times 40')$ SCALE: 1/4'' = 1'-0''Oststast STKP-62 PROJECT NUMBER: 4134, 4153, 4173, 4203 C MODTECH, INC. 2001 4207, 4215 4250, 4284, 4302, 4350 4304, 4347, 4373, 4422 4506 DRAWN BY: M. ANDERSEN DATE: APR 15 2002 CHECKED BY: 4012-12. DATE: 04-16-02 MODIECH Index No. FLOOR PLAN 24'x40' STANDARD/COMP LAB AI.