



1. MAIN RUNNERS @ 47.0" O.C. WITH HANGER WIRES SPACED @ 47.0" O.C.

2. MAIN RUNNER: DONN CORP. DX-26 HEAVY DUTY

3. CROSS RUNNER: DONN CORP. DX-216 HEAVY DUTY

4. WALL RUNNER: DONN CORP. H7-EV

5. TYPICAL HANGER WIRE TO BE 1/2 GA. STEEL WIRE ATTACHED TO STRUCTURE ABOVE AND TO GRID WITH CLEBS THICKER THAN (4) TIGHT WRAPS IN 1-1/2". SEE DETAIL 4.

6. TYPICAL SPLAY WIRE TO BE 12 GA. STEEL WIRE ATTACHED TO STRUCTURE ABOVE AND TO GRID WITH CLEBS THICKER THAN (4) TIGHT WRAPS IN 1-1/2". SEE DETAIL 4.

7. AT END OF ROWS OF RUNNERS, A HANGER WIRE SHALL BE ATTACHED WITHIN 8" OF ANY WALL OR SOFFIT.

8. VERTICAL WIRES MORE THAN 1/4 OUT OF PLUMB SHALL HAVE COUNTERBRACING WIRES INSTALLED.

9. RUNNERS MAY BE ATTACHED TO WALL HOLDING AT (2) ADDING WALLS; AT OTHER WALLS NO ATTACHMENT. WHERE THERE IS NO ATTACHMENT, THERE SHALL BE A 1/2" CLEARANCE BETWEEN END OF RUNNER AND FACE OF WALL.

10. PLACE SETS OF BRACKETS AT SPACING NOT MORE THAN 12" ON CENTER AS INDICATED ON CEILING PLAN. SPLAY WIRE SHALL BE TAUT BUT SHALL NOT DISTORT GRID.

11. ELECTRICIAN SHALL PROVIDE 12 GA. SLACK HANGER WIRES AT OPPOSITE CORNERS OF ALL LIGHT FIXTURES. WIRES SHALL BE ATTACHED TO STRUCTURE ABOVE PER NOTE 5. LIGHT FIXTURES SHALL BE ATTACHED TO CEILING GRID WITH (2) #8 SHEET METAL SCREWS. ALL LIGHT FIXTURES TO STRUCTURE ABOVE SHALL BE RIGIDLY ATTACHED TO STRUCTURE ABOVE AT INTERVALS NOT TO EXCEED 4'. BRACKETS SHALL BE MAX. 3/4" DEPTH. MAX. 1/2" AND SHALL NOT BE CLOSER THAN 1" TO ANY WIRE. MAX. SPACING SHALL BE MAX. 3/4" DEPTH. MAX. 1/2" AND SHALL NOT BE CLOSER THAN 1" TO ANY WIRE. MAX. SPACING SHALL BE MAX. 3/4" DEPTH. MAX. 1/2"

12. DUCTWORK IF REQUIRED SHALL BE RIGIDLY ATTACHED TO STRUCTURE ABOVE AT INTERVALS NOT TO EXCEED 4'. BRACKETS SHALL BE MAX. 3/4" DEPTH. MAX. 1/2" AND SHALL NOT BE CLOSER THAN 1" TO ANY WIRE. MAX. SPACING SHALL BE MAX. 3/4" DEPTH. MAX. 1/2"

13. CEILING REGISTERS, WHEN INDICATED ON PLANS, SHALL BE ATTACHED TO STRUCTURE ABOVE PER NOTE 5.

14. CONTINUOUS WALL ANGLE WITH POP RIVET TO EACH MEMBER.

15. CONTINUOUS WALL ANGLE

16. 6 d NAIL @ 16" O.C. INTO BLOCK OR STUD

17. NOT USED

18. ROOF JOIST- SEE SHEET 5.

19. RIDGE BEAM- SEE SHEET 5

20. CLOSE OFF CROSS TEE- INSERT ONE END OF CROSS TEE INTO MAIN RUNNER AND ATTACH TO OPPOSITE END. BRID OVER END OF TEE AND ATTACH TO MAIN RUNNER WITH (2) #8 SHEET METAL SCREWS.

21. VERTICAL BRACE - 1/2" STEEL CONDUIT AT SPLAY WIRE LOCATIONS. DRILL 1/8" HOLE THRU CONDUIT AND MAIN RUNNER AND INSTALL 12 GA WIRE W/ 3 TIGHT TURNS. ATTACH CONDUIT TO JOISTS ABOVE W/ (2) #8 SCREWS.