



- METAL SUSPENSION SYSTEMS FOR LAY IN PANEL CEILING.**
- 12 GA. (MIN) HANGER WIRES MAY BE USED FOR UP TO AND INCLUDING 4'-0" x 4'-0" GRID SPACING, ALONG MAIN RUNNER. SPLICES WILL NOT BE PERMITTED IN ANY HANGER WIRES UNLESS SPECIFICALLY APPROVED BY OSA/SSS.
  - PROVIDE 12 GA. HANGER WIRES WITHIN 6" OF THE ENDS OF ALL MAIN AND CROSS RUNNERS OR AT 1/4 OF THE LENGTH OF THE END TEE, WHICHEVER IS LESS AT THE PROVIDE TRAPEZOID OR OTHER SUPPLEMENTARY SUPPORT MEMBERS AT OBSTRUCTIONS TO MAIN HANGER BRACES AS REQUIRED AT ALL CEILING BREAKS, SOFFITS OR DISCONTINUOUS AREA. HANGER WIRES THAT ARE MORE THAN 1 IN 6 OUT OF PLUMB ARE TO HAVE COUNTERBRACED CEILING GRID MEMBERS MAY BE ATTACHED TO NOT MORE THAN 6 IN. OF ADJACENT WALLS. CEILING GRID MEMBERS SHOULD BE AT LEAST 1/2 INCH FREE OF OTHER WALLS. IF WALLS ARE UNDESIRABLE TO CEILING GRID SYSTEM RUNNERS, ONE END OF MAIN AND CROSS RUNNERS SHOULD BE FREE AND A MINIMUM OF 1/2 INCH CLEAR OF WALL.
  - AT THE PERIMETER OF THE CEILING AREA WHERE MAIN OR CROSS RUNNERS ARE NOT CONNECTED TO THE ADJACENT WALL, PROVIDE INTERCONNECTION BETWEEN THE RUNNERS AT THE FREE END TO PREVENT LATERAL SPREADING. A METAL STRUT OR A 1/8 GA. WIRE WITH A POSITIVE MECHANICAL CONNECTION TO THE RUNNERS MAY BE USED. WHERE THE PERPENDICULAR DISTANCE FROM THE WALL TO THE FIRST PARALLEL RUNNERS IS 12" OR LESS, THIS INTERLOCK IS NOT REQUIRED.
  - PROVIDE SETS OF 4-#12 GA. SPAYED BRACING WIRES ORIENTED 90 DEGREES FROM EACH OTHER AT THE FOLLOWING SPACING:
    - (A) FOR SCHOOL BUILDINGS, PLACE SETS OF SPAY WIRE AT 12 FEET ON CENTER.
    - (B) PROVIDE SPAY WIRES AT LOCATIONS NOT MORE THAN 1/2 THE ABOVE SPACING FROM EACH PERIMETER WALL OR AT SCHOOL AND HOSPITAL BUILDINGS.
  - THE SLOPE OF THESE WIRES SHOULD NOT EXCEED 45 DEGREES FROM THE PLANE OF THE CEILING AND SHOULD BE TIGHT WITHOUT CAUSING PERMITTED WITHOUT SPECIAL OSA/SSS APPROVAL.
  - FASTEN HANGER WIRES WITH NOT LESS THAN 3 TIGHT TURNS. FASTEN SPAY WIRES WITH 4 TIGHT TURNS. MAKE ALL TIGHT TURNS WITH AN OVERLAP OF 1/2 INCHES. HANGER OR BRACING WIRE ANCHORAGE TO THE STRUCTURE SHOULD BE INSTALLED IN SUCH A MANNER THAT THE DIRECTION OF THE WIRE ALONGS AS CLOSELY AS POSSIBLE WITH THE DIRECTION OF THE FORCES ACTING ON THE WIRE.
  - SEPARATE ALL CEILING HANGING AND BRACING WIRES AT LEAST 6 INCHES FROM ALL UNBRACED BUCKS, SPECS, CONDUIT, ETC. IT IS ACCEPTABLE TO ATTACH LIGHT-WIRE-TIGHT TURNS TO A SINGLE ELECTRICAL CONDUIT NOT EXCEEDING 2 1/4" NOMINAL DIAMETER, TO HANGER WIRES USING CONNECTORS ACCEPTABLE TO OSA/SSS.
  - ATTACH ALL LIGHT FIXTURES AND AIR TERMINALS TO THE CEILING GRID RUNNERS TO RESIST A HORIZONTAL FORCE EQUAL TO THE WEIGHT OF THE FIXTURES.
  - FLUSH OR RECESSED LIGHT FIXTURES AND AIR TERMINALS OR SERVICES WEIGHING LESS THAN 56 POUNDS MAY BE SUPPORTED DIRECTLY ON THE RUNNERS OF A HEAVY DUTY GRID SYSTEM. BUT, IN ADDITION, THEY MUST HAVE A MINIMUM OF 3-#12 GA. SLACK SAFETY WIRES ATTACHED AT DIAGONAL CORNERS AND ANCHORED TO THE STRUCTURE ABOVE.
  - CLASSIFICATION OF CEILING GRID IS "HEAVY DUTY" CHROME METALLIC, PER ASTM C835.
  - MANUFACTURER'S CATALOG NUMBER - MAIN RUNNER HEAVY DUTY MAIN TEE OR EQUAL #244-5042710-01
  - MANUFACTURER'S CATALOG NUMBER - CROSS RUNNER CHROME METALLIC 1254-01 CROSS TEES, OF DIMEN. 2-D-2-1/2
  - MANUFACTURER'S CATALOG NUMBER OF DETAIL FOR RUNNER SPICE N/A.
  - ACOUSTICAL PANELS SHALL BE 5/8" MINIMUM THICK, MINERAL FIBERBOARD OR VINYL-FACED FIBERGLASS LAM-IN PANELS, SQUARE SIZE, LIGHT REFLECTION 75% MINIMUM, NOISE REDUCTION COEFFICIENT OF 0.85 MINIMUM. MAXIMUM SMOKE DENSITY NOT TO EXCEED 450.

NOTE: SPAYED BRACING WIRES SHALL BE SPACED NOT MORE THAN 12 FT. ON CENTER.

ATTACHMENT FOR CEILING GRID DETAIL

NO SCALE

3

NOTE: METAL SUSPENSION SYSTEMS FOR LAY IN PANEL CEILING. WALL AT ENDS OF HORIZ. STRUTS ARE TO BE PLACED WITH WALL TOWARD OF SPAN OF STRUT.

FIXED END

ALTERNATE

FREE END

MODULE LINE "T" GRID

WIRE CONNECTIONS TO GRID

NO SCALE

3

CONNECTIONS TO WOOD JOISTS OR RAFTERS

DETAIL

NO SCALE

3

CEILING TEE BAR GRID LAYOUT WITH LIGHT FIXTURES

SCALE: 1/4"=1'-0"

36 X 40

HEAD START

AMERICAN Modular Systems

CUSTOMER: HEADQUARTERS

DATE: 1-17-84

SCALE: NONE

DRAWN BY: AS

CHECKED BY:

SERIAL NO: 84-R100-001 A,B,C

CEILING GRID, DETAILS AND NOTES

NO.	DATE	DESCRIPTION	NO.	DATE	DESCRIPTION
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					