



- ### KEY NOTES
- 1 ROOF OVERHANG
 - 2 HVAC UNIT [HV]
 - 3 2- 8'X4' MARKER BOARDS (SEE SPEC'S. FOR TYPE)
 - 4 FINISH FLOORING: (SEE FINISH SCHED.) A5.0
 - 5 TYPICAL INTERIOR FINISH (SEE FINISH SCHEDULE) A5.0
 - 6 FIRE EXTINGUISHER - 5 LBS. DRY CHEMICAL WITH 2A-10BC U.L. RATING ON WALL MTD. BRACKET. HANDLE AT 48" A.F.F.
 - 7 MODLINE (M. TYPICAL)
 - 8 RAMP (SEE R1.0 & R2.0)

- ### NOTES
1. METAL TAG ON ALL MODULES. MECHANICALLY ATTACHED TO REAR EXTERIOR OF BUILDING. SHOW D.S.A. APPLICATION NUMBER, MANUFACTURER'S NAME AND SERIAL NUMBER, ROOF & FLOOR DESIGN LIVE LOAD, AND DESIGN WIND LOAD.
 2. INSULATION MATERIALS INSTALLED WITHIN FLOOR-CEILING ASSEMBLIES, ROOF-CEILING ASSEMBLIES, WALLS, CRAWL SPACES, OR ATTICS SHALL HAVE A FLAMESPREAD RATING NOT TO EXCEED 25 AND A SMOKE DENSITY NOT TO EXCEED 450. EXCEPTIONS: 1. FOAM PLASTIC INSULATION SHALL COMPLY WITH SEC. 2602 2. WHEN MATERIALS ARE INSTALLED IN CONCEALED SPACES OF TYPES I, II, IV, AND V CONSTRUCTION, THE FLAME SPREAD AND SMOKE-DEVELOPED LIMITATIONS DO NOT APPLY TO FACINGS IF THE FACING IS INSTALLED IN SUBSTANTIAL CONTACT WITH THE UNEXPOSED SURFACE OF THE CEILING, FLOOR OR WALL FINISH. (SEC. 707.3 CBC.)

~~REVISED~~

MAY 20 1999

MAY 20 1999

A-SHOWN
B-OPPOSITE

FLOOR PLAN

24' X 40'
SCALE: 1/4" = 1'

REVISIONS <table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="width: 20px;">1</td><td style="width: 50px;"> </td><td style="width: 50px;"> </td></tr> <tr><td>2</td><td> </td><td> </td></tr> <tr><td>3</td><td> </td><td> </td></tr> <tr><td>4</td><td> </td><td> </td></tr> <tr><td>5</td><td> </td><td> </td></tr> </table>	1			2			3			4			5			Electrical Engineer's Seal Mechanical Engineer's Seal Structural Engineer's Seal Architects Seal	IDENTIFICATION STAMP DIV. OF THE STATE ARCHITECT OFFICE OF REGULATION SERVICES APPL. _____ AC. _____ FLS. _____ SS. _____ DATE _____	<p>MODTECH INC. 2830 BARRETT AVENUE PERRIS, CALIF. 92572 PH (909) 943-4014 FAX (909) 940-0427</p>	PROJECT NUMBER: XXXX © MODTECH, INC. 1998	DRAWN BY: --- DATE: --- CHECKED BY: --- DATE: --- MODTECH PROJECT NO: XXXX MODTECH Index No. <h1 style="font-size: 2em; margin: 0;">A1.0</h1>
1																				
2																				
3																				
4																				
5																				
FLOOR PLAN																				

FILE PATH: -A10.DWG PROJECT NO. XXXX