



- ### KEY NOTES
- TYP. INTERIOR FINISH (SEE FINISH SCHEDULE)
 - TYPICAL EXTERIOR FINISH
 - 1/2" GYPSUM BOARD BACKING W/ 7d COOLER NAILS AT MAX 7" O.C. TYP. AT EA. STUD
 - 2X4 STUD TYP. AT 16" O.C. MAX.
 - CORNER MOLD
 - 26GA SHEET METAL FLASH 2" X 4" X LENGTH
 - TUBE STEEL COLUMN SEE **STR**
 - SEALANT TYP. (SEE SPECS.) **BA** SEALANT BEHIND TRIM
 - #10 S.T.S.M.S. AT MAX. 24" O.C. (ALT. HILTI 0.145 SHOT PIN) 2X FILLER TO COLUMN
 - VINYL CLOSURE
 - MODULE JOINT
 - 16d AT 24" O.C. FACE NAIL OR 16d AT 12" O.C. TOE NAIL (SEE SHEET S5.1)
 - FLOOR BEAM SEE **STR**
 - PRESSED STEEL FRAME (K.D. TYPE SEE A5.0)
 - ALUMINUM THRESHOLD (SEE HARDWARE SCHEDULE)
 - FINISH LANDING SEE FLOOR PLAN AND FOUNDATION FOR TYPE AND FINISH
 - DOOR BOTTOM (SEE HARDWARE SCHEDULE)
 - (2) 2X4 KING STUD (SEE SHEET S5.0)
 - 2X4 TRIMMER (SEE SHEET S5.0)
 - "Z" MOLD 26GA
 - 1X4 WOOD TRIM W/ Bd ELECTRO GALV. AT 12" O.C.
 - (2) 2X4 SILL PLATE W/ 16d AT 16" O.C.
 - INSULATION (SEE SPECS. FOR SIZE AND TYPE)
 - FINISH FLOORING (SEE FINISH SCHEDULE SHEET A5.0)
 - 2X4 JAMB STUDS (SEE SHEET S5.0) DETAILS FOR NUMBER OF STUDS REQUIRED AND NAILING SCHEDULE FOR NAILING
 - WINDOW GLAZING (SEE WINDOW SCHEDULE SHEET A5.0)
 - 2X6 LET IN (SEE WALL FRAMING SHEET S5.0)
 - ALUMINUM WINDOW FRAME WITH NAIL-ON FINISH. INSTALL W/ MIN. 3" BLDG. PAPER BETWEEN FINISH AND FRAMING. INSTALL WITH 8d AT MAX. 24" O.C.
 - 16d BOX STAGGERED AT MAX 24" O.C.
 - HEADER 12/S5.0
 - DOOR (SEE DOOR SCHEDULE) A5.0
 - 6-3/8" x 2" GALVANIZED LAG SCREWS
 - L 1-1/2"x1-1/2"x1/8"x18" LONG (BY HVAC MFR.) ATTACHED TO A/C W/ 4-#10 SELF TAPPING SHEET METAL SCREWS AND ATTACH TO WALL W/ 3" x 2" GALVANIZED LAG SCREWS
 - SIDE OF HVAC UNIT SEE **HW**
 - (3) 2X4 W/ PLYWOOD SPACER- BUILT- UP POST. Bd AT O.C. STAGGERED SPACER TO FIRST 2X4 16d AT 12" O.C. SECOND 2X4 12d AT 12" O.C. STAGGERED THIRD 2X4 ALTERNATE USE 4X4 POST
 - 11GA. X24" STEEL SUPPORT BRACKET
 - EN - Bd BOX ELECTRO GALV. AT 6" O.C.
 - FN - Bd BOX ELECTRO GALV. AT 12" O.C.

JUL 1 1999
 REVISED
 IDENTIFICATION STAMP
 DIV. OF THE STATE ARCHITECT
 OFFICE OF REGULATION SERVICES
 04 101527
 DATE SEP 02 1999

- ### NOTES
- EN Bd ELECTRO GALV. AT 6" O.C.
 - FN Ed ELECTRO GALV. AT 12" O.C.
 - SEE SHEET S5.0 FOR TYPICAL WALL FRAMING NAILING
- INSULATION MATERIALS INSULATED WITHIN FLOOR-CEILING ASSEMBLIES, ROOF-CEILING ASSEMBLIES, WALLS, CRAWL SPACES, OR ATTICS SHALL HAVE A FLAMESPREAD RATING NOT TO EXCEED 25 AND A SMOKE DENSITY NOT TO EXCEED 450. EXCEPTIONS:
 A: FOAM PLASTIC INSULATION SHALL COMPLY WITH SEC. 2602
 B: WHEN MATERIALS ARE INSULATED IN CONCEALED SPACES OF TYPES I, II, IV, AND V CONSTRUCTION, THE FLAME SPREAD AND SMOKE-DEVELOPED LIMITATIONS DO NOT APPLY TO FACINGS. IF THE FACING IS INSTALLED IN SUBSTANTIAL CONTACT WITH THE UNEXPOSED SURFACE OF THE CEILING, FLOOR OR WALL FINISH. (SEC. 707.3 CBC)

REVISIONS

Electrical Engineer's Seal
 Mechanical Engineer's Seal
 Structural Engineer's Seal
 Architect's Seal

IDENTIFICATION STAMP
 DIV. OF THE STATE ARCHITECT
 OFFICE OF REGULATION SERVICES
 PC - 270
 AC. 101527
 DATE SEP 02 1999
 REVISED

MODTECH INC.
 2830 BARRETT AVENUE
 PERRIS, CALIF. 92572
 PH (909) 943-4014
 FAX (909) 940-0427

PROJECT NUMBER: _____
 © MODTECH, INC. 1999

DRAWN BY: RVF
 DATE: 2-2-98
 CHECKED BY: [Signature]
 DATE: 2/1/98
 MODTECH PROJECT NO:
 MODTECH Index No.

ARCHITECTURAL DETAILS

A6.0

FILE PATH: PC270A60.DWG PROJECT NO. PC-270