

REFLECTED CEILING PLAN (24'X40')

SCALE 1/4" = 1'

KEY NOTES

- 1 MAIN RUNNERS @ 4'-0" W/12GA HANGER WIRES @ END OF EACH RUNNER
- 2 AT THE END OF ROWS OF RUNNERS A 12GA HANGER WIRE SHALL BE ATTACHED WITHIN 8" OF WALL OR SOFFIT
- 3 VERTICAL WIRES MORE THAN 1'-IN-6" OUT OF PLUMB SHALL HAVE COUNTERBRACING WIRES
- 4 PROVIDE 2-12GA SLACK WIRES TO HOUSING OF ALL LIGHT FIXTURES AT DIAGONAL CORNERS. WIRES SHALL BE ATTACHED TO STRUCTURAL OF LIGHT FIXTURES RECESSED. ATTACH FIXTURE TO GRID W/1-#8 (111) METAL SCREW AT EACH CORNER
- 5 RUNNERS MAY BE ATTACHED TO WALLS OR MOLD AT 2-ADJACENT WALLS. OTHER WALLS NO ATTACHMENT. CLEARANCE OF 1/2" BETWEEN END OF RUNNERS AND FACE OF WALL
- 6 CEILING ARTAS SHALL HAVE 2/4-WAY SPLAYS PER DETAIL 1 ON SHEET A7.1 IN LOCATIONS INDICATED ON DRAWINGS. WIRES TAUT BUT NOT TO DISTORT GRID

7 T-BAR PART NUMBERS

	ARMSTRONG PA-041		
RUNNER MAIN	7301D		
4' CROSS TEE	7343		
2' CROSS TEE	732B		
WALL ANGLE	7800D		

- 8 DUCTWORK SHALL BE RIGIDLY ATTACHED TO BUILDING AND SHALL NOT BE CLOSER THAN 6" TO HANGER WIRES
- 9 REGISTERS SHALL BE POSITIVELY ATTACHED W/4-10#4 SHEET METAL SCREWS (TYP 1- AT EACH CORNER)
- 10 CEILING PANELS 2910

~~REVISED~~

RPS
JUL 1 1999

REGISTRATION STAMP
DIV. OF THE STATE ARCHITECT
OFFICE OF REGULATION SERVICES
101527
04 10 1999
MAY 20 1999

LEGEND

- 1 & 1 BAR CEILING
- 2 X 4 ELEC FIXTURE RECESS
- SUPPLY AIR DIFFUSER
- RETURN AIR DIFFUSER
- SPLAY WIRE 4 WAY
- INDICATES FIXED SIDE (SEE DETAIL 7/A7.1)
- INDICATES FREE SIDE (SEE DETAIL 6/A7.1)


REVISIONS

Electrical Engineer's Seal
Mechanical Engineer's Seal

Professional Engineer Seal
STATE OF CALIFORNIA
02 08 99

Architect's Seal

Division of the State Architect
REGISTRATION STAMP
OFFICE OF REGULATION SERVICES
PC-270
FEB 19 1999



MODTECH INC
2830 BARRETT AVENUE
PERRIS, CALIF 92572
PH (909) 943-4014
FAX (909) 940-0427

PROJECT JMBF

© MODTECH INC 1999

DRAWN BY RVP
DATE 2-2-99
CHECKED BY SSS
DATE
MODTECH PROJECT NO
MODTECH Index No
A7.0

REFLECTED CEILING PLAN

FILE PATH

PROJECT NO
PC-270