



NORTH
SCALE - 1/8" = 1'-0"

TYPICAL AUTOMATIC PRESSURE RELIEF DAMPER
SCALE - 3/4" = 1'-0"

SECTION THRU UNIT VENTILATOR
SCALE - 3/4" = 1'-0"

TYPICAL DETAILS - UNIT VENTILATORS

PIPING CONNECTIONS AT UNIT VENTILATOR
NO SCALE

ISOMETRIC PIPING LAYOUT BOILER ROOM
NO SCALE

SECTION X-Y THRU BOILER ROOM
SCALE - 1/2" = 1'-0"

DETAIL OF BOILER STACK THIMBLE
SCALE - 1/2" = 1'-0"

PUMP SCHEDULE

PUMP NO.	CAPACITY	HEAD	MOTOR DATA
PUMP-1	42 GPM	47 FT.	1 HP 208V, 50/60, 3450RPM.
PUMP-2	18 GPM	29 FT.	1/4 HP 115V, 15/50, 1750RPM.
PUMP-3	24 GPM	22 FT.	1/4 HP 208V, 50/60, 1750RPM.
PUMP-4	20 GPM	29 FT.	1/4 HP 208V, 50/60, 1750RPM.
PUMP-5	18 GPM	35 FT.	1/4 HP 208V, 50/60, 1750RPM.
PUMP-6	10 GPM	46 FT.	1/4 HP 208V, 50/60, 3450RPM.

531
19 3-11-54
239
W. A. STAINS
CONSULTING ENGINEER
1414 S. CALIFORNIA AVENUE
PASADENA, CALIFORNIA

W. A. STAINS
CONSULTING ENGINEER
1414 S. CALIFORNIA AVENUE
PASADENA, CALIFORNIA

DIVISION OF ARCHITECTURE
ARCHITECTURE
PRES.
SEC.

BOARD OF EDUCATION
HTG. & VENTILATING PLANS
ADMINISTRATION UNIT
CLASSROOMS

WILLIAM PENN SCHOOL
BAKERSFIELD CALIFORNIA

WHITNEY BIGGAR ARCHITECT
MEMBER AMERICAN INSTITUTE OF ARCHITECTS
3601 STOCKDALE HIGHWAY
BAKERSFIELD, CALIFORNIA
29285 REGISTRATION C-1128

PROJECT NO. 2-54
DRAWN BY: J.R.
CHECKED BY:
DATE: 2-23-54
SHEET
of 4