



HEATING & VENTILATING SCHEDULE									
SYMBOL	DESCRIPTION	CAPACITY	TOTAL	OUTSIDE	ELECTRICAL	CHARACTERISTICS	REMARKS		
		CFM	CFM	CFM	WATTS	TYPE			
1	UNIT HEATER	100,000 B.T.U./HR.	800	100	1/2	1	60		
2	UNIT VENTILATOR	17,600 B.T.U.	400	100	1/2	1	60		
3	UNIT VENTILATOR	60,000 B.T.U.	1000	250	1/2	1	60		
4	UNIT VENTILATOR	50,000 B.T.U.	1000	250	1/2	1	60		
5	HOOD EXHAUST	56 GPM @ 115	1350	1/2	1/2	1	60		
6	CIRC. PUMP	34 GPM @ 115	1/2	1/2	1	60			
7	CIRC. PUMP	15 GPM @ 110 HP	1/2	1/2	1	60			
8	H.W. BOILER	2250 B.T.U.	3740 B.T.U.	1/2	1/2	1	60		
9	H.W. BOILER	940 B.T.U.	2250 B.T.U.	1/2	1/2	1	60		
10	EXP. TANK	47 GAL. CAP.	60 GAL. CAP.						
11	BALANCING COCK								
12	WALL HEATER	25,000 B.T.U./HR.	100	3/4	115	1	60	DELETED	
13	COMPRESSOR	8,500 B.T.U./HR.	100	1/5	115	1	60	DELETED	
14	EXHAUST BLOWER		100	1/5	115	1	60	DELETED	
15	EXHAUST BLOWER		100	1/5	115	1	60	DELETED	
16	WALL HEATER	25,000 B.T.U./HR.	100	3/4	115	1	60	DELETED	
17	COMPRESSOR	8,500 B.T.U./HR.	100	1/5	115	1	60	DELETED	
18	EXHAUST BLOWER		100	1/5	115	1	60	DELETED	
19	EXHAUST BLOWER		100	1/5	115	1	60	DELETED	
20	EXHAUST BLOWER		100	1/5	115	1	60	DELETED	
21	EXHAUST BLOWER		100	1/5	115	1	60	DELETED	
22	EXHAUST BLOWER		100	1/5	115	1	60	DELETED	



OFFICE OF SUPERINTENDENT OF SCHOOLS
 STATE OF CALIFORNIA
 DEPARTMENT OF PUBLIC WORKS
 DIVISION OF ARCHITECTURE

APPROVED DATE 11-11-53

STATE OF CALIFORNIA - DEPARTMENT OF PUBLIC WORKS
 DIVISION OF ARCHITECTURE
 APPROVED DATE 11-11-53

BAKERSFIELD CITY SCHOOLS
 1600 N. ST. BAKERSFIELD CALIFORNIA
 BOARD OF EDUCATION

APPROVED DATE 11-11-53

ROOSEVELT ELEM. SCHOOL ADDITION
 BAKERSFIELD CITY SCHOOL DISTRICT
 2324 VERDE STREET CALIFORNIA

ERNEST L. MCCOY A. I. A. ARCHITECT
 2811 H STREET BAKERSFIELD CALIFORNIA

DATE 11-11-53
 DRAWN BY
 CHECKED BY
 SHEET NO.